

**TABULATED ANALYTICAL REPORT
QUALITATIVE GC FINGERPRINT 8015**

CLIENT: PSEG

CLIENT PROJECT : Bergen Spare 345kV - Bergen
REPORT DATE: Switch Station
10/30/20
PROJECT RECEIVED DATE : 10/29/20
ANALYSIS DATE 10/29/20
EXT. DATE: 10/29/20
MATRIX: WIPE
LAB PROJECT: L4566

| CLIENT ID | FILE ID | LAB ID | FUEL TYPE |
|------------|------------|----------|-----------|
| BS-STAIN-A | FE033078.D | L4566-04 | E |
| BS-STAIN-B | FE033080.D | L4566-05 | E |

COMMENTS:

A= GASOLINE

B= UNKNOWN FUEL OIL

C= #DIESEL FUEL OIL#2

D= #4 FUEL OIL

G= #5 FUEL OIL

H= #6 FUEL OIL

N = JET FUEL STANDARD

E= NO CALIBRATED STANDARDS DETECTED

CS= CLIENT STANDARDS(DIELECTRIC FLUID)

WM= WEATHERED MOTOR OIL

WO= WEATHERED HYDRAULIC OIL

K= 30 W LUBRICATING OIL

L= 40 W LUBRICATING OIL

M= 50 W LUBRICATING OIL

ND = NOT DETECTED (CONC)

MS= MINERAL SPIRITS

O= HYDRAULIC OIL

F=KEROSENE

CT= COAL TAR

PT= PAINT THINNER