


Batch Folder: D:\Agilent\ICPMH\1\DATA\P8051721MS.b\
Analysis File: P8051721MS.batch.bin
DA Date-Time: 2021-05-17 15:05:11
Calibration Title:
Calibration Method: External Calibration
VIS Interpolation Fit:

Level	Standard Data File	Sample Name	Acq. Date-Time
1	004CALB.d	S00	2021-05-17 14:20:28
2	006CALS.d	S01	2021-05-17 14:26:27
3	008CALS.d	S02	2021-05-17 14:32:25
4	009CALS.d	S03	2021-05-17 14:35:24
5	010CALS.d	S04	2021-05-17 14:38:24
6	011CALS.d	S05	2021-05-17 14:41:23
7	012CALS.d	S06	2021-05-17 14:44:24
8	013CALS.d	S07	2021-05-17 14:47:22
9	014CALS.d	S08	2021-05-17 14:50:22

9 Be [No Gas] ISTD:6 Li [No Gas]

	R _{ct}	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	20.66	0.0000	P	34.7
2	☐	0.100	0.097	75.99	0.0001	P	25.1
3	☐	1.000	1.014	626.56	0.0005	P	3.7
4	☐	50.000	50.126	29702.63	0.0262	P	0.9
5	☐	125.000	126.354	75622.70	0.0660	P	1.1
6	☐	250.000	248.627	149871.10	0.1298	P	4.2
7	☐	500.000	513.182	309685.53	0.2678	P	6.9
8	☐	1000.000	993.577	614006.93	0.5185	P	4.0
9	☐			196.63	0.0002	P	8.5


$$y = 5.2188\text{E-}004 * x + 1.8518\text{E-}005$$

$$R = 0.9999$$

$$DL = 0.03697$$

Weight: <None>

Min Conc: 0

10 B [No Gas] ISTD:6 Li [No Gas]

	R _{ct}	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	78.65	0.0001	P	25.8
2	☐	2.500	2.315	179.97	0.0002	P	10.1
3	☐	25.000	23.314	1146.49	0.0010	P	14.5
4	☐	50.000	46.724	2202.40	0.0019	P	6.7
5	☐	125.000	115.652	5391.94	0.0047	P	7.8
6	☐	250.000	235.646	10968.64	0.0095	P	11.8
7	☐	500.000	490.475	22741.78	0.0197	P	13.8
8	☐	1000.000	1009.726	47903.03	0.0405	P	10.9
9	☐			7105.67	0.0060	P	7.4


$$y = 4.0035\text{E-}005 * x + 7.0474\text{E-}005$$

$$R = 0.9998$$

$$DL = 1.363$$

Weight: <None>

Min Conc: 0

11 B [No Gas] ISTD:6 Li [No Gas]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	329.28	0.0003	P	11.1
2	☐	2.500	2.431	846.53	0.0008	P	7.1
3	☐	25.000	23.848	5625.32	0.0049	P	13.3
4	☐	50.000	46.140	10498.38	0.0093	P	8.8
5	☐	125.000	114.400	25816.92	0.0225	P	7.9
6	☐	250.000	236.762	53385.73	0.0463	P	11.8
7	☐	500.000	494.220	111085.24	0.0962	P	13.2
8	☐	1000.000	1007.746	231785.65	0.1959	P	11.1
9	☐			33524.20	0.0285	P	7.4


$$y = 1.9415E-004 * x + 2.9446E-004$$

$$R = 0.9999$$


$$DL = 0.5041$$

Weight: <None>


Min Conc: 0

12 C [No Gas] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			2352528.26		A	1.3
2	☐			2425904.87		A	2.2
3	☐			2480353.05		A	0.8
4	☐			2884450.47		A	2.6
5	☐			2988872.90		A	2.9
6	☐			3058309.83		A	3.4
7	☐			3174982.51		A	2.2
8	☐			3299507.45		A	2.8
9	☐			3163919.86		A	2.1

12 C [He] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			31743.23		P	2.4
2	☐			33115.65		P	0.4
3	☐			33973.26		P	1.6
4	☐			41359.03		P	2.3
5	☐			42475.80		P	2.1
6	☐			43503.80		P	1.7
7	☐			45618.58		P	0.6
8	☐			48675.56		P	1.6
9	☐			48385.76		P	1.4

23 Na [He] ISTD:45 Sc [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	17839.02	0.1212	P	3.0
2	☐	50.000	49.334	25912.36	0.1705	P	1.6
3	☐	500.000	496.083	91939.44	0.6165	P	1.5
4	☐	5000.000	5048.403	764754.55	5.1620	P	1.9
5	☐	12500.000	12523.285	1906012.20	12.6256	A	1.0
6	☐	25000.000	25958.635	3857763.15	26.0406	A	2.3
7	☐	50000.000	51527.518	7703302.08	51.5709	A	1.3
8	☐	100000.00	101637.15	15469409.37	101.6049	A	2.5
9	☐	500000.00	499470.82	76430798.24	498.8379	A	1.1


$$y = 9.9849\text{E-}004 * x + 0.1212$$

$$R = 1.0000$$

$$DL = 11.07$$

Weight: <None>

Min Conc: 0



	R _{ct}	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	602.81	0.0041	P	6.8
2	☐	50.000	46.890	4317.41	0.0284	P	7.8
3	☐	500.000	495.516	38916.28	0.2610	P	1.1
4	☐	5000.000	5036.528	387403.66	2.6149	P	1.7
5	☐	12500.000	12545.781	982413.89	6.5075	P	0.3
6	☐	25000.000	25953.786	1993837.02	13.4579	A	2.0
7	☐	50000.000	52613.777	4074571.01	27.2777	A	1.1
8	☐	100000.00	101171.78	7987418.32	52.4490	A	0.5
9	☐	500000.00	499455.07	39670078.32	258.9089	A	1.0


$$y = 5.1837\text{E-}004 * x + 0.0041$$

$$R = 1.0000$$

$$DL = 1.614$$

Weight: <None>

Min Conc: 0



	R _{ct}	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	383.29	0.0026	P	8.2
2	☒	2.000					
3	☐	20.000	21.126	992.83	0.0067	P	7.3
4	☐	1000.000	987.260	28456.99	0.1921	P	1.6
5	☐	2500.000	2457.967	71607.24	0.4743	P	1.3
6	☐	5000.000	4950.548	141119.71	0.9527	P	3.0
7	☐	10000.000	10142.164	291136.32	1.9491	P	1.6
8	☐	20000.000	19267.454	563476.07	3.7005	P	1.6
9	☐	100000.00	100135.94	2945102.41	19.2211	A	1.2

$$y = 1.9192\text{E-}004 * x + 0.0026$$


$$R = 1.0000$$

$$DL = 3.354$$

Weight: <None>

Min Conc: 0

28 Si [No Gas] ISTD : 45 Sc [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	6092033.34	1.9713	A	0.6
2	☐	10.000	-497.429	5696703.95	1.8299	A	2.0
3	☐	10.000	-486.137	5725237.37	1.8331	A	1.8
4	☐	50.000	-398.598	5764209.37	1.8580	A	0.9
5	☐	125.000	-316.651	5960567.58	1.8813	A	2.2
6	☐	250.000	-112.463	6147096.15	1.9393	A	1.6
7	☐	500.000	478.968	6579060.78	2.1074	A	4.4
8	☐	1000.000	1188.804	7371130.98	2.3092	A	0.3
9	☐			5912252.04	1.8213	A	2.6

$$y = 2.8420\text{E-}004 * x + 1.9713$$


$$R = 0.9526$$

$$DL = 125.8$$

Weight: <None>

Min Conc: 0

31 P [He] ISTD : 45 Sc [He]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	1.682	180.56	0.0012	P	27.0
2	☐	0.000	10.146	202.78	0.0013	P	14.8
3	☐	0.000	-11.828	158.34	0.0011	P	36.0
4	☐	1000.000	982.543	1986.31	0.0134	P	7.0
5	☐	2500.000	2425.264	4728.67	0.0313	P	3.9
6	☐	5000.000	4984.023	9347.71	0.0631	P	2.8
7	☐	10000.000	10541.445	19735.99	0.1321	P	1.4
8	☐	20000.000	19743.487	37524.01	0.2464	P	1.1
9	☐			202.78	0.0013	P	16.2

$$y = 1.2420\text{E-}005 * x + 0.0012$$


$$R = 0.9995$$

$$DL = 73.26$$

Weight: <None>

Min Conc: 0

34 S [No Gas] ISTD:45 Sc [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	65.554	401929.68	0.1301	P	0.8
2	☐	0.000	-222.137	401877.44	0.1291	P	0.9
3	☐	0.000	156.583	407192.66	0.1304	P	1.4
4	☐	1000.000	1476.829	418359.62	0.1349	P	1.5
5	☐	2500.000	1933.232	432187.80	0.1364	P	2.5
6	☐	5000.000	4122.564	456018.45	0.1439	P	1.5
7	☐	10000.000	10037.733	512010.02	0.1640	P	4.1
8	☐	20000.000	20247.497	634367.93	0.1987	P	1.1
9	☐			378319.89	0.1165	P	2.5

$$y = 3.4030E-006 * x + 0.1298$$


$$R = 0.9981$$

$$DL = 1201$$


Weight: <None>

Min Conc: 0


35 Cl [No Gas] No available calibration points



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			344647.25		P	1.5
2	☐			347488.08		P	1.4
3	☐			351706.82		P	0.5
4	☐			408056.59		P	1.7
5	☐			408534.69		P	2.0
6	☐			413529.68		P	2.2
7	☐			391982.28		P	1.4
8	☐			415038.84		P	1.7
9	☐			423249.26		P	2.1

35 Cl [He] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			4292.41		P	4.7
2	☐			4398.02		P	1.7
3	☐			4356.33		P	4.9
4	☐			5289.99		P	3.8
5	☐			4998.22		P	1.9
6	☐			5162.16		P	4.6
7	☐			4917.63		P	2.1
8	☐			5184.39		P	6.7
9	☐			5198.27		P	6.2

39 K [He] ISTD:45 Sc [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	34717.58	0.2359	P	3.6
2	☐	50.000	46.357	39072.99	0.2570	P	2.8
3	☐	500.000	496.711	68942.82	0.4623	P	1.8
4	☐	2500.000	2556.639	207641.69	1.4014	P	0.6
5	☐	6250.000	6319.630	470498.42	3.1169	P	2.2
6	☐	12500.000	13002.226	912926.80	6.1633	P	2.9
7	☐	25000.000	26613.578	1847507.57	12.3685	A	1.3
8	☐	50000.000	51269.015	3595501.21	23.6084	A	0.1
9	☐	250000.00	249557.42	17468027.65	114.0040	A	0.4


$$y = 4.5588\text{E-}004 * x + 0.2359$$

$$R = 1.0000$$

$$DL = 56.07$$

Weight: <None>

Min Conc: 0

43 Ca [No Gas] ISTD:45 Sc [No Gas]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	180.03	0.0001	P	8.7
2	☐	50.000	48.769	588.81	0.0002	P	2.1
3	☐	500.000	472.067	4139.66	0.0013	P	1.4
4	☐	5000.000	4105.128	34362.62	0.0111	P	1.8
5	☐	12500.000	10138.269	86376.14	0.0273	P	3.2
6	☐	25000.000	20170.368	171770.13	0.0542	P	1.6
7	☐	50000.000	42411.377	355374.96	0.1139	P	6.3
8	☐	100000.00	83074.577	711883.42	0.2230	P	0.5
9	☐	500000.00	504453.44	4396150.81	1.3539	A	0.4


$$y = 2.6837E-006 * x + 5.8260E-005$$

$$R = 0.9993$$

$$DL = 5.645$$

Weight: <None>

Min Conc: 0

44 Ca [No Gas] ISTD:45 Sc [No Gas]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	55733.03	0.0180	P	1.6
2	☒	50.000					
3	☐	500.000	434.768	115761.59	0.0371	P	0.8
4	☐	5000.000	4566.953	676003.08	0.2179	P	1.5
5	☐	12500.000	11992.179	1719983.17	0.5428	A	1.8
6	☐	25000.000	23466.590	3312061.89	1.0450	A	1.9
7	☐	50000.000	48855.576	6730922.72	2.1560	A	4.7
8	☐	100000.00	94978.124	13326032.12	4.1744	A	0.6
9	☐	500000.00	501212.57	71282077.38	21.9515	A	0.2

$$y = 4.3761E-005 * x + 0.0180$$


$$R = 0.9999$$

$$DL = 19.55$$

Weight: <None>

Min Conc: 0

47 Ti [No Gas] ISTD:45 Sc [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	219.45	0.0001	P	18.1
2	☐	0.500	0.544	466.68	0.0001	P	5.7
3	☐	5.000	4.908	2441.94	0.0008	P	6.8
4	☐	250.000	242.626	109276.22	0.0352	P	1.8
5	☐	625.000	601.325	276245.67	0.0872	P	3.1
6	☐	1250.000	1212.934	557339.92	0.1758	P	2.0
7	☐	2500.000	2539.822	1148907.99	0.3681	M	6.4
8	☐	5000.000	4992.684	2309874.20	0.7235	A	1.7
9	☐			1080.62	0.0003	P	5.3

$$y = 1.4490\text{E-}004 * x + 7.1071\text{E-}005$$


$$R = 0.9999$$

$$DL = 0.2671$$

Weight: <None>

Min Conc: 0

51 V [He] ISTD:45 Sc [He]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	26.67	0.0002	P	26.1
2	☐	0.500	0.482	478.90	0.0032	P	2.7
3	☐	5.000	5.029	4644.13	0.0311	P	2.0
4	☐	50.000	49.022	44727.48	0.3019	P	1.5
5	☐	125.000	122.226	113596.78	0.7525	P	0.4
6	☐	250.000	251.250	229104.21	1.5466	P	2.4
7	☐	500.000	510.050	468930.09	3.1395	P	1.7
8	☐	1000.000	995.058	932563.85	6.1246	P	1.8
9	☐			321.12	0.0021	P	4.4


$$y = 0.0062 * x + 1.8153\text{E-}004$$

$$R = 0.9999$$

$$DL = 0.02309$$

Weight: <None>

Min Conc: 0



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	1977.94	0.0134	P	1.7
2	☐	0.200	0.215	2289.10	0.0151	P	9.1
3	☐	2.000	2.042	4305.13	0.0289	P	0.8
4	☐	50.000	50.349	58350.75	0.3938	P	1.0
5	☐	125.000	122.396	141630.49	0.9382	P	1.0
6	☐	250.000	254.098	286349.64	1.9333	P	3.1
7	☐	500.000	513.130	581083.07	3.8904	P	1.8
8	☐	1000.000	992.719	1144038.89	7.5139	P	2.1
9	☐			9363.12	0.0611	P	0.9


$$y = 0.0076 * x + 0.0134$$

$$R = 0.9999$$

$$DL = 0.0884$$

Weight: <None>

Min Conc: 0



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	620.39	0.0042	P	10.6
2	☐	5.000	6.020	940.79	0.0062	P	9.6
3	☐	50.000	52.097	3183.74	0.0214	P	4.0
4	☐	2500.000	2528.239	123852.73	0.8360	P	2.3
5	☐	6250.000	6241.146	310610.83	2.0575	P	0.8
6	☐	12500.000	12883.513	628413.55	4.2429	P	3.3
7	☐	25000.000	26253.249	1290503.49	8.6415	M	4.2
8	☐	50000.000	52557.687	2633727.98	17.2957	A	1.5
9	☐	250000.00	249343.90	12570237.89	82.0382	A	0.9


$$y = 3.2900E-004 * x + 0.0042$$

$$R = 0.9999$$

$$DL = 4.078$$

Weight: <None>

Min Conc: 0



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	122.22	0.0008	P	9.7
2	☐	0.100	0.103	186.67	0.0012	P	16.3
3	☐	1.000	1.028	710.02	0.0048	P	13.5
4	☐	500.000	488.109	276861.99	1.8687	P	0.7
5	☐	1250.000	1196.441	691289.87	4.5792	P	0.7
6	☐	2500.000	2576.240	1460157.86	9.8592	A	3.7
7	☐	5000.000	5211.944	2979161.52	19.9452	A	1.6
8	☐	10000.000	9882.258	5758310.54	37.8169	A	1.9
9	☐			4083.96	0.0267	P	4.0


$$y = 0.0038 * x + 8.3096E-004$$

$$R = 0.9996$$

$$DL = 0.06296$$

Weight: <None>

Min Conc: 0



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	3661.65	0.0249	P	2.8
2	☐	5.000	4.754	8113.53	0.0534	P	3.5
3	☐	50.000	49.606	48027.20	0.3221	P	3.1
4	☐	2500.000	2638.465	2345439.32	15.8324	A	2.1
5	☐	6250.000	6388.841	5781780.57	38.3016	A	1.9
6	☐	12500.000	13253.061	11766806.97	79.4264	A	2.0
7	☐	25000.000	26888.446	24065954.47	161.1185	A	1.7
8	☐	50000.000	51225.270	46741063.08	306.9248	A	1.5
9	☐	250000.00	249523.59	229056416.2	1,494.966	A	1.1


$$y = 0.0060 * x + 0.0249$$

$$R = 1.0000$$

$$DL = 0.3518$$

Weight: <None>

Min Conc: 0



	R _{ct}	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	168.52	0.0011	P	12.6
2	☒	5.000					
3	☐	50.000	48.024	1257.48	0.0084	P	2.5
4	☐	2500.000	2453.749	55327.56	0.3735	P	2.1
5	☐	6250.000	6050.388	138761.36	0.9192	P	1.0
6	☐	12500.000	12474.223	280559.28	1.8939	P	2.2
7	☐	25000.000	25215.837	571682.35	3.8272	P	1.0
8	☐	50000.000	48370.358	1117701.55	7.3404	P	1.8
9	☐	250000.00	250311.08	5818991.28	37.9811	A	2.5


$$y = 1.5173\text{E-}004 * x + 0.0011$$

$$R = 1.0000$$

$$DL = 2.844$$

Weight: <None>

Min Conc: 0



	R _{ct}	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	74.44	0.0005	P	37.3
2	☐	0.100	0.078	230.01	0.0015	P	7.8
3	☐	1.000	0.934	1876.81	0.0126	P	2.0
4	☐	50.000	48.849	93644.67	0.6320	P	1.0
5	☐	125.000	119.659	233613.90	1.5475	P	0.7
6	☐	250.000	248.049	475076.63	3.2073	P	2.9
7	☐	500.000	496.580	959019.16	6.4204	P	1.4
8	☐	1000.000	1002.923	1974367.59	12.9665	A	2.4
9	☐			3075.92	0.0201	P	3.3


$$y = 0.0129 * x + 5.0700\text{E-}004$$

$$R = 1.0000$$

$$DL = 0.04384$$

Weight: <None>

Min Conc: 0

60 Ni [He] ISTD:45 Sc [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	62.22	0.0004	P	8.2
2	☐	0.100	0.080	105.56	0.0007	P	19.8
3	☐	1.000	1.079	606.69	0.0041	P	3.1
4	☐	50.000	51.381	25773.36	0.1740	P	2.4
5	☐	125.000	123.488	63034.35	0.4175	P	0.9
6	☐	250.000	257.387	128812.97	0.8698	P	4.2
7	☐	500.000	520.191	262531.29	1.7575	P	1.1
8	☐	1000.000	988.178	508321.91	3.3383	P	1.6
9	☐			1775.69	0.0116	P	10.2


$$y = 0.0034 * x + 4.2281E-004$$

$$R = 0.9997$$

$$DL = 0.03074$$

Weight: <None>

Min Conc: 0

63 Cu [He] ISTD:45 Sc [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	211.12	0.0014	P	7.9
2	☐	0.200	0.215	528.91	0.0035	P	13.0
3	☐	2.000	1.841	2824.76	0.0189	P	3.2
4	☐	500.000	481.248	678286.96	4.5784	P	1.6
5	☐	1250.000	1268.304	1821142.80	12.0638	A	1.8
6	☐	2500.000	2578.676	3633504.29	24.5263	A	2.0
7	☐	5000.000	5151.401	7317994.13	48.9945	A	2.0
8	☐	10000.000	9903.280	14343789.09	94.1878	A	0.7
9	☐			10581.81	0.0691	P	1.6


$$y = 0.0095 * x + 0.0014$$

$$R = 0.9998$$

$$DL = 0.03559$$

Weight: <None>

Min Conc: 0

66 Zn [He] ISTD:45 Sc [He]

	R _{ct}	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	193.34	0.0013	P	11.3
2	☒	0.200					
3	☐	2.000	2.009	577.79	0.0039	P	12.5
4	☐	500.000	491.194	93070.91	0.6282	P	1.2
5	☐	1250.000	1199.786	231347.17	1.5325	P	1.6
6	☐	2500.000	2471.637	467434.00	3.1558	P	2.9
7	☐	5000.000	4998.479	953080.26	6.3806	P	1.4
8	☐	10000.000	10014.568	1946606.08	12.7825	A	0.8
9	☐			5292.15	0.0345	P	2.3


$$y = 0.0013 * x + 0.0013$$

$$R = 1.0000$$

$$DL = 0.3491$$

Weight: <None>

Min Conc: 0

75 As [He] ISTD:89 Y [He]

	R _{ct}	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	8.67	0.0000	P	52.7
2	☒	0.100					
3	☐	1.000	0.973	136.68	0.0001	P	29.1
4	☐	50.000	49.296	6457.47	0.0070	P	1.7
5	☐	125.000	123.088	16227.28	0.0174	P	0.1
6	☐	250.000	252.182	32984.62	0.0357	P	3.3
7	☐	500.000	506.494	67458.02	0.0716	P	1.5
8	☐	1000.000	996.482	132616.17	0.1409	P	0.7
9	☐			73.68	0.0001	P	18.4

$$y = 1.4140E-004 * x + 9.3735E-006$$


$$R = 1.0000$$

$$DL = 0.1048$$

Weight: <None>

Min Conc: 0

77 Se [He] ISTD:89 Y [He]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	1.11	0.0000	P	173.2
2	☐	0.500	0.005	1.11	0.0000	P	173.2
3	☐	5.000	7.252	15.56	0.0000	P	66.8
4	☐	50.000	40.810	82.22	0.0001	P	10.4
5	☐	125.000	125.413	252.23	0.0003	P	9.8
6	☐	250.000	251.352	501.13	0.0005	P	7.2
7	☐	500.000	528.310	1071.16	0.0011	P	7.7
8	☐	1000.000	985.904	1994.61	0.0021	P	1.3
9	☐			7.78	0.0000	P	65.7

$$y = 2.1484\text{E-}006 * x + 1.1985\text{E-}006$$


$$R = 0.9994$$

$$DL = 2.899$$

Weight: <None>

Min Conc: 0

78 Se [He] ISTD:89 Y [He]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	64.68	0.0001	P	11.3
2	☐	0.500	0.504	68.34	0.0001	P	18.1
3	☐	5.000	3.678	90.01	0.0001	P	22.9
4	☐	50.000	50.661	404.71	0.0004	P	5.7
5	☐	125.000	123.343	898.79	0.0010	P	4.8
6	☐	250.000	256.860	1786.63	0.0019	P	5.5
7	☐	500.000	508.353	3538.14	0.0038	P	1.1
8	☐	1000.000	994.289	6851.03	0.0073	P	1.8
9	☐			67.34	0.0001	P	13.7


$$y = 7.2513\text{E-}006 * x + 7.0051\text{E-}005$$

$$R = 0.9999$$


$$DL = 3.276$$

Weight: <None>

Min Conc: 0

81 Br [No Gas] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			2933.34		P	2.1
2	☐			2906.65		P	5.7
3	☐			2946.68		P	8.2
4	☐			2913.32		P	6.9
5	☐			2833.20		P	9.6
6	☐			2946.68		P	9.5
7	☐			3066.84		P	1.5
8	☐			2913.30		P	3.6
9	☐			3163.63		P	3.3

82 Se [No Gas] ISTD: 89 Y [No Gas]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	-20.06	0.0000	P	-300.
2	☒	0.500					
3	☐	5.000	5.205	213.35	0.0000	P	19.3
4	☐	50.000	48.904	2122.07	0.0003	P	1.6
5	☐	125.000	123.616	5581.98	0.0008	P	1.6
6	☐	250.000	245.773	11000.07	0.0017	P	2.3
7	☐	500.000	518.851	22574.67	0.0036	P	7.8
8	☐	1000.000	991.858	44857.02	0.0068	P	0.8
9	☐			78.97	0.0000	P	128.4


$$y = 6.8982E-006 * x - 3.2018E-006$$

$$R = 0.9997$$


$$DL = 4.184$$

Weight: <None>

Min Conc: 0

83 Kr [No Gas] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			2090.18		P	2.2
2	☐			1990.16		P	2.5
3	☐			2097.96		P	2.0
4	☐			2094.62		P	4.0
5	☐			2105.73		P	0.8
6	☐			2084.62		P	1.4
7	☐			2046.84		P	2.8
8	☐			2059.06		P	7.3
9	☐			1970.16		P	3.6

86 Sr [No Gas] ISTD : 89 Y [No Gas]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	3372.72	0.0005	P	3.1
2	☐	0.100	0.010	3431.08	0.0005	P	5.1
3	☐	1.000	0.756	4200.75	0.0006	P	1.2
4	☐	500.000	475.565	428380.47	0.0675	P	1.7
5	☐	1250.000	1185.334	1099241.30	0.1673	P	3.4
6	☐	2500.000	2488.137	2279390.46	0.3506	A	2.1
7	☐	5000.000	5179.152	4605473.28	0.7293	A	6.6
8	☐	10000.000	9922.695	9161736.57	1.3967	A	1.5
9	☐			7438.31	0.0011	P	1.0


$$y = 1.4071E-004 * x + 5.3711E-004$$

$$R = 0.9998$$

$$DL = 0.3578$$

Weight: <None>

Min Conc: 0

88 Sr [No Gas] ISTD: 89 Y [No Gas]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	230.57	0.0000	P	9.3
2	☐	0.100	0.097	969.51	0.0002	P	3.2
3	☐	1.000	0.955	7677.30	0.0012	P	3.1
4	☐	500.000	497.722	3771018.49	0.5938	A	2.2
5	☐	1250.000	1222.616	9582822.18	1.4585	A	2.1
6	☐	2500.000	2468.798	19144613.27	2.9451	A	2.6
7	☐	5000.000	5183.147	39045512.33	6.1831	A	6.7
8	☐	10000.000	9919.764	77617347.57	11.8335	A	0.9
9	☐			34640.80	0.0052	P	1.2


$$y = 0.0012 * x + 3.6742E-005$$

$$R = 0.9998$$

$$DL = 0.008566$$

Weight: <None>

Min Conc: 0

90 Zr [No Gas] ISTD: 89 Y [No Gas]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	413.91	0.0001	P	5.1
2	☐	0.100	0.089	850.05	0.0001	P	6.2
3	☐	1.000	0.984	5320.60	0.0008	P	0.8
4	☐	50.000	48.222	233568.05	0.0368	P	1.5
5	☐	125.000	118.680	594052.34	0.0904	P	2.4
6	☐	250.000	240.257	1189378.67	0.1830	P	3.3
7	☐	500.000	514.078	2471693.81	0.3914	A	7.0
8	☐	1000.000	996.275	4975199.85	0.7585	A	0.8
9	☐			1961.31	0.0003	P	10.6

$$y = 7.6131E-004 * x + 6.5930E-005$$


$$R = 0.9998$$

$$DL = 0.01319$$

Weight: <None>

Min Conc: 0

91 Zr [No Gas] ISTD: 89 Y [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	91.67	0.0000	P	8.7
2	☐	0.100	0.102	200.01	0.0000	P	16.1
3	☐	1.000	0.930	1097.30	0.0002	P	13.0
4	☐	50.000	49.422	51875.08	0.0082	P	2.5
5	☐	125.000	122.279	132637.79	0.0202	P	2.1
6	☐	250.000	246.263	264148.81	0.0406	P	2.7
7	☐	500.000	515.980	537605.95	0.0851	P	6.9
8	☐	1000.000	993.313	1074903.95	0.1639	P	1.6
9	☐			477.80	0.0001	P	25.1

$$y = 1.6498E-004 * x + 1.4597E-005$$


$$R = 0.9998$$

$$DL = 0.02319$$

Weight: <None>

Min Conc: 0

94 Mo [No Gas] ISTD: 89 Y [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	144.45	0.0000	P	28.3
2	☐	0.500	0.463	711.15	0.0001	P	0.7
3	☐	5.000	4.456	5715.24	0.0009	P	8.2
4	☐	250.000	237.928	289092.04	0.0455	P	1.6
5	☐	625.000	583.775	733584.54	0.1117	P	2.3
6	☐	1250.000	1239.843	1540433.61	0.2371	A	5.5
7	☐	2500.000	2573.111	3106958.64	0.4921	A	7.2
8	☐	5000.000	4971.741	6235821.45	0.9507	A	2.5
9	☐			2950.40	0.0004	P	4.9

$$y = 1.9122E-004 * x + 2.3000E-005$$


$$R = 0.9998$$

$$DL = 0.1019$$

Weight: <None>

Min Conc: 0

95 Mo [No Gas] ISTD:89 Y [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	19.44	0.0000	P	65.2
2	☐	0.500	0.402	638.92	0.0001	P	2.4
3	☐	5.000	4.613	7290.97	0.0011	P	1.2
4	☐	250.000	235.330	360861.34	0.0568	P	2.2
5	☐	625.000	579.673	919625.46	0.1400	P	1.6
6	☐	1250.000	1216.748	1909444.90	0.2938	A	2.6
7	☐	2500.000	2561.894	3905280.30	0.6186	A	7.9
8	☐	5000.000	4983.766	7892434.64	1.2033	A	1.7
9	☐			4120.17	0.0006	P	10.2

$$y = 2.4144\text{E-}004 * x + 3.0878\text{E-}006$$


$$R = 0.9998$$

$$DL = 0.02502$$

Weight: <None>

Min Conc: 0

96 Mo [No Gas] ISTD:89 Y [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	194.45	0.0000	P	28.9
2	☐	0.500	0.410	880.61	0.0001	P	9.4
3	☐	5.000	4.518	7924.67	0.0012	P	1.7
4	☐	250.000	239.197	397897.93	0.0627	P	1.9
5	☐	625.000	584.033	1004885.93	0.1529	P	1.0
6	☐	1250.000	1245.384	2119262.53	0.3261	A	3.3
7	☐	2500.000	2592.358	4285268.24	0.6787	A	7.4
8	☐	5000.000	4960.637	8518490.64	1.2987	A	0.1
9	☐			4884.34	0.0007	P	5.0

$$y = 2.6180\text{E-}004 * x + 3.1022\text{E-}005$$


$$R = 0.9997$$

$$DL = 0.1028$$

Weight: <None>

Min Conc: 0

97 Mo [No Gas] ISTD:89 Y [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	5.56	0.0000	P	173.2
2	☐	0.500	0.486	455.57	0.0001	P	9.4
3	☐	5.000	4.559	4328.58	0.0007	P	1.4
4	☐	250.000	239.592	220974.53	0.0348	P	1.2
5	☐	625.000	592.333	565185.21	0.0860	P	2.0
6	☐	1250.000	1195.204	1128146.42	0.1736	P	3.4
7	☐	2500.000	2600.457	2384968.17	0.3776	A	6.4
8	☐	5000.000	4968.074	4731960.05	0.7215	A	1.4
9	☐			2289.13	0.0003	P	4.6

$$y = 1.4522\text{E-}004 * x + 8.7554\text{E-}007$$


$$R = 0.9997$$

$$DL = 0.03133$$

Weight: <None>

Min Conc: 0

98 Mo [No Gas] ISTD:89 Y [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	19.44	0.0000	P	100.1
2	☐	0.500	0.417	1033.40	0.0002	P	6.6
3	☐	5.000	4.378	10910.07	0.0017	P	4.0
4	☐	250.000	236.641	572565.42	0.0902	P	2.3
5	☐	625.000	605.106	1514575.74	0.2305	A	2.6
6	☐	1250.000	1220.175	3021559.60	0.4649	A	3.2
7	☐	2500.000	2547.234	6129234.60	0.9704	A	6.0
8	☐	5000.000	4986.994	12460935.87	1.8999	A	1.7
9	☐			6118.19	0.0009	P	8.2


$$y = 3.8097\text{E-}004 * x + 3.1214\text{E-}006$$

$$R = 0.9999$$

$$DL = 0.0246$$

Weight: <None>

Min Conc: 0



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	1508.46	0.0003	P	11.7
2	☐	0.100	-3.305	1316.76	0.0003	P	4.9
3	☐	1.000	-3.282	1344.55	0.0003	P	7.9
4	☐	50.000	48.076	4550.88	0.0010	P	5.5
5	☐	125.000	124.671	9586.91	0.0021	P	3.5
6	☐	250.000	246.742	17581.14	0.0039	P	6.7
7	☐	500.000	512.845	34148.65	0.0078	P	6.2
8	☐	1000.000	994.534	66997.07	0.0147	P	2.2
9	☐			1402.90	0.0003	P	6.6


$$y = 1.4448\text{E-}005 * x + 3.4578\text{E-}004$$

$$R = 0.9999$$

$$DL = 8.392$$

Weight: <None>

Min Conc: 0



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	33.33	0.0000	P	49.6
2	☐	0.100	0.075	291.68	0.0001	P	6.9
3	☐	1.000	0.857	3030.97	0.0007	P	5.9
4	☐	50.000	47.739	162065.93	0.0370	P	1.9
5	☐	125.000	120.242	416788.72	0.0933	P	1.4
6	☐	250.000	236.574	825591.31	0.1836	P	4.5
7	☐	500.000	518.474	1771512.52	0.4023	A	5.6
8	☐	1000.000	994.827	3514435.54	0.7719	A	2.5
9	☐			1288.99	0.0003	P	9.9


$$y = 7.7591\text{E-}004 * x + 7.6210\text{E-}006$$

$$R = 0.9997$$

$$DL = 0.01462$$

Weight: <None>

Min Conc: 0



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	5.56	0.0000	P	42.6
2	☐	0.100	0.152	12.50	0.0000	P	32.5
3	☐	1.000	0.846	44.45	0.0000	P	47.4
4	☐	50.000	48.793	2176.59	0.0005	P	3.9
5	☐	125.000	124.556	5660.94	0.0013	P	3.9
6	☐	250.000	248.622	11371.45	0.0025	P	5.0
7	☐	500.000	514.620	23047.20	0.0052	P	5.1
8	☐	1000.000	993.151	45969.41	0.0101	P	3.7
9	☐			43.06	0.0000	P	23.3


$$y = 1.0166\text{E-}005 * x + 1.2712\text{E-}006$$

$$R = 0.9998$$

$$DL = 0.1599$$

Weight: <None>

Min Conc: 0



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	19.44	0.0000	P	49.8
2	☐	0.100	0.093	325.02	0.0001	P	6.4
3	☐	1.000	0.876	2942.06	0.0007	P	5.3
4	☐	50.000	47.556	154066.66	0.0352	P	1.4
5	☐	125.000	119.644	395677.30	0.0886	P	1.9
6	☐	250.000	236.875	788948.41	0.1754	P	3.6
7	☐	500.000	517.331	1686738.91	0.3830	A	5.6
8	☐	1000.000	995.408	3355392.17	0.7370	A	2.9
9	☐			1255.65	0.0003	P	5.2


$$y = 7.4040\text{E-}004 * x + 4.4628\text{E-}006$$

$$R = 0.9997$$

$$DL = 0.009005$$

Weight: <None>

Min Conc: 0



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	324.19	0.0001	P	11.6
2	☐	0.100	0.026	343.49	0.0001	P	10.2
3	☐	1.000	0.765	798.93	0.0002	P	3.8
4	☐	50.000	50.017	29772.91	0.0068	P	2.0
5	☐	125.000	125.893	76027.17	0.0170	P	2.0
6	☐	250.000	246.682	149736.71	0.0333	P	2.7
7	☐	500.000	516.561	306625.37	0.0696	P	5.0
8	☐	1000.000	992.437	608686.87	0.1337	P	2.0
9	☐			596.28	0.0001	P	6.5


$$y = 1.3463\text{E-}004 * x + 7.4308\text{E-}005$$

$$R = 0.9998$$

$$DL = 0.1924$$

Weight: <None>

Min Conc: 0



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	269.45	0.0001	P	5.6
2	☐	0.500	0.511	1294.54	0.0003	P	6.5
3	☐	5.000	4.556	9561.91	0.0021	P	1.0
4	☐	50.000	48.737	96641.50	0.0221	P	1.4
5	☐	125.000	120.189	242960.01	0.0544	P	2.6
6	☐	250.000	241.090	490601.03	0.1091	P	3.4
7	☐	500.000	500.982	997645.18	0.2266	P	6.3
8	☐	1000.000	1002.403	2064176.13	0.4533	A	0.8
9	☐			1841.85	0.0004	P	5.1

$$y = 4.5213\text{E-}004 * x + 6.1755\text{E-}005$$


$$R = 1.0000$$

$$DL = 0.02281$$

Weight: <None>

Min Conc: 0

121 Sb [No Gas] ISTD : 159 Tb [No Gas]



	R _{ct}	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	22.22	0.0000	P	43.0
2	☐	0.200	0.190	547.25	0.0001	P	10.9
3	☐	2.000	1.883	5337.30	0.0012	P	4.6
4	☐	50.000	47.957	131386.98	0.0300	P	1.1
5	☐	125.000	119.442	334105.35	0.0748	P	1.6
6	☐	250.000	239.432	674447.05	0.1499	P	3.2
7	☐	500.000	502.280	1385145.06	0.3145	P	5.3
8	☐	1000.000	1002.299	2857913.48	0.6277	A	1.2
9	☐			2464.18	0.0005	P	1.4

$$y = 6.2621\text{E-}004 * x + 5.0876\text{E-}006$$


$$R = 0.9999$$

$$DL = 0.01047$$

Weight: <None>

Min Conc: 0

135 Ba [No Gas] ISTD : 159 Tb [No Gas]



	R _{ct}	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	30.56	0.0000	P	56.2
2	☐	1.000	0.809	486.13	0.0001	P	11.7
3	☐	10.000	9.443	5440.14	0.0012	P	0.8
4	☐	250.000	240.060	133458.39	0.0305	P	1.7
5	☐	625.000	602.089	341848.44	0.0765	P	0.6
6	☐	1250.000	1186.491	678395.82	0.1508	P	2.5
7	☐	2500.000	2525.448	1412681.41	0.3210	M	8.0
8	☐	5000.000	5006.515	2897164.47	0.6363	A	2.0
9	☐			1491.79	0.0003	P	4.2


$$y = 1.2709\text{E-}004 * x + 6.9919\text{E-}006$$

$$R = 0.9999$$

$$DL = 0.09281$$

Weight: <None>

Min Conc: 0

137 Ba [No Gas] ISTD :159 Tb [No Gas]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	41.67	0.0000	P	59.8
2	☐	1.000	0.870	902.84	0.0002	P	7.0
3	☐	10.000	9.574	9689.79	0.0022	P	2.1
4	☐	250.000	238.011	232797.94	0.0532	P	2.0
5	☐	625.000	600.241	599429.89	0.1342	P	1.9
6	☐	1250.000	1183.362	1190321.78	0.2646	P	2.4
7	☐	2500.000	2572.322	2532818.50	0.5751	A	5.2
8	☐	5000.000	4984.194	5073701.50	1.1144	A	2.6
9	☐			2683.68	0.0006	P	6.3


$$y = 2.2358E-004 * x + 9.5528E-006$$

$$R = 0.9998$$


$$DL = 0.07667$$

Weight: <None>


Min Conc: 0

150 Nd [No Gas] No available calibration points


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			6.67		P	173.2
2	☐			6.67		P	100.0
3	☐			6.67		P	0.0
4	☐			17.78		P	43.3
5	☐			17.78		P	78.1
6	☐			42.22		P	18.2
7	☐			51.11		P	7.5
8	☐			84.45		P	18.2
9	☐			11.11		P	124.9

150 Nd [He] No available calibration points


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			2.22		P	173.2
2	☐			2.22		P	86.6
3	☐			0.00		P	
4	☐			1.11		P	173.2
5	☐			3.33		P	100.1
6	☐			4.44		P	43.4
7	☐			3.33		P	0.0
8	☐			1.11		P	173.2
9	☐			6.66		P	86.6

156 Dy [No Gas] No available calibration points


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			11.11		P	114.6
2	☐			0.00		P	
3	☐			8.33		P	0.0
4	☐			11.11		P	43.3
5	☐			22.22		P	57.3
6	☐			25.00		P	33.3
7	☐			80.56		P	6.0
8	☐			144.45		P	23.3
9	☐			605.58		P	3.5

156 Dy [He] No available calibration points


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			2.22		P	86.6
2	☐			2.22		P	173.2
3	☐			1.11		P	173.2
4	☐			6.67		P	50.0
5	☐			11.11		P	75.5
6	☐			23.33		P	42.9
7	☐			41.11		P	4.7
8	☐			74.44		P	33.6
9	☐			321.12		P	3.2

160 Gd [No Gas] Noavailable calibration poin_


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			47.22		P	44.4
2	☐			27.78		P	17.3
3	☐			55.56		P	8.7
4	☐			36.11		P	35.3
5	☐			58.33		P	24.7
6	☐			75.00		P	58.8
7	☐			105.56		P	19.9
8	☐			197.23		P	34.2
9	☐			730.59		P	5.3

160 Gd [He] No available calibration points


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			12.22		P	41.7
2	☐			12.22		P	95.8
3	☐			7.78		P	24.7
4	☐			15.56		P	61.9
5	☐			24.45		P	28.4
6	☐			30.00		P	11.1
7	☐			64.44		P	13.0
8	☐			88.89		P	20.7
9	☐			430.01		P	2.3

164 Er [No Gas] No available calibration points


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			27.78		P	75.5
2	☐			25.00		P	88.2
3	☐			44.45		P	39.0
4	☐			25.00		P	120.2
5	☐			38.89		P	61.9
6	☐			41.67		P	20.0
7	☐			33.33		P	50.0
8	☐			50.00		P	33.3
9	☐			105.56		P	27.7

164 Er [He] No available calibration points


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			16.67		P	52.9
2	☐			22.22		P	60.6
3	☐			11.11		P	75.5
4	☐			5.55		P	69.3
5	☐			23.33		P	37.8
6	☐			23.34		P	24.7
7	☐			20.00		P	28.9
8	☐			25.56		P	60.2
9	☐			51.11		P	10.0

172 Yb [No Gas] No available calibration points


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			8.33		P	100.0
2	☐			22.22		P	43.3
3	☐			13.89		P	124.9
4	☐			19.45		P	24.7
5	☐			13.89		P	69.3
6	☐			25.00		P	66.7
7	☐			11.11		P	43.3
8	☐			5.55		P	86.6
9	☐			25.00		P	33.3

172 Yb [He] No available calibration points


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			3.71		P	86.6
2	☐			3.71		P	86.6
3	☐			7.41		P	86.6
4	☐			12.96		P	89.2
5	☐			12.96		P	89.2
6	☐			7.41		P	114.5
7	☐			7.41		P	114.5
8	☐			7.41		P	43.2
9	☐			25.93		P	65.5

176 Yb [No Gas] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			402.79		P	11.9
2	☐			416.68		P	13.1
3	☐			438.91		P	20.9
4	☐			388.91		P	6.9
5	☐			375.01		P	22.6
6	☐			427.80		P	9.6
7	☐			469.47		P	4.5
8	☐			433.35		P	6.9
9	☐			438.91		P	40.0

176 Yb [He] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			292.60		P	10.8
2	☐			203.71		P	29.2
3	☐			201.86		P	5.7
4	☐			229.63		P	6.1
5	☐			229.64		P	19.4
6	☐			201.86		P	17.5
7	☐			214.82		P	7.9
8	☐			216.67		P	37.2
9	☐			262.97		P	4.4

203 Tl [No Gas] ISTD :209 Bi [No Gas]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	97.22	0.0000	P	23.1
2	☐	0.100	0.089	255.57	0.0001	P	15.4
3	☐	1.000	0.853	1658.49	0.0007	P	8.7
4	☐	50.000	46.477	83214.62	0.0351	P	0.5
5	☐	125.000	117.578	211048.53	0.0887	P	1.8
6	☐	250.000	230.182	419850.55	0.1736	P	2.2
7	☐	500.000	489.314	875072.40	0.3689	P	5.6
8	☐	1000.000	1011.402	1842142.27	0.7624	A	2.3
9	☐			769.49	0.0003	P	28.4

$$y = 7.5379E-004 * x + 4.1965E-005$$


$$R = 0.9997$$

$$DL = 0.03857$$

Weight: <None>

Min Conc: 0

205 Tl [No Gas] ISTD :209 Bi [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	202.78	0.0001	P	13.1
2	☐	0.100	0.102	627.81	0.0003	P	22.1
3	☐	1.000	0.871	3975.73	0.0016	P	4.8
4	☐	50.000	46.099	195389.11	0.0824	P	2.3
5	☐	125.000	118.605	504061.16	0.2118	P	1.1
6	☐	250.000	232.712	1004890.10	0.4154	P	1.9
7	☐	500.000	519.063	2197649.05	0.9264	A	5.6
8	☐	1000.000	995.785	4294141.37	1.7772	A	2.1
9	☐			2027.99	0.0009	P	14.5

$$y = 0.0018 * x + 8.7145E-005$$


$$R = 0.9996$$

$$DL = 0.01918$$

Weight: <None>

Min Conc: 0

206 [Pb] [No Gas] ISTD :209 Bi [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	177.78	0.0001	P	20.3
2	☐	0.100	0.104	329.64	0.0001	P	9.2
3	☐	1.000	0.811	1392.70	0.0006	P	5.9
4	☐	250.000	222.112	324091.90	0.1366	P	2.3
5	☐	625.000	576.567	843646.79	0.3545	P	3.1
6	☐	1250.000	1245.791	1852672.58	0.7658	A	1.6
7	☐	2500.000	2593.933	3783043.17	1.5945	A	4.8
8	☐	5000.000	4961.534	7368987.95	3.0498	A	1.8
9	☐			15314.80	0.0064	P	0.6

$$y = 6.1467E-004 * x + 7.6899E-005$$


$$R = 0.9997$$

$$DL = 0.07626$$

Weight: <None>

Min Conc: 0

207 [Pb] [No Gas] ISTD :209 Bi [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	164.82	0.0001	P	16.4
2	☐	0.100	0.088	275.93	0.0001	P	24.5
3	☐	1.000	0.904	1363.06	0.0006	P	5.0
4	☐	250.000	227.962	294452.78	0.1241	P	0.2
5	☐	625.000	581.206	752845.07	0.3163	P	2.9
6	☐	1250.000	1155.857	1521710.83	0.6290	P	1.5
7	☐	2500.000	2609.806	3369720.30	1.4202	A	4.1
8	☐	5000.000	4975.209	6541321.91	2.7074	A	2.4
9	☐			13531.32	0.0057	P	0.8

$$y = 5.4416\text{E-}004 * x + 7.0994\text{E-}005$$


$$R = 0.9995$$

$$DL = 0.06424$$

Weight: <None>

Min Conc: 0

208 Pb [No Gas] ISTD :209 Bi [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	724.10	0.0003	P	9.3
2	☐	0.100	0.101	1309.31	0.0006	P	5.4
3	☐	1.000	0.865	5932.12	0.0025	P	4.3
4	☐	250.000	224.633	1317929.39	0.5555	P	1.3
5	☐	625.000	603.765	3552383.68	1.4926	A	2.8
6	☐	1250.000	1218.432	7285763.79	3.0119	A	1.5
7	☐	2500.000	2585.046	15160964.75	6.3897	A	4.4
8	☐	5000.000	4969.292	29679088.92	12.2827	A	1.4
9	☐			62339.66	0.0262	P	0.5


$$y = 0.0025 * x + 3.1181\text{E-}004$$

$$R = 0.9998$$

$$DL = 0.03506$$

Weight: <None>

Min Conc: 0

238 U [No Gas] ISTD :209 Bi [No Gas]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	5.55	0.0000	P	86.6
2	☐	0.100	0.096	494.47	0.0002	P	5.0
3	☐	1.000	0.886	4689.89	0.0019	P	3.1
4	☐	50.000	45.046	233521.14	0.0984	P	2.0
5	☐	125.000	116.671	606724.91	0.2549	P	2.6
6	☐	250.000	231.175	1222003.52	0.5051	P	2.0
7	☐	500.000	510.356	2645580.57	1.1151	A	5.6
8	☐	1000.000	1000.817	5283678.29	2.1868	A	2.2
9	☐			1394.56	0.0006	P	1.2


$$y = 0.0022 * x + 2.4321E-006$$

$$R = 0.9997$$


$$DL = 0.002893$$

Weight: <None>


Min Conc: 0

6 Li (ISTD) [No Gas]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		1119096.34		A	2.2
2	☐	1.000		1103968.98		A	1.4
3	☐	1.000		1144329.59		A	2.1
4	☐	1.000		1134629.71		A	0.3
5	☐	1.000		1146482.95		A	2.1
6	☐	1.000		1155467.79		A	2.9
7	☐	1.000		1158485.58		A	4.2
8	☐	1.000		1184798.34		A	2.2
9	☐	1.000		1176150.67		A	1.8

45 Sc (ISTD) [No Gas]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		3090419.92		A	0.7
2	☐	1.000		3113464.95		A	0.9
3	☐	1.000		3123677.52		A	1.3
4	☐	1.000		3102503.81		A	1.2
5	☐	1.000		3169435.37		A	2.4
6	☐	1.000		3170169.85		A	1.5
7	☐	1.000		3125441.20		A	3.9
8	☐	1.000		3192204.36		A	1.3
9	☐	1.000		3247239.15		A	1.9

45 Sc (ISTD) [He]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		147177.34		P	1.1
2	☐	1.000		152038.00		P	1.2
3	☐	1.000		149137.13		P	0.9
4	☐	1.000		148170.03		P	1.4
5	☐	1.000		150968.10		P	0.7
6	☐	1.000		148202.25		P	2.8
7	☐	1.000		149386.97		P	1.2
8	☐	1.000		152299.21		P	2.0
9	☐	1.000		153225.80		P	0.8

89 Y (ISTD) [No Gas]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		6279213.10		A	1.3
2	☐	1.000		6374699.07		A	1.4
3	☐	1.000		6528330.53		A	0.7
4	☐	1.000		6350773.94		A	0.2
5	☐	1.000		6571350.39		A	1.2
6	☐	1.000		6502207.13		A	2.6
7	☐	1.000		6326180.25		A	4.0
8	☐	1.000		6559086.50		A	0.5
9	☐	1.000		6618805.59		A	1.0

89 Y (ISTD) [He]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		922931.84		P	0.8
2	☐	1.000		926141.60		P	1.0
3	☐	1.000		932192.12		P	1.4
4	☐	1.000		925258.92		P	1.2
5	☐	1.000		931826.64		P	0.3
6	☐	1.000		925370.84		P	3.1
7	☐	1.000		941917.62		P	1.7
8	☐	1.000		941105.01		P	0.6
9	☐	1.000		945707.45		P	0.9

103 Rh (ISTD) [No Gas]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		4247738.55		A	2.0
2	☐	1.000		4246671.62		A	2.7
3	☐	1.000		4283653.05		A	0.7
4	☐	1.000		4178357.00		A	1.4
5	☐	1.000		4261248.58		A	1.2
6	☐	1.000		4201149.53		A	1.2
7	☐	1.000		4166147.75		A	3.2
8	☐	1.000		4285113.60		A	2.1
9	☐	1.000		4137769.84		A	0.4

103 Rh (ISTD) [He]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		2235093.00		A	2.7
2	☐	1.000		2263783.63		A	1.0
3	☐	1.000		2275188.04		A	2.1
4	☐	1.000		2246132.14		A	0.1
5	☐	1.000		2270638.37		A	0.8
6	☐	1.000		2257408.91		A	0.1
7	☐	1.000		2243130.31		A	2.3
8	☐	1.000		2264827.09		A	1.5
9	☐	1.000		2190380.75		A	1.4

115 In (ISTD) [No Gas]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		4093092.99		A	1.6
2	☐	1.000		4062343.25		A	1.2
3	☐	1.000		4115341.85		A	1.9
4	☐	1.000		4063738.21		A	0.3
5	☐	1.000		4135862.92		A	1.5
6	☐	1.000		4151269.08		A	3.1
7	☐	1.000		4059764.84		A	4.1
8	☐	1.000		4113149.00		A	1.1
9	☐	1.000		4090192.79		A	1.3

115 In (ISTD) [He]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		804360.62		P	0.8
2	☐	1.000		811103.26		P	0.5
3	☐	1.000		815452.51		P	1.1
4	☐	1.000		817804.64		P	0.4
5	☐	1.000		819256.10		P	0.8
6	☐	1.000		810015.21		P	2.2
7	☐	1.000		815901.13		P	1.1
8	☐	1.000		811108.21		P	0.2
9	☐	1.000		807459.01		P	0.4

159 Tb (ISTD) [No Gas]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		4364599.52		A	0.8
2	☐	1.000		4419631.63		A	2.3
3	☐	1.000		4506776.25		A	0.3
4	☐	1.000		4374306.50		A	2.3
5	☐	1.000		4466794.13		A	1.6
6	☐	1.000		4500115.52		A	2.2
7	☐	1.000		4408594.97		A	3.3
8	☐	1.000		4553787.67		A	1.2
9	☐	1.000		4601391.43		A	1.3

159 Tb (ISTD) [He]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		2331538.32		A	1.5
2	☐	1.000		2320384.22		A	1.9
3	☐	1.000		2340626.13		A	1.8
4	☐	1.000		2343383.12		A	1.5
5	☐	1.000		2410087.71		A	1.2
6	☐	1.000		2372421.55		A	2.9
7	☐	1.000		2398901.32		A	1.5
8	☐	1.000		2451697.57		A	0.5
9	☐	1.000		2413657.03		A	0.3

165 Ho (ISTD) [No Gas]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		4068413.11		A	1.0
2	☐	1.000		4089811.03		A	1.1
3	☐	1.000		4101676.61		A	0.1
4	☐	1.000		4131660.16		A	1.9
5	☐	1.000		4252492.76		A	1.6
6	☐	1.000		4176686.72		A	2.5
7	☐	1.000		4154432.73		A	2.3
8	☐	1.000		4282964.72		A	0.4
9	☐	1.000		4339694.15		A	1.2

165 Ho (ISTD) [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		2234799.90		A	1.4
2	☐	1.000		2247191.72		A	1.1
3	☐	1.000		2334120.41		A	2.7
4	☐	1.000		2313047.27		A	1.8
5	☐	1.000		2315966.93		A	1.3
6	☐	1.000		2336705.68		A	4.6
7	☐	1.000		2369485.31		A	1.3
8	☐	1.000		2392272.21		A	0.6
9	☐	1.000		2376434.06		A	1.9

209 Bi (ISTD) [No Gas]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		2321736.84		A	3.1
2	☐	1.000		2336292.26		A	2.7
3	☐	1.000		2421707.15		A	2.0
4	☐	1.000		2372369.25		A	0.7
5	☐	1.000		2380353.51		A	1.2
6	☐	1.000		2419357.24		A	1.8
7	☐	1.000		2374135.96		A	2.5
8	☐	1.000		2416615.10		A	1.3
9	☐	1.000		2376948.59		A	1.3

209 Bi (ISTD) [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		1381454.25		P	0.8
2	☐	1.000		1365620.90		P	1.4
3	☐	1.000		1397849.13		P	0.7
4	☐	1.000		1415491.18		P	1.2
5	☐	1.000		1426943.97		P	0.7
6	☐	1.000		1408746.87		P	2.2
7	☐	1.000		1433604.08		P	1.0
8	☐	1.000		1434805.13		P	1.1
9	☐	1.000		1362811.49		P	0.2

US EPA Tune Check Report

Operator Name Jaswal
Acq/Data Batch D:\Agilent\ICPMH\1\DATA\P8051721MS.b
Acq. Date-Time 2021-05-17 13:40:45
Report Comment ---
Instrument Name G8403A SG19224459

[No Gas]

Sensitivity

Mass	Conc. [ug/l]	Count	CPS	Resp (Required) [cps/ug/l]	Resp (Flag)	RSD%	RSD% (Required)
9		5138	51378.61			1.799	5.000
24		47661	476609.72			1.745	5.000
25		6425	64246.96			1.648	5.000
26		7544	75444.91			1.769	5.000
59		39777	397774.82			2.245	5.000
113		4955	49549.73			2.089	5.000
115		30415	304148.69			1.998	5.000
206		7357	73569.52			2.544	5.000
207		6396	63956.65			2.614	5.000
208		15503	155027.92			2.491	5.000
220		1	5.20			27.702	

Mass	RSD% (Flag)
9	
24	
25	
26	
59	
113	
115	
206	
207	
208	
220	


Mass	Rep#1 Count	Rep#2 Count	Rep#3 Count	Rep#4 Count	Rep#5 Count
9	4983	5159	5196	5135	5217
24	46457	47178	48308	47933	48429
25	6268	6406	6534	6405	6511
26	7313	7549	7602	7618	7640
59	38300	39624	40498	40078	40388
113	4788	4925	5022	4993	5046
115	29390	30403	30948	30757	30577
206	7060	7318	7562	7424	7420
207	6134	6329	6546	6493	6477
208	14882	15383	15836	15745	15668

US EPA Tune Check Report

Mass	Rep#1 Count	Rep#2 Count	Rep#3 Count	Rep#4 Count	Rep#5 Count
220	0	0	0	1	1

Integration Time [sec] 0.1

Resolution/Axis



Mass	Peak Height	Axis	Axis (Required)	Axis (Flag)
9	9536.46	9.05	8.90 - 9.10	
24	85672.69	24.05	23.90 - 24.10	
25	11453.43	25.05	24.90 - 25.10	
26	13156.46	26.05	25.90 - 26.10	
59	74407.73	59.00	58.90 - 59.10	
113	9895.97	113.05	112.90 - 113.10	
115	61155.50	115.05	114.90 - 115.10	
206	14103.73	206.00	205.90 - 206.10	
207	12220.19	206.95	206.90 - 207.10	
208	29823.69	207.95	207.90 - 208.10	
220			-	

Mass	W-50%	W-5%	W-5% (Required)	W-5% (Flag)
9	0.58	0.776	0.900	
24	0.59	0.783	0.900	
25	0.60	0.778	0.900	
26	0.60	0.784	0.900	
59	0.56	0.737	0.900	
113	0.51	0.737	0.900	
115	0.52	0.732	0.900	
206	0.54	0.817	0.900	
207	0.53	0.780	0.900	
208	0.54	0.786	0.900	
220				

Integration Time [sec] 0.1

Acquisition Time [sec] 256.770000000002

Y Axis Linear

Tune Parameters

Plasma Parameters

Plasma Mode HMI Nebulizer Gas 0.49 L/min Dilution Gas 0.44 L/min

US EPA Tune Check Report

RF Power	1600 W	Option Gas	---	Auxiliary Gas	0.90 L/min
RF Matching	1.40 V	Nebulizer Pump	0.10 rps	Plasma Gas	15.0 L/min
Sample Depth	10.0 mm	S/C Temp	2 °C		

Lens Parameters

Extract 1	-6.0 V	Omega Lens	9.4 V	Deflect	16.6 V
Extract 2	-250.0 V	Cell Entrance	-30 V	Plate Bias	-50 V
Omega Bias	-120 V	Cell Exit	-50 V		

Cell Parameters

Use Gas	No	3rd Gas Flow	---	Energy Discrimination	4.0 V
He Flow	0.0 mL/min	OctP Bias	-8.0 V		
H2 Flow	---	OctP RF	170 V		

QP Parameters

Mass Gain	122	Axis Gain	0.9989	QP Bias	-4.0 V
Mass Offset	125	Axis Offset	0.02		

Hardware Settings

Torch

Torch H	0.6 mm	Torch V	-0.8 mm
---------	--------	---------	---------

EM

Discriminator	4.1 mV	Analog HV	2192 V	Pulse HV	1460 V
---------------	--------	-----------	--------	----------	--------

[He]

Sensitivity

Mass	Conc. [ug/l]	Count	CPS	Resp (Required) [cps/ug/l]	Resp (Flag)	RSD%	RSD% (Required)
59		11176	111764.19			1.240	
89		18907	189072.05			1.255	
205		9974	99740.57			1.044	

Mass	RSD% (Flag)
59	
89	
205	

Mass	Rep#1 Count	Rep#2 Count	Rep#3 Count	Rep#4 Count	Rep#5 Count
59	11020	11161	11399	11127	11176
89	18707	19028	19262	18710	18829
205	9875	9950	10150	9933	9963

Integration Time [sec] 0.1

Tune Parameters

Plasma Parameters

Plasma Mode	HMI	Nebulizer Gas	0.49 L/min	Dilution Gas	0.44 L/min
RF Power	1600 W	Option Gas	---	Auxiliary Gas	0.90 L/min
RF Matching	1.40 V	Nebulizer Pump	0.10 rps	Plasma Gas	15.0 L/min
Sample Depth	10.0 mm	S/C Temp	2 °C		

Lens Parameters

Extract 1	-6.0 V	Omega Lens	9.4 V	Deflect	4.2 V
-----------	--------	------------	-------	---------	-------

US EPA Tune Check Report

Extract 2	-250.0 V	Cell Entrance	-50 V	Plate Bias	-60 V
Omega Bias	-120 V	Cell Exit	-70 V		
Cell Parameters					
Use Gas	Yes	3rd Gas Flow	---	Energy Discrimination	5.0 V
He Flow	4.5 mL/min	OctP Bias	-18.0 V		
H2 Flow	---	OctP RF	190 V		
QP Parameters					
Mass Gain	122	Axis Gain	0.9989	QP Bias	-13.0 V
Mass Offset	125	Axis Offset	0.02		
Hardware Settings					
Torch					
Torch H	0.6 mm	Torch V	-0.8 mm		
EM					
Discriminator	4.1 mV	Analog HV	2192 V	Pulse HV	1460 V