


Calibration for 003CALB.d

Batch Folder: D:\Agilent\ICPMH\1\DATA\P7051522MS1.b\
 Analysis File: P7051522MS1.batch.bin
 DA Date-Time: 2022-05-16 14:45:34
 Calibration Title:
 Calibration Method: External Calibration
 VIS Interpolation Fit:

Level	Standard Data File	Sample Name	Acq. Date-Time
1	003CALB.d	S00	2022-05-15 15:53:30
2	004CALS.d	S02	2022-05-15 15:56:24
3	006CALS.d	S03	2022-05-15 16:02:10
4	007CALS.d	S04	2022-05-15 16:04:54
5	008CALS.d	S05	2022-05-15 16:07:41
6	009CALS.d	S06	2022-05-15 16:10:25
7	010CALS.d	S07	2022-05-15 16:13:12
8	011CALS.d	S08	2022-05-15 16:15:57

9 Be [No Gas] ISTD:6 Li [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	81.11	0.0000	P	36.2
2	☐	1.000	1.126	2565.79	0.0009	P	4.0
3	☐	50.000	52.788	116381.23	0.0408	P	1.4
4	☐	125.000	128.988	282855.53	0.0996	P	0.5
5	☐	250.000	254.100	539519.82	0.1962	P	1.0
6	☐	500.000	508.497	1024419.32	0.3926	P	1.1
7	☐	1000.000	994.088	1979606.73	0.7674	A	1.7
8	☐			387.79	0.0002	P	28.1

$$y = 7.7194\text{E-}004 * x + 2.8627\text{E-}005$$

$$R = 0.9999$$


$$DL = 0.04024$$

$$BEC = 0.03708$$

Weight: <None>

Min Conc: 0

10 B [No Gas] ISTD:6 Li [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	383.35	0.0001	P	20.6
2	☐	25.000	22.840	7082.35	0.0025	P	6.3
3	☐	50.000	51.712	15513.72	0.0054	P	6.8
4	☐	125.000	123.123	36234.54	0.0128	P	4.6
5	☐	250.000	247.862	70245.66	0.0255	P	4.1
6	☐	500.000	505.749	135674.44	0.0520	P	2.2
7	☐	1000.000	997.863	264233.27	0.1024	P	2.6
8	☐			10517.71	0.0042	P	12.9

$$y = 1.0251\text{E-}004 * x + 1.3586\text{E-}004$$

$$R = 1.0000$$


$$DL = 0.8195$$

$$BEC = 1.325$$

Weight: <None>

Min Conc: 0

11 B [No Gas] ISTD:6 Li [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	1769.60	0.0006	P	1.0
2	☐	25.000	23.212	33316.97	0.0117	P	5.1
3	☐	50.000	53.113	73809.56	0.0259	P	4.3
4	☐	125.000	125.758	171522.07	0.0604	P	3.3
5	☐	250.000	254.386	334160.82	0.1215	P	3.1
6	☐	500.000	515.640	641174.04	0.2457	P	2.0
7	☐	1000.000	990.878	1216343.04	0.4715	A	3.3
8	☐			50193.54	0.0199	P	12.6

$$y = 4.7521\text{E-}004 * x + 6.2585\text{E-}004$$

$$R = 0.9998$$

$$DL = 0.03765$$

$$BEC = 1.317$$

Weight: <None>

Min Conc: 0


12 C [No Gas] No available calibration points



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐						
2	☐						
3	☐						
4	☐						
5	☐						
6	☐						
7	☐						
8	☐						

12 C [He] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐						
2	☐						
3	☐						
4	☐						
5	☐						
6	☐						
7	☐						
8	☐						

23 Na [He] ISTD:45 Sc [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	11819.49	0.0221	P	2.8
2	☐	500.000	510.435	417398.37	0.7708	P	0.3
3	☐	5000.000	5163.589	4153833.89	7.5959	A	1.1
4	☐	12500.000	12989.916	10088712.15	19.0753	A	1.0
5	☐	25000.000	25923.640	19520037.24	38.0461	A	1.5
6	☐	50000.000	51731.875	37835308.25	75.9009	A	0.8
7	☐	100000.00	102499.33	73862987.76	150.3651	A	0.8
8	☐	500000.00	499266.86	370920641.62	732.3322	A	0.7

$$y = 0.0015 * x + 0.0221$$


$$R = 1.0000$$

$$DL = 1.268$$

$$BEC = 15.05$$

Weight: <None>

Min Conc: 0

24 Mg [He] ISTD:45 Sc [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	487.05	0.0009	P	3.8
2	☐	500.000	525.297	250311.66	0.4622	P	0.9
3	☐	5000.000	5188.411	2492147.25	4.5573	A	1.1
4	☐	12500.000	12794.942	5943278.20	11.2373	A	1.0
5	☐	25000.000	25485.272	11483118.43	22.3819	A	1.1
6	☐	50000.000	50699.663	22195314.85	44.5250	A	0.5
7	☐	100000.00	100096.91	43182038.00	87.9054	A	0.4
8	☐	500000.00	499877.10	222344867.93	438.9898	A	0.6

$$y = 8.7819\text{E-}004 * x + 9.0938\text{E-}004$$


$$R = 1.0000$$

$$DL = 0.1175$$

$$BEC = 1.036$$

Weight: <None>

Min Conc: 0

27 Al [He] ISTD:45 Sc [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	255.56	0.0005	P	6.5
2	☐	20.000	19.876	5473.27	0.0101	P	1.5
3	☐	1000.000	960.913	254863.23	0.4660	P	0.2
4	☐	2500.000	2413.232	618644.49	1.1697	P	0.1
5	☐	5000.000	4799.584	1193255.66	2.3258	M	1.6
6	☐	10000.000	9552.752	2307430.32	4.6287	A	1.3
7	☐	20000.000	18896.006	4497388.18	9.1555	A	1.4
8	☐	100000.00	100278.10	24607625.55	48.5845	A	0.1

$$y = 4.8449\text{E-}004 * x + 4.7727\text{E-}004$$

$$R = 0.9999$$


$$DL = 0.1916$$

$$BEC = 0.9851$$

Weight: <None>

Min Conc: 0

28 Si [No Gas] ISTD : 45 Sc [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	358888.75	0.0531	P	1.1
2	☐	10.000	9.445	432885.59	0.0638	P	1.2
3	☐	50.000	56.952	797223.37	0.1174	P	1.0
4	☐	125.000	142.459	1427787.88	0.2139	A	1.9
5	☐	250.000	269.992	2285416.59	0.3579	A	1.7
6	☐	500.000	519.774	3952620.36	0.6398	A	1.1
7	☐	1000.000	982.591	7082952.33	1.1622	A	1.5
8	☐			886056.86	0.1444	P	3.3

$$y = 0.0011 * x + 0.0531$$

$$R = 0.9994$$


$$DL = 1.559$$

$$BEC = 47.05$$

Weight: <None>

Min Conc: 0

31 P [He] ISTD : 45 Sc [He]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	-6.496	738.93	0.0014	P	2.8
2	☐	0.000	6.496	919.50	0.0017	P	6.0
3	☐	1000.000	1027.132	14582.28	0.0267	P	1.4
4	☐	2500.000	2596.824	34406.08	0.0651	P	3.8
5	☐	5000.000	5043.401	64081.77	0.1249	P	0.2
6	☐	10000.000	10117.681	124131.35	0.2490	P	0.9
7	☐	20000.000	19916.850	240069.58	0.4887	P	0.4
8	☐			819.49	0.0016	P	7.5

$$y = 2.4459E-005 * x + 0.0015$$

$$R = 1.0000$$


$$DL = 8.569$$

$$BEC = 62.92$$

Weight: <None>

Min Conc: 0

34 S [No Gas] ISTD:45 Sc [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	-22.002	458353.58	0.0678	P	1.4
2	☐	0.000	22.002	463073.66	0.0682	P	1.4
3	☐	1000.000	1087.521	527334.22	0.0777	P	1.2
4	☐	2500.000	2280.608	588865.60	0.0882	P	0.3
5	☐	5000.000	4538.119	691090.72	0.1082	P	0.1
6	☐	10000.000	9250.174	926155.24	0.1499	P	1.4
7	☐	20000.000	20513.431	1521556.31	0.2497	A	0.4
8	☐			355748.61	0.0580	P	0.7

$$y = 8.8545\text{E-}006 * x + 0.0680$$

$$R = 0.9986$$

$$DL = 327.8$$

$$BEC = 7683$$

Weight: <None>

Min Conc: 0


35 Cl [No Gas] No available calibration points



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐						
2	☐						
3	☐						
4	☐						
5	☐						
6	☐						
7	☐						
8	☐						

35 Cl [He] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐						
2	☐						
3	☐						
4	☐						
5	☐						
6	☐						
7	☐						
8	☐						

39 K [He] ISTD:45 Sc [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	68894.99	0.1287	P	1.4
2	☐	500.000	535.200	327388.93	0.6046	P	0.4
3	☐	2500.000	2545.717	1308182.79	2.3922	A	1.2
4	☐	6250.000	6293.011	3027499.85	5.7242	A	0.7
5	☐	12500.000	12378.310	5713116.62	11.1351	A	1.1
6	☐	25000.000	24751.453	11035495.91	22.1369	A	0.5
7	☐	50000.000	49363.560	21625360.38	44.0213	A	0.2
8	☐	250000.00	250156.62	112724902.52	222.5607	A	0.4

$$y = 8.8917E-004 * x + 0.1287$$


$$R = 1.0000$$

$$DL = 6.228$$

$$BEC = 144.7$$

Weight: <None>

Min Conc: 0

43 Ca [No Gas] ISTD:45 Sc [No Gas]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	322.23	0.0000	P	5.1
2	☐	500.000	530.089	17377.01	0.0026	P	1.8
3	☐	5000.000	6347.029	204607.79	0.0301	P	0.8
4	☐	12500.000	15506.534	490893.68	0.0735	P	0.7
5	☐	25000.000	30728.217	930428.92	0.1457	P	1.0
6	☐	50000.000	60496.034	1771596.07	0.2868	A	0.5
7	☐	100000.00	117528.84	3395174.86	0.5571	A	1.5
8	☐	500000.00	495069.55	14400242.33	2.3465	A	0.6

$$y = 4.7397E-006 * x + 4.7703E-005$$


R = 0.9992

DL = 1.538

BEC = 10.06

Weight: <None>

Min Conc: 0

44 Ca [No Gas] ISTD:45 Sc [No Gas]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	19068.42	0.0028	P	2.0
2	☐	500.000	539.233	297965.29	0.0439	P	1.1
3	☐	5000.000	5641.139	2937092.25	0.4325	A	0.5
4	☐	12500.000	13880.639	7076189.48	1.0601	A	0.9
5	☐	25000.000	27593.256	13441249.43	2.1047	A	0.4
6	☐	50000.000	55307.150	26040335.83	4.2157	A	1.4
7	☐	100000.00	109310.80	50761906.69	8.3292	A	0.9
8	☐	500000.00	497436.49	232543169.09	37.8935	A	0.5

$$y = 7.6172E-005 * x + 0.0028$$

R = 0.9998


DL = 2.176

BEC = 37.05

Weight: <None>

Min Conc: 0

47 Ti [No Gas] ISTD:45 Sc [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	211.12	0.0000	P	6.9
2	☐	5.000	5.202	8349.75	0.0012	P	3.8
3	☐	500.000	519.784	813808.26	0.1198	P	0.6
4	☐	1250.000	1267.403	1950150.44	0.2922	A	1.5
5	☐	2500.000	2522.145	3713005.33	0.5814	A	0.6
6	☐	5000.000	5004.140	7125437.22	1.1535	A	1.0
7	☐	10000.000	9989.229	14032886.08	2.3026	A	0.7
8	☐			2461.37	0.0004	P	4.5

$$y = 2.3050E-004 * x + 3.1256E-005$$

$$R = 1.0000$$


$$DL = 0.02824$$

$$BEC = 0.1356$$

Weight: <None>

Min Conc: 0

51 V [He] ISTD:45 Sc [He]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	28.89	0.0001	P	42.8
2	☐	5.000	5.096	21217.26	0.0392	P	0.9
3	☐	50.000	51.385	215795.83	0.3946	P	0.7
4	☐	125.000	127.661	518467.79	0.9803	P	0.2
5	☐	250.000	253.262	997766.96	1.9447	P	1.3
6	☐	500.000	500.530	1915884.97	3.8433	A	0.4
7	☐	1000.000	998.517	3766184.18	7.6670	A	0.9
8	☐			912.26	0.0018	P	1.9

$$y = 0.0077 * x + 5.3811E-005$$


$$R = 1.0000$$

$$DL = 0.008998$$

$$BEC = 0.007008$$

Weight: <None>

Min Conc: 0

52 Cr [He] ISTD:45 Sc [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	2224.63	0.0042	P	2.8
2	☐	2.000	2.096	12473.00	0.0230	P	0.6
3	☐	50.000	51.864	257712.63	0.4712	P	0.3
4	☐	125.000	128.821	615818.38	1.1643	P	0.7
5	☐	250.000	254.954	1180154.25	2.3003	P	1.2
6	☐	500.000	502.083	2256156.98	4.5260	A	0.8
7	☐	1000.000	997.149	4413294.31	8.9846	A	1.4
8	☐			44646.99	0.0881	P	1.1

$$y = 0.0090 * x + 0.0042$$


$$R = 1.0000$$

$$DL = 0.03856$$

$$BEC = 0.4614$$

Weight: <None>

Min Conc: 0

54 Fe [He] ISTD:45 Sc [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	1421.54	0.0027	P	2.1
2	☐	50.000	55.497	14344.85	0.0265	P	1.6
3	☐	2500.000	2806.711	660633.05	1.2080	P	1.2
4	☐	6250.000	6704.543	1524196.99	2.8820	A	2.1
5	☐	12500.000	13415.810	2957484.26	5.7643	A	0.5
6	☐	25000.000	26345.646	5641423.83	11.3172	A	0.8
7	☐	50000.000	52818.322	11143737.83	22.6863	A	1.6
8	☐	250000.00	249241.54	54216633.06	107.0434	A	0.4

$$y = 4.2947E-004 * x + 0.0027$$


$$R = 0.9999$$

$$DL = 0.3936$$

$$BEC = 6.182$$

Weight: <None>

Min Conc: 0



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	408.90	0.0008	P	4.6
2	☐	1.000	1.064	4231.74	0.0078	P	3.6
3	☐	500.000	502.019	1818938.01	3.3262	A	0.8
4	☐	1250.000	1257.216	4404836.71	8.3286	A	1.5
5	☐	2500.000	2504.520	8512339.52	16.5908	A	0.6
6	☐	5000.000	4937.500	16303296.28	32.7069	A	1.7
7	☐	10000.000	10029.117	32634383.68	66.4339	A	0.5
8	☐			20421.73	0.0403	P	1.0

$$y = 0.0066 * x + 7.6389E-004$$


$$R = 1.0000$$

$$DL = 0.01582$$

$$BEC = 0.1153$$

Weight: <None>

Min Conc: 0



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	14390.41	0.0269	P	3.4
2	☐	50.000	54.860	250209.49	0.4620	P	0.5
3	☐	2500.000	2633.847	11439396.67	20.9191	A	1.3
4	☐	6250.000	6605.069	27723923.77	52.4196	A	1.5
5	☐	12500.000	13135.964	53472818.79	104.2240	A	0.7
6	☐	25000.000	25944.237	102600142.11	205.8218	A	0.8
7	☐	50000.000	52320.136	203875945.30	415.0407	A	0.9
8	☐	250000.00	249399.53	1002002170.5	1,978.314	A	0.9

$$y = 0.0079 * x + 0.0269$$


$$R = 1.0000$$

$$DL = 0.3417$$

$$BEC = 3.388$$

Weight: <None>

Min Conc: 0

57 Fe [He] ISTD:45 Sc [He]

	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	562.99	0.0011	P	10.9
2	☐	50.000	57.422	6733.09	0.0124	P	2.9
3	☐	2500.000	2704.918	293787.99	0.5372	P	1.4
4	☐	6250.000	6751.174	708347.03	1.3393	P	1.3
5	☐	12500.000	13453.609	1368800.59	2.6680	P	0.9
6	☐	25000.000	26092.940	2578925.92	5.1735	A	1.3
7	☐	50000.000	51876.585	5051964.52	10.2846	A	1.3
8	☐	250000.00	249453.12	25046122.55	49.4503	A	0.5

$$y = 1.9823\text{E-}004 * x + 0.0011$$


R = 1.0000

DL = 1.729

BEC = 5.299

Weight: <None>

Min Conc: 0

59 Co [He] ISTD:45 Sc [He]

	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	161.11	0.0003	P	11.2
2	☐	1.000	1.066	8364.62	0.0154	P	1.8
3	☐	50.000	52.229	406058.00	0.7425	P	0.9
4	☐	125.000	129.186	971140.60	1.8362	P	0.8
5	☐	250.000	256.769	1872272.89	3.6493	A	1.1
6	☐	500.000	502.171	3557507.34	7.1367	A	0.9
7	☐	1000.000	996.587	6956960.38	14.1630	A	1.4
8	☐			21509.94	0.0425	P	0.9

$$y = 0.0142 * x + 3.0072\text{E-}004$$


R = 1.0000

DL = 0.007105

BEC = 0.02116

Weight: <None>

Min Conc: 0

60 Ni [He] ISTD:45 Sc [He]

	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	116.67	0.0002	P	3.7
2	☐	1.000	1.085	2270.19	0.0042	P	4.6
3	☐	50.000	52.817	105887.20	0.1936	P	0.6
4	☐	125.000	130.329	252523.19	0.4775	P	0.7
5	☐	250.000	256.421	481843.72	0.9392	P	1.0
6	☐	500.000	499.973	912734.53	1.8310	P	0.9
7	☐	1000.000	997.601	1794547.54	3.6532	A	1.1
8	☐			15588.16	0.0308	P	1.9

$$y = 0.0037 * x + 2.1780E-004$$


$$R = 1.0000$$

$$DL = 0.006594$$

$$BEC = 0.05948$$

Weight: <None>

Min Conc: 0

63 Cu [He] ISTD:45 Sc [He]

	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	1280.07	0.0024	P	1.3
2	☐	2.000	2.168	13142.53	0.0243	P	0.7
3	☐	500.000	531.188	2932273.29	5.3623	A	1.4
4	☐	1250.000	1296.917	6922787.33	13.0888	A	0.2
5	☐	2500.000	2569.527	13303944.11	25.9300	A	0.6
6	☐	5000.000	5071.489	25510431.57	51.1759	A	1.0
7	☐	10000.000	9939.450	49267259.82	100.2958	A	1.0
8	☐			17766.21	0.0351	P	1.5

$$y = 0.0101 * x + 0.0024$$


$$R = 0.9999$$

$$DL = 0.009452$$

$$BEC = 0.2369$$

Weight: <None>

Min Conc: 0

66 Zn [He] ISTD:45 Sc [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	1300.07	0.0024	P	6.5
2	☐	2.000	2.515	3583.80	0.0066	P	1.1
3	☐	500.000	521.013	475935.28	0.8703	P	0.1
4	☐	1250.000	1295.985	1143002.34	2.1611	P	0.4
5	☐	2500.000	2578.344	2204757.22	4.2971	A	0.1
6	☐	5000.000	5105.202	4240034.69	8.5060	A	1.1
7	☐	10000.000	9921.014	8118596.20	16.5275	A	1.6
8	☐			14155.69	0.0279	P	1.5

$$y = 0.0017 * x + 0.0024$$


$$R = 0.9999$$

$$DL = 0.2835$$

$$BEC = 1.458$$

Weight: <None>

Min Conc: 0

75 As [He] ISTD:89 Y [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	24.07	0.0000	P	31.0
2	☐	1.000	1.107	671.01	0.0002	P	4.9
3	☐	50.000	51.966	30273.93	0.0081	P	2.5
4	☐	125.000	128.892	72611.07	0.0202	P	0.4
5	☐	250.000	254.249	139629.25	0.0398	P	0.3
6	☐	500.000	506.019	271271.77	0.0792	P	0.9
7	☐	1000.000	995.344	529938.82	0.1558	P	0.3
8	☐			245.68	0.0001	P	7.6

$$y = 1.5651E-004 * x + 6.5602E-006$$

$$R = 1.0000$$


$$DL = 0.03901$$

$$BEC = 0.04191$$

Weight: <None>

Min Conc: 0

77 Se [He] ISTD:89 Y [He]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	1.11	0.0000	P	173.
2	☐	5.000	5.873	106.67	0.0000	P	25.5
3	☐	50.000	54.499	977.82	0.0003	P	12.3
4	☐	125.000	133.601	2319.10	0.0006	P	4.1
5	☐	250.000	251.297	4251.76	0.0012	P	3.1
6	☐	500.000	500.402	8263.49	0.0024	P	1.7
7	☐	1000.000	998.170	16370.24	0.0048	P	0.6
8	☐			13.33	0.0000	P	50.4

$$y = 4.8211\text{E-}006 * x + 2.9990\text{E-}007$$

$$R = 1.0000$$


$$DL = 0.3232$$

$$BEC = 0.06221$$

Weight: <None>

Min Conc: 0

78 Se [He] ISTD:89 Y [He]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	245.68	0.0001	P	4.0
2	☐	5.000	5.865	598.17	0.0002	P	1.4
3	☐	50.000	52.274	3343.60	0.0009	P	2.5
4	☐	125.000	130.001	7684.73	0.0021	P	0.5
5	☐	250.000	258.164	14646.15	0.0042	P	2.5
6	☐	500.000	510.650	28059.22	0.0082	P	1.7
7	☐	1000.000	991.891	53920.83	0.0159	P	0.2
8	☐			235.81	0.0001	P	3.9

$$y = 1.5914\text{E-}005 * x + 6.6920\text{E-}005$$

$$R = 0.9999$$

$$DL = 0.4992$$

$$BEC = 4.205$$

Weight: <None>


Min Conc: 0

81 Br [No Gas] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			15366.67		P	1.8
2	☐			15297.17		P	2.2
3	☐			15625.28		P	2.9
4	☐			14490.85		P	1.5
5	☐			13784.55		P	0.8
6	☐			13036.67		P	3.0
7	☐			13403.64		P	2.5
8	☐			13248.00		P	5.3

81 Br [He] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			116.78		P	21.6
2	☐			176.85		P	21.4
3	☐			76.74		P	41.9
4	☐			93.43		P	12.4
5	☐			123.46		P	4.7
6	☐			130.14		P	26.7
7	☐			96.77		P	39.2
8	☐			120.12		P	36.3

82 Se [No Gas] ISTD:89 Y [No Gas]

	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	2.27	0.0000	P	405.
2	☐	5.000	5.975	1187.06	0.0001	P	9.3
3	☐	50.000	52.645	10499.81	0.0007	P	0.6
4	☐	125.000	128.258	25554.47	0.0016	P	0.8
5	☐	250.000	257.223	49782.63	0.0033	P	0.5
6	☐	500.000	506.545	95833.45	0.0064	P	0.9
7	☐	1000.000	994.377	186590.10	0.0126	P	1.0
8	☐			78.46	0.0000	P	217.

$$y = 1.2651\text{E-}005 * x + 1.4300\text{E-}007$$

R = 0.9999

DL = 0.1375

BEC = 0.0113


Weight: <None>

Min Conc: 0

83 Kr [No Gas] No available calibration points

	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐			5192.07		P	2.0
2	☐			5128.71		P	1.9
3	☐			5354.36		P	2.2
4	☐			5235.43		P	5.6
5	☐			4937.53		P	1.0
6	☐			4836.38		P	1.2
7	☐			4768.59		P	0.5
8	☐			4666.34		P	3.3

86 Sr [No Gas] ISTD:89 Y [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	8274.77	0.0005	P	1.6
2	☐	1.000	1.037	11930.11	0.0008	P	0.3
3	☐	1250.000	1291.482	4558549.63	0.2892	A	1.0
4	☐	3125.000	3141.896	11068209.62	0.7028	A	0.6
5	☐	6250.000	6321.842	21624433.30	1.4136	A	1.5
6	☐	12500.000	12582.307	42066558.58	2.8130	A	1.3
7	☐	25000.000	24936.700	82685854.62	5.5746	A	1.1
8	☐			29516.17	0.0020	P	1.2

$$y = 2.2353\text{E-}004 * x + 5.2955\text{E-}004$$

$$R = 1.0000$$


$$DL = 0.117$$

$$BEC = 2.369$$

Weight: <None>

Min Conc: 0

88 Sr [No Gas] ISTD:89 Y [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	508.35	0.0000	P	16.4
2	☐	1.000	1.016	31918.69	0.0020	P	1.3
3	☐	1250.000	1274.051	39627428.32	2.5142	A	1.6
4	☐	3125.000	3119.416	96940456.34	6.1557	A	0.7
5	☐	6250.000	6294.812	190015336.19	12.4218	A	1.8
6	☐	12500.000	12543.983	370166391.61	24.7535	A	1.5
7	☐	25000.000	24966.301	730756405.22	49.2669	A	1.1
8	☐			200412.13	0.0139	P	1.3

$$y = 0.0020 * x + 3.2570\text{E-}005$$

$$R = 1.0000$$


$$DL = 0.008122$$

$$BEC = 0.0165$$

Weight: <None>

Min Conc: 0

90 Zr [No Gas] ISTD : 89 Y [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	605.59	0.0000	P	14.7
2	☐	1.000	0.986	19488.38	0.0012	P	2.3
3	☐	50.000	51.834	998586.78	0.0634	P	0.7
4	☐	125.000	126.914	2441814.01	0.1551	A	0.6
5	☐	250.000	250.228	4676145.29	0.3057	A	0.3
6	☐	500.000	499.862	9131080.15	0.6106	A	0.9
7	☐	1000.000	999.681	18111751.79	1.2211	A	1.2
8	☐			7813.39	0.0005	P	2.4

$$y = 0.0012 * x + 3.8805E-005$$

$$R = 1.0000$$


$$DL = 0.01405$$

$$BEC = 0.03177$$

Weight: <None>

Min Conc: 0

91 Zr [No Gas] ISTD : 89 Y [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	144.45	0.0000	P	22.8
2	☐	1.000	1.003	4372.98	0.0003	P	3.2
3	☐	50.000	51.799	219824.90	0.0139	P	0.9
4	☐	125.000	127.484	540292.58	0.0343	P	1.6
5	☐	250.000	252.302	1038593.66	0.0679	P	0.6
6	☐	500.000	505.233	2033012.00	0.1359	A	0.8
7	☐	1000.000	996.407	3976633.12	0.2681	A	1.9
8	☐			1625.13	0.0001	P	11.5

$$y = 2.6906E-004 * x + 9.2618E-006$$

$$R = 1.0000$$


$$DL = 0.02353$$

$$BEC = 0.03442$$

Weight: <None>

Min Conc: 0

94 Mo [No Gas] ISTD:89 Y [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	263.90	0.0000	P	15.5
2	☐	5.000	6.024	23068.66	0.0015	P	1.3
3	☐	500.000	519.983	1980276.46	0.1256	A	1.1
4	☐	1250.000	1262.116	4801543.12	0.3049	A	1.0
5	☐	2500.000	2489.353	9199401.07	0.6014	A	0.4
6	☐	5000.000	5004.412	18078512.04	1.2089	A	1.2
7	☐	10000.000	9997.941	35823594.20	2.4152	A	1.1
8	☐			11529.84	0.0008	P	4.3

$$y = 2.4157E-004 * x + 1.6877E-005$$

$$R = 1.0000$$


$$DL = 0.03251$$

$$BEC = 0.06986$$

Weight: <None>

Min Conc: 0

95 Mo [No Gas] ISTD:89 Y [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	144.45	0.0000	P	43.1
2	☐	5.000	5.191	28706.56	0.0018	P	1.1
3	☐	500.000	513.051	2839658.20	0.1802	A	0.4
4	☐	1250.000	1258.504	6958715.87	0.4419	A	1.6
5	☐	2500.000	2504.311	13451469.83	0.8793	A	0.6
6	☐	5000.000	5026.528	26393304.58	1.7649	A	1.0
7	☐	10000.000	9983.943	51996835.54	3.5055	A	1.4
8	☐			15719.83	0.0011	P	2.6

$$y = 3.5112E-004 * x + 9.2316E-006$$

$$R = 1.0000$$


$$DL = 0.03401$$

$$BEC = 0.02629$$

Weight: <None>

Min Conc: 0

96 Mo [No Gas] ISTD:89 Y [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	261.12	0.0000	P	0.9
2	☐	5.000	5.326	31657.02	0.0020	P	0.2
3	☐	500.000	517.668	3069373.99	0.1947	A	1.1
4	☐	1250.000	1255.968	7439594.52	0.4724	A	1.5
5	☐	2500.000	2520.701	14504356.05	0.9481	A	0.5
6	☐	5000.000	5018.491	28230150.98	1.8876	A	0.1
7	☐	10000.000	9983.950	55701758.19	3.7553	A	0.6
8	☐			22086.65	0.0015	P	3.3

$$y = 3.7613E-004 * x + 1.6712E-005$$

$$R = 1.0000$$


$$DL = 0.001135$$

$$BEC = 0.04443$$

Weight: <None>

Min Conc: 0

97 Mo [No Gas] ISTD:89 Y [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	102.78	0.0000	P	37.8
2	☐	5.000	5.231	17688.83	0.0011	P	2.4
3	☐	500.000	515.572	1743247.85	0.1106	A	0.6
4	☐	1250.000	1262.716	4265331.35	0.2709	A	1.6
5	☐	2500.000	2514.473	8250848.62	0.5394	A	0.9
6	☐	5000.000	4993.995	16020067.20	1.0712	A	0.6
7	☐	10000.000	9997.016	31806073.28	2.1443	A	1.3
8	☐			9489.45	0.0007	P	5.7

$$y = 2.1450E-004 * x + 6.6010E-006$$

$$R = 1.0000$$


$$DL = 0.03491$$

$$BEC = 0.03077$$

Weight: <None>

Min Conc: 0

98 Mo [No Gas] ISTD:89 Y [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	233.34	0.0000	P	18.5
2	☐	5.000	5.263	46168.07	0.0029	P	1.3
3	☐	500.000	513.879	4511390.81	0.2862	A	0.7
4	☐	1250.000	1259.107	11043257.71	0.7013	A	1.0
5	☐	2500.000	2505.374	21345528.43	1.3953	A	0.4
6	☐	5000.000	5020.351	41813759.96	2.7960	A	0.9
7	☐	10000.000	9986.649	82498634.48	5.5619	A	1.0
8	☐			24242.92	0.0017	P	3.9

$$y = 5.5693\text{E-}004 * x + 1.4950\text{E-}005$$

$$R = 1.0000$$


$$DL = 0.01491$$

$$BEC = 0.02684$$

Weight: <None>

Min Conc: 0

106 Cd [No Gas] ISTD:159 Tb [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	6996.30	0.0006	P	4.5
2	☐	1.000	1.947	7685.60	0.0006	P	2.4
3	☐	50.000	56.494	23975.90	0.0019	P	1.8
4	☐	125.000	134.061	47024.07	0.0037	P	2.7
5	☐	250.000	261.337	84719.50	0.0066	P	1.2
6	☐	500.000	509.111	156979.34	0.0123	P	0.1
7	☐	1000.000	991.152	301345.05	0.0235	P	1.7
8	☐			6807.31	0.0006	P	2.7

$$y = 2.3095\text{E-}005 * x + 5.6074\text{E-}004$$

$$R = 0.9999$$


$$DL = 3.251$$

$$BEC = 24.28$$

Weight: <None>

Min Conc: 0

107 Ag [No Gas] ISTD :159 Tb [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	86.11	0.0000	P	11.3
2	☐	1.000	0.907	11585.54	0.0009	P	9.5
3	☐	50.000	56.191	721152.64	0.0561	P	1.1
4	☐	125.000	137.039	1759935.58	0.1369	A	1.8
5	☐	250.000	265.355	3403577.77	0.2650	A	1.1
6	☐	500.000	514.201	6543490.42	0.5135	A	0.8
7	☐	1000.000	987.246	12668036.14	0.9859	A	2.5
8	☐			5378.90	0.0004	P	7.9

$$y = 9.9863E-004 * x + 6.9003E-006$$

$$R = 0.9997$$


$$DL = 0.002346$$

$$BEC = 0.00691$$

Weight: <None>

Min Conc: 0

108 Cd [No Gas] ISTD :159 Tb [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	176.39	0.0000	P	6.9
2	☐	1.000	1.006	393.07	0.0000	P	4.2
3	☐	50.000	55.926	12217.76	0.0010	P	4.1
4	☐	125.000	134.180	29091.76	0.0023	P	1.4
5	☐	250.000	260.297	56194.37	0.0044	P	0.4
6	☐	500.000	513.534	109814.50	0.0086	P	1.0
7	☐	1000.000	989.215	213136.30	0.0166	P	2.5
8	☐			284.73	0.0000	P	7.3

$$y = 1.6754E-005 * x + 1.4123E-005$$

$$R = 0.9998$$


$$DL = 0.1747$$

$$BEC = 0.843$$

Weight: <None>

Min Conc: 0

109 Ag [No Gas] ISTD :159 Tb [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	33.33	0.0000	P	26.3
2	☐	1.000	0.937	11446.52	0.0009	P	7.6
3	☐	50.000	56.147	692465.49	0.0539	P	0.5
4	☐	125.000	136.438	1683750.17	0.1309	A	2.1
5	☐	250.000	265.387	3271164.94	0.2547	A	0.9
6	☐	500.000	513.077	6274389.50	0.4924	A	0.9
7	☐	1000.000	987.878	12183007.48	0.9480	A	1.1
8	☐			5109.36	0.0004	P	4.8

$$y = 9.5966\text{E-}004 * x + 2.6771\text{E-}006$$

$$R = 0.9997$$


$$DL = 0.002205$$

$$BEC = 0.00279$$

Weight: <None>

Min Conc: 0

111 Cd [No Gas] ISTD :159 Tb [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	4866.99	0.0004	P	4.5
2	☐	1.000	1.213	8213.48	0.0006	P	2.6
3	☐	50.000	54.806	154443.81	0.0120	P	0.5
4	☐	125.000	134.471	371889.00	0.0289	P	2.0
5	☐	250.000	262.680	720802.65	0.0561	P	0.3
6	☐	500.000	512.245	1389840.92	0.1091	P	0.7
7	☐	1000.000	989.283	2702177.66	0.2103	A	1.2
8	☐			5628.37	0.0005	P	2.5

$$y = 2.1216\text{E-}004 * x + 3.9008\text{E-}004$$


$$R = 0.9998$$

$$DL = 0.2461$$

$$BEC = 1.839$$

Weight: <None>

Min Conc: 0



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	1583.46	0.0001	P	4.7
2	☐	5.000	5.235	45316.40	0.0036	P	0.4
3	☐	50.000	53.412	453330.70	0.0353	P	0.9
4	☐	125.000	130.331	1104555.76	0.0859	P	1.9
5	☐	250.000	258.283	2184743.58	0.1701	A	1.2
6	☐	500.000	502.761	4217481.34	0.3310	A	2.0
7	☐	1000.000	995.711	8421511.21	0.6554	A	2.4
8	☐			9356.06	0.0008	P	3.1

$$y = 6.5811\text{E-}004 * x + 1.2681\text{E-}004$$


$$R = 1.0000$$

$$DL = 0.02721$$

$$BEC = 0.1927$$

Weight: <None>

Min Conc: 0



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	108.34	0.0000	P	53.4
2	☐	2.000	2.105	20373.27	0.0016	P	2.1
3	☐	50.000	53.097	517847.43	0.0403	P	1.2
4	☐	125.000	130.290	1271374.83	0.0989	P	2.0
5	☐	250.000	255.623	2491387.62	0.1940	A	0.4
6	☐	500.000	507.791	4910058.44	0.3853	A	1.0
7	☐	1000.000	993.883	9689986.33	0.7542	A	3.1
8	☐			9845.31	0.0008	P	2.0

$$y = 7.5880\text{E-}004 * x + 8.6457\text{E-}006$$

$$R = 0.9999$$


$$DL = 0.01824$$

$$BEC = 0.01139$$

Weight: <None>

Min Conc: 0

135 Ba [No Gas] ISTD :159 Tb [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	77.78	0.0000	P	23.4
2	☐	10.000	10.284	24463.15	0.0019	P	1.2
3	☐	250.000	261.804	628904.04	0.0489	P	1.0
4	☐	625.000	653.221	1570078.54	0.1221	M	1.3
5	☐	1250.000	1280.392	3073668.32	0.2393	A	1.2
6	☐	2500.000	2538.587	6045937.81	0.4745	A	1.4
7	☐	5000.000	4968.990	11934411.98	0.9287	A	1.6
8	☐			4867.65	0.0004	P	3.4

$$y = 1.8690E-004 * x + 6.2202E-006$$

$$R = 0.9999$$


$$DL = 0.0234$$

$$BEC = 0.03328$$

Weight: <None>

Min Conc: 0

137 Ba [No Gas] ISTD :159 Tb [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	113.89	0.0000	P	22.7
2	☐	10.000	10.286	42391.48	0.0033	P	1.4
3	☐	250.000	264.216	1100018.49	0.0856	P	1.2
4	☐	625.000	651.310	2713582.42	0.2110	A	1.7
5	☐	1250.000	1272.483	5294700.25	0.4122	A	0.6
6	☐	2500.000	2534.338	10461853.36	0.8210	A	1.4
7	☐	5000.000	4973.210	20703731.02	1.6111	A	1.3
8	☐			8625.01	0.0007	P	3.3

$$y = 3.2396E-004 * x + 9.1316E-006$$

$$R = 0.9999$$

$$DL = 0.01917$$

$$BEC = 0.02819$$

Weight: <None>

Min Conc: 0

150 Nd [No Gas] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			8.89		P	86.6
2	☐			4.44		P	173.
3	☐			66.67		P	10.0
4	☐			131.12		P	15.5
5	☐			222.23		P	4.6
6	☐			420.02		P	20.6
7	☐			762.26		P	10.9
8	☐			111.11		P	12.5

150 Nd [He] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			7.78		P	65.5
2	☐			14.44		P	70.5
3	☐			16.67		P	40.0
4	☐			22.22		P	82.6
5	☐			40.00		P	14.4
6	☐			72.22		P	20.8
7	☐			143.34		P	2.3
8	☐			83.33		P	17.4

156 Dy [No Gas] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			8.33		P	0.0
2	☐			25.00		P	66.7
3	☐			41.67		P	40.0
4	☐			88.89		P	23.6
5	☐			152.78		P	12.6
6	☐			286.12		P	6.1
7	☐			386.13		P	3.3
8	☐			1288.98		P	4.4

156 Dy [He] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			5.56		P	34.7
2	☐			13.33		P	25.0
3	☐			36.67		P	48.1
4	☐			67.78		P	32.0
5	☐			131.11		P	18.0
6	☐			223.34		P	6.5
7	☐			482.24		P	15.8
8	☐			742.25		P	0.3

160 Gd [No Gas] Noavailable calibration poin...


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			125.00		P	0.0
2	☐			108.33		P	13.3
3	☐			144.45		P	52.4
4	☐			125.01		P	43.7
5	☐			138.89		P	22.7
6	☐			166.67		P	18.0
7	☐			291.68		P	14.8
8	☐			936.17		P	5.7

160 Gd [He] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			264.45		P	3.9
2	☐			275.56		P	7.3
3	☐			256.67		P	19.7
4	☐			264.45		P	5.1
5	☐			275.56		P	1.4
6	☐			342.23		P	1.5
7	☐			335.57		P	10.7
8	☐			722.25		P	6.4


164 Er [No Gas] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			119.45		P	40.9
2	☐			102.78		P	16.9
3	☐			100.01		P	30.0
4	☐			113.89		P	52.9
5	☐			127.78		P	57.0
6	☐			97.22		P	26.2
7	☐			113.89		P	22.4
8	☐			100.00		P	16.7

164 Er [He] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			57.78		P	27.3
2	☐			57.78		P	20.3
3	☐			65.55		P	34.6
4	☐			73.34		P	29.8
5	☐			57.78		P	37.1
6	☐			88.89		P	5.7
7	☐			74.44		P	6.8
8	☐			82.23		P	32.8

203 Tl [No Gas] ISTD :209 Bi [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	1250.09	0.0002	P	2.9
2	☐	1.000	0.946	11313.29	0.0014	P	0.7
3	☐	50.000	48.545	522487.61	0.0624	P	1.8
4	☐	125.000	121.980	1316023.62	0.1564	P	0.8
5	☐	250.000	251.075	2665804.73	0.3218	A	1.3
6	☐	500.000	497.171	5251376.11	0.6371	A	0.9
7	☐	1000.000	1001.596	10472032.09	1.2834	A	1.2
8	☐			5484.58	0.0008	P	5.7

$$y = 0.0013 * x + 1.5371E-004$$

R = 1.0000


DL = 0.01032

BEC = 0.12

Weight: <None>

Min Conc: 0

205 Tl [No Gas] ISTD :209 Bi [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	3025.43	0.0004	P	3.4
2	☐	1.000	0.949	27005.01	0.0033	P	0.5
3	☐	50.000	48.410	1237503.71	0.1477	P	1.1
4	☐	125.000	124.774	3196858.88	0.3800	A	1.1
5	☐	250.000	249.237	6284139.46	0.7587	A	1.5
6	☐	500.000	500.072	12541622.33	1.5219	A	2.1
7	☐	1000.000	1000.262	24836227.29	3.0438	A	0.7
8	☐			12923.09	0.0018	P	2.7

$$y = 0.0030 * x + 3.7202E-004$$

R = 1.0000


DL = 0.01244

BEC = 0.1223

Weight: <None>

Min Conc: 0

206 [Pb] [No Gas] ISTD :209 Bi [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	329.64	0.0000	P	13.5
2	☐	1.000	0.975	8853.04	0.0011	P	5.1
3	☐	250.000	250.484	2213486.75	0.2641	A	1.1
4	☐	625.000	625.368	5546747.12	0.6593	A	1.6
5	☐	1250.000	1243.708	10860627.44	1.3112	A	0.7
6	☐	2500.000	2515.161	21852222.25	2.6517	A	2.1
7	☐	5000.000	4993.922	42959805.13	5.2649	A	1.0
8	☐			9540.50	0.0013	P	1.8

$$y = 0.0011 * x + 4.0503E-005$$

$$R = 1.0000$$


$$DL = 0.01559$$

$$BEC = 0.03842$$

Weight: <None>

Min Conc: 0

207 [Pb] [No Gas] ISTD :209 Bi [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	300.01	0.0000	P	20.4
2	☐	1.000	0.929	7517.02	0.0009	P	3.6
3	☐	250.000	251.903	1976750.59	0.2359	A	2.6
4	☐	625.000	625.175	4925261.86	0.5855	A	0.7
5	☐	1250.000	1251.701	9708808.78	1.1722	A	0.3
6	☐	2500.000	2502.344	19310783.77	2.3433	A	2.1
7	☐	5000.000	4998.286	38191998.54	4.6805	A	0.6
8	☐			8280.42	0.0011	P	3.0

$$y = 9.3642E-004 * x + 3.6952E-005$$

$$R = 1.0000$$


$$DL = 0.02412$$

$$BEC = 0.03946$$

Weight: <None>

Min Conc: 0

208 Pb [No Gas] ISTD :209 Bi [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	1301.90	0.0002	P	3.4
2	☐	1.000	0.944	34606.59	0.0042	P	3.2
3	☐	250.000	251.796	8979627.96	1.0715	A	1.0
4	☐	625.000	625.061	22373710.39	2.6596	A	0.9
5	☐	1250.000	1247.978	43980435.59	5.3098	A	0.2
6	☐	2500.000	2511.108	88048128.36	10.6840	A	1.9
7	☐	5000.000	4994.854	173402144.62	21.2513	A	1.0
8	☐			38065.83	0.0053	P	1.4

$$y = 0.0043 * x + 1.6009E-004$$

$$R = 1.0000$$


$$DL = 0.003858$$

$$BEC = 0.03763$$

Weight: <None>

Min Conc: 0

232 Th [No Gas] ISTD :209 Bi [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	538.91	0.0001	P	18.6
2	☐	1.000	0.853	34308.89	0.0041	P	0.7
3	☐	50.000	47.595	1905208.16	0.2273	A	1.1
4	☐	125.000	119.401	4796939.11	0.5702	A	1.5
5	☐	250.000	243.086	9614951.49	1.1608	A	1.4
6	☐	500.000	495.827	19513490.94	2.3677	A	1.3
7	☐	1000.000	1004.635	39142249.48	4.7972	A	1.9
8	☐			3265.27	0.0005	P	6.7

$$y = 0.0048 * x + 6.6285E-005$$

$$R = 1.0000$$


$$DL = 0.007755$$

$$BEC = 0.01388$$

Weight: <None>

Min Conc: 0

238 U [No Gas] ISTD :209 Bi [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	197.23	0.0000	P	17.7
2	☐	1.000	0.906	33005.47	0.0040	P	1.2
3	☐	50.000	46.921	1718906.30	0.2051	M	1.8
4	☐	125.000	119.799	4404189.03	0.5235	A	1.2
5	☐	250.000	245.398	8882517.73	1.0724	A	0.5
6	☐	500.000	498.407	17951541.89	2.1780	A	1.2
7	☐	1000.000	1002.751	35754690.04	4.3820	A	1.4
8	☐			3117.11	0.0004	P	3.8

$$y = 0.0044 * x + 2.4289E-005$$

$$R = 1.0000$$


$$DL = 0.002949$$

$$BEC = 0.005558$$


Weight: <None>

Min Conc: 0


6 Li (ISTD) [No Gas]




	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	1.000		2827249.58		A	1.5
2	☐	1.000		2857691.62		A	1.3
3	☐	1.000		2854238.12		A	0.9
4	☐	1.000		2839974.19		A	0.8
5	☐	1.000		2750226.59		A	0.4
6	☐	1.000		2609855.34		A	1.4
7	☐	1.000		2579670.45		A	0.2
8	☐	1.000		2531075.33		A	1.7

45 Sc (ISTD) [No Gas]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		6757723.51		A	1.3
2	☐	1.000		6788661.91		A	1.5
3	☐	1.000		6790749.76		A	0.5
4	☐	1.000		6674896.15		A	0.4
5	☐	1.000		6386530.11		A	0.5
6	☐	1.000		6177721.50		A	1.2
7	☐	1.000		6094478.24		A	0.2
8	☐	1.000		6136581.02		A	0.8

45 Sc (ISTD) [He]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		535494.57		P	1.3
2	☐	1.000		541537.00		P	0.1
3	☐	1.000		546885.34		P	1.1
4	☐	1.000		528904.95		P	0.6
5	☐	1.000		513080.44		P	1.0
6	☐	1.000		498499.50		P	0.7
7	☐	1.000		491242.63		P	0.8
8	☐	1.000		506491.23		P	0.1

89 Y (ISTD) [No Gas]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	1.000		15624048.52		A	1.4
2	☐	1.000		15671476.43		A	0.4
3	☐	1.000		15762821.85		A	0.8
4	☐	1.000		15748334.90		A	0.5
5	☐	1.000		15297840.19		A	0.5
6	☐	1.000		14955351.31		A	0.9
7	☐	1.000		14833042.70		A	0.4
8	☐	1.000		14401094.09		A	1.1

89 Y (ISTD) [He]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	1.000		3670770.15		A	0.7
2	☐	1.000		3732701.44		A	1.0
3	☐	1.000		3720062.00		A	1.4
4	☐	1.000		3598264.36		A	0.7
5	☐	1.000		3508320.78		A	1.0
6	☐	1.000		3425115.40		A	1.1
7	☐	1.000		3401613.28		A	0.3
8	☐	1.000		3488236.72		A	1.0

103 Rh (ISTD) [No Gas]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	1.000		9959150.06		A	1.6
2	☐	1.000		9923130.27		A	1.5
3	☐	1.000		10052226.31		A	1.2
4	☐	1.000		9926469.57		A	0.1
5	☐	1.000		9480797.36		A	0.7
6	☐	1.000		9062232.23		A	0.6
7	☐	1.000		8921731.88		A	0.7
8	☐	1.000		8267297.45		A	1.6

103 Rh (ISTD) [He]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	1.000		6005448.73		A	0.6
2	☐	1.000		6046176.37		A	0.6
3	☐	1.000		6040907.13		A	1.1
4	☐	1.000		5786358.45		A	0.7
5	☐	1.000		5677374.77		A	0.4
6	☐	1.000		5464682.56		A	0.4
7	☐	1.000		5363336.79		A	0.5
8	☐	1.000		5080061.07		A	0.2

115 In (ISTD) [No Gas]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	1.000		10150102.21		A	1.8
2	☐	1.000		10205370.36		A	1.7
3	☐	1.000		10247261.88		A	1.9
4	☐	1.000		10173607.45		A	0.8
5	☐	1.000		10006080.14		A	0.8
6	☐	1.000		9590500.12		A	0.5
7	☐	1.000		9524801.73		A	0.8
8	☐	1.000		9049047.22		A	0.2

115 In (ISTD) [He]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	1.000		3372769.68		A	1.2
2	☐	1.000		3360987.93		A	1.6
3	☐	1.000		3363346.68		A	0.9
4	☐	1.000		3230217.03		A	0.8
5	☐	1.000		3170915.92		A	0.4
6	☐	1.000		3082258.89		A	0.6
7	☐	1.000		3006390.54		A	1.5
8	☐	1.000		3031430.48		A	0.7

159 Tb (ISTD) [No Gas]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	1.000		12481697.59		A	1.4
2	☐	1.000		12686742.59		A	1.0
3	☐	1.000		12851592.03		A	1.7
4	☐	1.000		12860204.25		A	1.2
5	☐	1.000		12843837.03		A	0.3
6	☐	1.000		12743511.48		A	1.1
7	☐	1.000		12851692.17		A	1.2
8	☐	1.000		12218362.73		A	0.9

159 Tb (ISTD) [He]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	1.000		7941894.74		A	0.9
2	☐	1.000		8163926.55		A	0.2
3	☐	1.000		8226247.45		A	1.0
4	☐	1.000		8111551.34		A	0.9
5	☐	1.000		8032525.02		A	0.8
6	☐	1.000		7975486.75		A	0.4
7	☐	1.000		7979868.21		A	0.3
8	☐	1.000		7798839.12		A	0.2

165 Ho (ISTD) [No Gas]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		12212164.26		A	1.0
2	☐	1.000		12406632.17		A	1.2
3	☐	1.000		12592337.59		A	0.7
4	☐	1.000		12609500.64		A	0.9
5	☐	1.000		12528698.98		A	1.7
6	☐	1.000		12408722.87		A	2.0
7	☐	1.000		12735716.75		A	0.4
8	☐	1.000		12006506.35		A	0.6

165 Ho (ISTD) [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		7886134.26		A	1.0
2	☐	1.000		8063617.17		A	1.3
3	☐	1.000		8103560.50		A	0.2
4	☐	1.000		8025211.69		A	1.5
5	☐	1.000		7884806.13		A	1.2
6	☐	1.000		7983450.78		A	0.9
7	☐	1.000		7933950.58		A	0.2
8	☐	1.000		7752674.12		A	1.1

209 Bi (ISTD) [No Gas]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	1.000		8135147.10		A	1.6
2	☐	1.000		8285340.36		A	1.0
3	☐	1.000		8382039.87		A	2.3
4	☐	1.000		8412432.24		A	0.4
5	☐	1.000		8282884.60		A	0.7
6	☐	1.000		8242980.99		A	1.8
7	☐	1.000		8159878.56		A	0.6
8	☐	1.000		7216179.33		A	0.7

209 Bi (ISTD) [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	1.000		6000356.23		A	0.3
2	☐	1.000		6114808.31		A	0.8
3	☐	1.000		6150043.03		A	1.0
4	☐	1.000		6085151.23		A	1.5
5	☐	1.000		5976137.97		A	2.7
6	☐	1.000		5930670.74		A	0.6
7	☐	1.000		5777855.12		A	0.7
8	☐	1.000		5234856.14		A	0.7

US EPA Tune Check Report

Operator Name Jaswal

Acq/Data Batch D:\Agilent\ICPMH\1\DATA\IP7051522MS1.b

Acq. Date-Time 2022-05-15 15:20:17

Report Comment ---

Instrument Name G8403A JP14410463

[No Gas]

Sensitivity

Mass	Conc. [ug/l]	Count	CPS	Resp (Required) [cps/ug/l]	Resp (Flag)	RSD%	RSD% (Required)
9		11315	113146.42			0.716	5.000
24		99476	994757.05			0.572	5.000
25		13571	135713.51			0.899	5.000
26		15500	155002.96			0.852	5.000
59		28343	283434.19			0.568	5.000
113		13494	134940.33			0.551	5.000
115		37779	377788.91			0.971	5.000
206		18821	188208.73			0.852	5.000
207		15901	159011.33			1.147	5.000
208		38732	387317.01			0.906	5.000
220		0	2.50			48.990	

Mass	RSD% (Flag)
9	
24	
25	
26	
59	
113	
115	
206	
207	
208	
220	


Mass	Rep#1 Count	Rep#2 Count	Rep#3 Count	Rep#4 Count	Rep#5 Count
9	11294	11437	11339	11283	11219
24	99715	100154	99640	99224	98646
25	13685	13685	13562	13532	13393
26	15598	15594	15524	15512	15275
59	28488	28433	28420	28289	28087
113	13503	13612	13480	13466	13409
115	38080	38208	37749	37522	37336
206	18893	18957	18859	18851	18544
207	16091	16025	15962	15775	15652
208	38907	38847	39001	38783	38121

US EPA Tune Check Report

Mass	Rep#1 Count	Rep#2 Count	Rep#3 Count	Rep#4 Count	Rep#5 Count
220	0	0	0	0	0

Integration Time [sec] 0.1

Resolution/Axis



Mass	Peak Height	Axis	Axis (Required)	Axis (Flag)
9	20618.19	8.95	8.90 - 9.10	
24	171257.26	23.90	23.90 - 24.10	
25	22828.60	24.90	24.90 - 25.10	
26	25991.27	25.95	25.90 - 26.10	
59	55018.11	59.00	58.90 - 59.10	
113	29731.50	113.00	112.90 - 113.10	
115	83206.59	115.00	114.90 - 115.10	
206	38512.42	205.95	205.90 - 206.10	
207	33145.04	206.95	206.90 - 207.10	
208	81975.20	207.95	207.90 - 208.10	
220			-	

Mass	W-50%	W-5%	W-5% (Required)	W-5% (Flag)
9	0.58	0.785	0.900	
24	0.63	0.822	0.900	
25	0.62	0.788	0.900	
26	0.63	0.788	0.900	
59	0.53	0.765	0.900	
113	0.46	0.678	0.900	
115	0.46	0.676	0.900	
206	0.49	0.759	0.900	
207	0.48	0.743	0.900	
208	0.48	0.772	0.900	
220				

Integration Time [sec] 0.1

Acquisition Time [sec] 256.770000000002

Y Axis Linear

Tune Parameters

Plasma Parameters

Plasma Mode --- Nebulizer Gas 0.73 L/min Dilution Gas 0.40 L/min

US EPA Tune Check Report

RF Power	1600 W	Option Gas	---	Auxiliary Gas	0.90 L/min
RF Matching	1.80 V	Nebulizer Pump	0.10 rps	Plasma Gas	15.0 L/min
Sample Depth	9.0 mm	S/C Temp	2 °C		

Lens Parameters

Extract 1	0.0 V	Omega Lens	9.0 V	Deflect	14.4 V
Extract 2	-155.0 V	Cell Entrance	-30 V	Plate Bias	-35 V
Omega Bias	-70 V	Cell Exit	-50 V		

Cell Parameters

Use Gas	No	3rd Gas Flow	---	Energy Discrimination	5.0 V
He Flow	0.0 mL/min	OctP Bias	-8.0 V		
H2 Flow	---	OctP RF	190 V		

QP Parameters

Mass Gain	122	Axis Gain	1.0005	QP Bias	-3.0 V
Mass Offset	124	Axis Offset	-0.07		

Hardware Settings

Torch

Torch H	-0.8 mm	Torch V	1.0 mm
---------	---------	---------	--------

EM

Discriminator	3.1 mV	Analog HV	2170 V	Pulse HV	1451 V
---------------	--------	-----------	--------	----------	--------

[He]

Sensitivity

Mass	Conc. [ug/l]	Count	CPS	Resp (Required) [cps/ug/l]	Resp (Flag)	RSD%	RSD% (Required)
59		9575	95749.23			0.675	
89		45667	456665.02			0.460	
205		58689	586891.66			0.331	

Mass	RSD% (Flag)
59	
89	
205	

Mass	Rep#1 Count	Rep#2 Count	Rep#3 Count	Rep#4 Count	Rep#5 Count
59	9594	9631	9552	9474	9624
89	45529	45948	45834	45484	45536
205	58846	58868	58749	58413	58570

Integration Time [sec] 0.1

Tune Parameters

Plasma Parameters

Plasma Mode	---	Nebulizer Gas	0.73 L/min	Dilution Gas	0.40 L/min
RF Power	1600 W	Option Gas	---	Auxiliary Gas	0.90 L/min
RF Matching	1.80 V	Nebulizer Pump	0.10 rps	Plasma Gas	15.0 L/min
Sample Depth	9.0 mm	S/C Temp	2 °C		

Lens Parameters

Extract 1	0.0 V	Omega Lens	8.4 V	Deflect	3.4 V
-----------	-------	------------	-------	---------	-------

US EPA Tune Check Report

Extract 2	-135.0 V	Cell Entrance	-40 V	Plate Bias	-60 V
Omega Bias	-65 V	Cell Exit	-60 V		

Cell Parameters

Use Gas	Yes	3rd Gas Flow	---	Energy Discrimination	5.0 V
He Flow	3.9 mL/min	OctP Bias	-18.0 V		
H2 Flow	---	OctP RF	200 V		

QP Parameters

Mass Gain	122	Axis Gain	1.0005	QP Bias	-13.0 V
Mass Offset	124	Axis Offset	-0.07		

Hardware Settings

Torch

Torch H	-0.8 mm	Torch V	1.0 mm
---------	---------	---------	--------

EM

Discriminator	3.1 mV	Analog HV	2170 V	Pulse HV	1451 V
---------------	--------	-----------	--------	----------	--------