


Batch Folder: D:\Agilent\ICPMH\1\DATA\P7091323MS.b\
Analysis File: P7091323MS.batch.bin
DA Date-Time: 2023-09-13 17:49:22
Calibration Title:
Calibration Method: External Calibration
VIS Interpolation Fit:

Level	Standard Data File	Sample Name	Acq. Date-Time
1	004CALB.d	S00	2023-09-13 15:53:10
2	005CALS.d	S02	2023-09-13 15:56:25
3	006CALS.d	S03	2023-09-13 15:59:41
4	007CALS.d	S04	2023-09-13 16:02:39
5	008CALS.d	S05	2023-09-13 16:05:32
6	009CALS.d	S06	2023-09-13 16:08:17
7	010CALS.d	S07	2023-09-13 16:11:04
8	011CALS.d	S08	2023-09-13 16:13:49

9 Be [No Gas] ISTD:6 Li [No Gas]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	48.89	0.0000	P	28.2
2	☐	1.000	1.118	2643.59	0.0008	P	1.1
3	☐	50.000	54.791	127084.95	0.0385	P	1.6
4	☐	125.000	135.044	312489.85	0.0950	P	0.6
5	☐	250.000	266.052	603289.62	0.1871	P	1.5
6	☐	500.000	498.039	1105710.50	0.3502	A	1.6
7	☐	1000.000	995.472	2145001.27	0.7001	A	1.2
8	☐			594.46	0.0002	P	12.9

$$y = 7.0322\text{E-}004 * x + 1.5234\text{E-}005$$


$$R = 0.9998$$

$$DL = 0.01836$$

$$BEC = 0.02166$$

Weight: <None>


Min Conc: 0

12 C [No Gas] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐						
2	☐						
3	☐						
4	☐						
5	☐						
6	☐						
7	☐						
8	☐						

12 C [He] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐						
2	☐						
3	☐						
4	☐						
5	☐						
6	☐						
7	☐						
8	☐						

23 Na [He] ISTD:45 Sc [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	15844.90	0.0300	P	1.1
2	☐	500.000	512.493	395013.42	0.7295	P	0.6
3	☐	5000.000	5261.581	3836959.84	7.2123	A	1.2
4	☐	12500.000	12976.650	9409286.39	17.7436	A	0.6
5	☐	25000.000	26197.856	18324735.28	35.7911	A	0.6
6	☐	50000.000	51437.202	36097627.80	70.2439	A	0.3
7	☐	100000.00	101631.90	71532761.16	138.7618	A	0.9
8	☐	500000.00	499455.46	330740208.4	681.8075	A	0.7

$$y = 0.0014 * x + 0.0300$$


$$R = 1.0000$$

$$DL = 0.7271$$

$$BEC = 21.96$$

Weight: <None>

Min Conc: 0

24 Mg [He] ISTD:45 Sc [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	526.68	0.0010	P	5.3
2	☐	500.000	512.018	232058.44	0.4286	P	0.7
3	☐	5000.000	5291.155	2351427.38	4.4197	A	0.7
4	☐	12500.000	13070.221	5788746.16	10.9161	A	0.6
5	☐	25000.000	26021.678	11126743.72	21.7321	A	0.2
6	☐	50000.000	50897.234	21842463.56	42.5060	A	1.3
7	☐	100000.00	100300.41	43180286.58	83.7634	A	0.8
8	☐	500000.00	499781.93	202464479.2	417.3764	A	0.7

$$y = 8.3512\text{E-}004 * x + 9.9632\text{E-}004$$


$$R = 1.0000$$

$$DL = 0.1887$$

$$BEC = 1.193$$

Weight: <None>

Min Conc: 0

27 Al [He] ISTD:45 Sc [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	388.90	0.0007	P	7.9
2	☐	20.000	23.742	6067.91	0.0112	P	1.6
3	☐	1000.000	1124.571	264268.05	0.4967	P	0.3
4	☐	2500.000	2796.374	654380.22	1.2340	P	0.6
5	☐	5000.000	5349.776	1208362.00	2.3601	A	0.3
6	☐	10000.000	10535.248	2387993.42	4.6470	A	0.9
7	☐	20000.000	20579.001	4678985.87	9.0766	A	1.3
8	☐	100000.00	99804.530	21351911.21	44.0168	A	0.6

$$y = 4.4102\text{E-}004 * x + 7.3593\text{E-}004$$

$$R = 1.0000$$


$$DL = 0.3947$$

$$BEC = 1.669$$

Weight: <None>

Min Conc: 0

28 Si [No Gas] ISTD:45 Sc [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	344352.47	0.0493	P	1.2
2	☐	10.000	0.440	419652.34	0.0589	P	1.9
3	☐	50.000	55.065	8739641.40	1.2493	A	0.5
4	☐	125.000	137.681	21008413.99	3.0496	A	2.4
5	☐	250.000	265.204	39954008.57	5.8286	A	0.2
6	☐	500.000	519.362	76578083.86	11.3671	A	0.7
7	☐	1000.000	984.775	144640853.4	21.5092	A	1.2
8	☐			932262.72	0.1484	P	9.0

$$y = 0.0218 * x + 0.0493$$

$$R = 0.9994$$


$$DL = 0.08142$$

$$BEC = 2.263$$

Weight: <None>

Min Conc: 0

31 P [He] ISTD:45 Sc [He]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	-7.182	520.02	0.0010	P	9.2
2	☐	0.000	7.182	715.58	0.0013	P	9.0
3	☐	1000.000	1028.937	13487.13	0.0254	P	3.4
4	☐	2500.000	2607.821	33141.50	0.0625	P	0.8
5	☐	5000.000	5141.227	62508.08	0.1221	P	1.2
6	☐	10000.000	10086.566	122516.54	0.2384	P	1.1
7	☐	20000.000	19906.486	241984.88	0.4694	P	0.7
8	☐			511.13	0.0011	P	4.0

$$y = 2.3523E-005 * x + 0.0012$$


$$R = 1.0000$$

$$DL = 13.4$$

$$BEC = 49$$

Weight: <None>

Min Conc: 0

34 S [No Gas] ISTD:45 Sc [No Gas]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	22.561	329167.73	0.0471	P	0.6
2	☐	0.000	-22.561	333349.57	0.0468	P	2.3
3	☐	1000.000	1035.944	385454.25	0.0551	P	0.8
4	☐	2500.000	2548.763	461385.87	0.0670	P	2.9
5	☐	5000.000	4871.503	584207.54	0.0852	P	1.0
6	☐	10000.000	9494.284	818793.69	0.1215	P	0.4
7	☐	20000.000	20277.090	1386830.10	0.2062	A	1.5
8	☐			280477.40	0.0446	P	2.7

$$y = 7.8550E-006 * x + 0.0470$$


$$R = 0.9995$$

$$DL = 263.1$$

$$BEC = 5978$$

Weight: <None>


Min Conc: 0

35 Cl [No Gas] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐						
2	☐						
3	☐						
4	☐						
5	☐						
6	☐						
7	☐						
8	☐						

35 Cl [He] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐						
2	☐						
3	☐						
4	☐						
5	☐						
6	☐						
7	☐						
8	☐						

39 K [He] ISTD:45 Sc [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	67682.80	0.1280	P	0.4
2	☐	500.000	519.473	314778.68	0.5814	P	0.5
3	☐	2500.000	2607.097	1278412.08	2.4031	A	1.6
4	☐	6250.000	6395.615	3027444.50	5.7092	A	1.2
5	☐	12500.000	12825.599	5795944.64	11.3204	A	0.6
6	☐	25000.000	25300.181	11411371.36	22.2064	A	0.7
7	☐	50000.000	50048.532	22580791.05	43.8032	A	0.6
8	☐	250000.00	249939.24	105866788.4	218.2389	A	0.6

$$y = 8.7266E-004 * x + 0.1280$$


$$R = 1.0000$$

$$DL = 1.786$$

$$BEC = 146.7$$

Weight: <None>

Min Conc: 0

43 Ca [No Gas] ISTD:45 Sc [No Gas]

	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	1102.28	0.0002	P	4.0
2	☐	500.000	493.809	17639.24	0.0025	P	1.4
3	☐	5000.000	5945.737	196317.03	0.0281	P	0.8
4	☐	12500.000	15099.205	489255.21	0.0710	P	2.4
5	☐	25000.000	29396.076	946811.34	0.1381	P	0.7
6	☐	50000.000	55384.785	1752108.74	0.2601	A	1.6
7	☐	100000.00	109291.46	3450172.83	0.5131	A	1.7
8	☐	500000.00	497308.99	14672168.67	2.3341	A	4.1

$$y = 4.6932\text{E-}006 * x + 1.5784\text{E-}004$$


$$R = 0.9998$$

$$DL = 4.044$$

$$BEC = 33.63$$

Weight: <None>

Min Conc: 0

44 Ca [No Gas] ISTD:45 Sc [No Gas]

	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	14810.84	0.0021	P	1.2
2	☐	500.000	499.617	283231.07	0.0397	P	1.4
3	☐	5000.000	5435.595	2878631.35	0.4115	A	0.7
4	☐	12500.000	13552.385	7046727.26	1.0227	A	1.6
5	☐	25000.000	26560.532	13726298.27	2.0024	A	0.6
6	☐	50000.000	52916.342	26861111.54	3.9872	A	0.8
7	☐	100000.00	104259.03	52811788.10	7.8538	A	1.7
8	☐	500000.00	498747.86	236159403.1	37.5625	A	3.0

$$y = 7.5309\text{E-}005 * x + 0.0021$$

$$R = 1.0000$$


$$DL = 1.008$$

$$BEC = 28.16$$

Weight: <None>

Min Conc: 0

47 Ti [No Gas] ISTD:45 Sc [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	150.00	0.0000	P	11.4
2	☐	5.000	5.054	7563.07	0.0011	P	2.4
3	☐	500.000	520.908	749994.65	0.1072	P	0.7
4	☐	1250.000	1288.889	1827120.41	0.2652	A	2.5
5	☐	2500.000	2538.098	3580135.50	0.5223	A	0.4
6	☐	5000.000	5037.969	6984143.92	1.0367	A	0.9
7	☐	10000.000	9965.584	13789345.76	2.0506	A	1.4
8	☐			1651.22	0.0003	P	7.5

$$y = 2.0577E-004 * x + 2.1478E-005$$

$$R = 1.0000$$


$$DL = 0.03561$$

$$BEC = 0.1044$$

Weight: <None>

Min Conc: 0

51 V [He] ISTD:45 Sc [He]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	2.22	0.0000	P	86.6
2	☐	5.000	4.893	17439.07	0.0322	P	1.7
3	☐	50.000	51.957	181885.95	0.3419	P	2.0
4	☐	125.000	130.952	456981.09	0.8618	P	0.8
5	☐	250.000	258.953	872482.07	1.7041	P	0.6
6	☐	500.000	501.017	1694281.92	3.2970	A	0.7
7	☐	1000.000	996.412	3380270.09	6.5571	A	0.9
8	☐			1254.51	0.0026	P	6.4

$$y = 0.0066 * x + 4.1948E-006$$


$$R = 0.9999$$

$$DL = 0.001656$$

$$BEC = 0.0006374$$

Weight: <None>

Min Conc: 0

52 Cr [He] ISTD:45 Sc [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	1765.68	0.0033	P	4.3
2	☐	2.000	2.116	10458.17	0.0193	P	2.0
3	☐	50.000	52.718	213528.39	0.4014	P	2.3
4	☐	125.000	131.310	527555.43	0.9948	P	1.3
5	☐	250.000	263.764	1021404.08	1.9950	P	0.7
6	☐	500.000	505.825	1964521.60	3.8228	A	0.4
7	☐	1000.000	992.722	3865941.19	7.4992	A	0.3
8	☐			13529.59	0.0279	P	1.1

$$y = 0.0076 * x + 0.0033$$


$$R = 0.9999$$

$$DL = 0.05732$$

$$BEC = 0.4424$$

Weight: <None>

Min Conc: 0

54 Fe [He] ISTD:45 Sc [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	1946.81	0.0037	P	2.9
2	☐	50.000	56.796	12845.58	0.0237	P	1.6
3	☐	2500.000	2943.984	554637.26	1.0425	P	0.7
4	☐	6250.000	7338.083	1375094.63	2.5930	P	0.3
5	☐	12500.000	13700.998	2477132.74	4.8383	A	0.7
6	☐	25000.000	26681.874	4840213.68	9.4188	A	0.3
7	☐	50000.000	52543.099	9559590.48	18.5443	A	1.3
8	☐	250000.00	249231.50	42662537.14	87.9488	A	0.5

$$y = 3.5287E-004 * x + 0.0037$$


$$R = 0.9999$$

$$DL = 0.9024$$

$$BEC = 10.44$$

Weight: <None>

Min Conc: 0

55 Mn [He] ISTD:45 Sc [He]

	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	190.00	0.0004	P	19.0
2	☐	1.000	1.103	3533.79	0.0065	P	6.3
3	☐	500.000	516.282	1535666.07	2.8865	A	1.1
4	☐	1250.000	1300.025	3854067.03	7.2679	A	1.3
5	☐	2500.000	2558.365	7322942.39	14.3023	A	0.8
6	☐	5000.000	5046.672	14497707.98	28.2126	A	0.9
7	☐	10000.000	9955.005	28688749.85	55.6515	A	0.6
8	☐			16700.48	0.0344	P	1.6

$$y = 0.0056 * x + 3.5975E-004$$


$$R = 1.0000$$

$$DL = 0.03668$$

$$BEC = 0.06435$$

Weight: <None>

Min Conc: 0

56 Fe [He] ISTD:45 Sc [He]

	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	13343.81	0.0252	P	3.8
2	☐	50.000	56.434	208666.43	0.3854	P	0.4
3	☐	2500.000	2693.328	9156749.17	17.2129	A	1.7
4	☐	6250.000	6892.728	23339211.04	44.0116	A	1.1
5	☐	12500.000	13501.718	44127183.23	86.1872	A	0.5
6	☐	25000.000	26463.641	86795912.04	168.9044	A	1.0
7	☐	50000.000	52046.391	171232153.0	332.1622	A	0.5
8	☐	250000.00	249376.26	771967899.6	1.591433	A	1.3

$$y = 0.0064 * x + 0.0252$$


$$R = 1.0000$$

$$DL = 0.4553$$

$$BEC = 3.956$$

Weight: <None>

Min Conc: 0

57 Fe [He] ISTD:45 Sc [He]

	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	837.81	0.0016	P	9.4
2	☐	50.000	57.604	5842.30	0.0108	P	2.3
3	☐	2500.000	2891.880	246632.20	0.4636	P	1.9
4	☐	6250.000	7306.164	619850.16	1.1689	P	0.9
5	☐	12500.000	14403.972	1179072.35	2.3029	P	0.4
6	☐	25000.000	26690.775	2192107.73	4.2660	A	1.7
7	☐	50000.000	51953.798	4279857.33	8.3023	A	0.8
8	☐	250000.00	249314.64	19323308.46	39.8348	A	0.5

$$y = 1.5977E-004 * x + 0.0016$$


$$R = 0.9999$$

$$DL = 2.803$$

$$BEC = 9.923$$

Weight: <None>

Min Conc: 0

59 Co [He] ISTD:45 Sc [He]

	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	42.22	0.0001	P	18.9
2	☐	1.000	1.007	6392.53	0.0118	P	3.2
3	☐	50.000	53.323	330467.47	0.6212	P	1.3
4	☐	125.000	133.115	822300.99	1.5506	P	0.2
5	☐	250.000	259.808	1549534.35	3.0263	A	1.2
6	☐	500.000	513.125	3071397.21	5.9770	A	1.4
7	☐	1000.000	989.805	5943517.69	11.5294	A	0.4
8	☐			15563.73	0.0321	P	0.6

$$y = 0.0116 * x + 7.9961E-005$$


$$R = 0.9998$$

$$DL = 0.003902$$

$$BEC = 0.006865$$

Weight: <None>

Min Conc: 0

60 Ni [He] ISTD:45 Sc [He]

	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	130.00	0.0002	P	9.7
2	☐	1.000	1.099	1909.03	0.0035	P	4.0
3	☐	50.000	53.793	85565.53	0.1608	P	0.6
4	☐	125.000	137.517	217817.18	0.4107	P	0.1
5	☐	250.000	264.226	403941.79	0.7890	P	0.8
6	☐	500.000	510.135	782635.24	1.5230	P	1.0
7	☐	1000.000	989.622	1522959.89	2.9543	A	0.6
8	☐			5522.17	0.0114	P	1.4

$$y = 0.0030 * x + 2.4585E-004$$


$$R = 0.9998$$

$$DL = 0.02385$$

$$BEC = 0.08236$$

Weight: <None>

Min Conc: 0

63 Cu [He] ISTD:45 Sc [He]

	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	1101.16	0.0021	P	7.8
2	☐	2.000	2.146	10603.84	0.0196	P	1.7
3	☐	500.000	535.188	2321980.09	4.3650	A	2.3
4	☐	1250.000	1347.159	5825116.02	10.9844	A	0.9
5	☐	2500.000	2619.331	10933344.98	21.3554	A	1.5
6	☐	5000.000	5108.191	21400313.43	41.6450	A	1.0
7	☐	10000.000	9902.167	41614833.27	80.7264	A	0.8
8	☐			11853.66	0.0244	P	0.8

$$y = 0.0082 * x + 0.0021$$


$$R = 0.9998$$

$$DL = 0.0599$$

$$BEC = 0.2556$$

Weight: <None>

Min Conc: 0

66 Zn [He] ISTD:45 Sc [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	472.23	0.0009	P	7.0
2	☐	2.000	2.423	2111.28	0.0039	P	2.7
3	☐	500.000	557.438	368204.50	0.6922	P	2.1
4	☐	1250.000	1384.073	910662.29	1.7173	P	1.0
5	☐	2500.000	2707.537	1719512.16	3.3585	A	1.9
6	☐	5000.000	5174.721	3298046.86	6.4180	A	1.2
7	☐	10000.000	9841.124	6291577.34	12.2048	A	1.0
8	☐			6418.11	0.0132	P	0.5

$$y = 0.0012 * x + 8.9349E-004$$


$$R = 0.9995$$

$$DL = 0.1509$$

$$BEC = 0.7205$$

Weight: <None>

Min Conc: 0

75 As [He] ISTD:89 Y [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	2.22	0.0000	P	86.6
2	☐	1.000	1.071	494.46	0.0001	P	13.0
3	☐	50.000	52.490	23648.93	0.0057	P	1.4
4	☐	125.000	129.378	58603.89	0.0140	P	1.4
5	☐	250.000	256.629	113733.61	0.0277	P	0.6
6	☐	500.000	508.616	224338.16	0.0549	P	0.3
7	☐	1000.000	993.363	441010.74	0.1072	P	0.1
8	☐			151.11	0.0000	P	27.7

$$y = 1.0794E-004 * x + 5.3707E-007$$

$$R = 0.9999$$


$$DL = 0.01293$$

$$BEC = 0.004976$$

Weight: <None>

Min Conc: 0

77 Se [He] ISTD:89 Y [He]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	2.22	0.0000	P	86.6
2	☐	5.000	4.967	76.67	0.0000	P	22.9
3	☐	50.000	57.713	850.04	0.0002	P	3.8
4	☐	125.000	134.471	1987.93	0.0005	P	3.5
5	☐	250.000	264.831	3829.43	0.0009	P	0.3
6	☐	500.000	513.339	7385.25	0.0018	P	0.6
7	☐	1000.000	988.053	14304.78	0.0035	P	1.8
8	☐			71.11	0.0000	P	21.2

$$y = 3.5196\text{E-}006 * x + 5.3684\text{E-}007$$

$$R = 0.9997$$


$$DL = 0.3963$$

$$BEC = 0.1525$$

Weight: <None>

Min Conc: 0

78 Se [He] ISTD:89 Y [He]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	191.11	0.0000	P	27.1
2	☐	5.000	5.357	462.23	0.0001	P	6.6
3	☐	50.000	54.949	2861.42	0.0007	P	4.6
4	☐	125.000	132.949	6684.91	0.0016	P	1.3
5	☐	250.000	260.661	12637.70	0.0031	P	1.1
6	☐	500.000	512.197	24531.49	0.0060	P	2.5
7	☐	1000.000	989.994	47549.41	0.0116	P	1.1
8	☐			436.68	0.0001	P	2.3

$$y = 1.1631\text{E-}005 * x + 4.6281\text{E-}005$$

$$R = 0.9998$$

$$DL = 3.233$$

$$BEC = 3.979$$

Weight: <None>


Min Conc: 0

81 Br [No Gas] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			26550.70		P	1.7
2	☐			26092.18		P	3.9
3	☐			26252.40		P	1.2
4	☐			26234.66		P	1.1
5	☐			26772.23		P	0.5
6	☐			26197.83		P	0.6
7	☐			26442.69		P	1.3
8	☐			33285.48		P	5.3

81 Br [He] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			133.34		P	10.9
2	☐			57.78		P	17.6
3	☐			58.89		P	21.4
4	☐			63.33		P	19.0
5	☐			75.56		P	13.5
6	☐			87.78		P	13.3
7	☐			128.89		P	15.6
8	☐			1462.31		P	3.4

82 Se [No Gas] ISTD:89 Y [No Gas]

	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	136.01	0.0000	P	20.8
2	☐	5.000	5.251	1094.17	0.0001	P	1.2
3	☐	50.000	54.014	9916.70	0.0005	P	1.5
4	☐	125.000	135.141	24508.39	0.0013	P	1.4
5	☐	250.000	261.858	48158.67	0.0024	P	0.9
6	☐	500.000	514.610	93107.73	0.0048	P	1.9
7	☐	1000.000	988.261	177772.67	0.0092	P	0.6
8	☐			1163.57	0.0001	P	2.7

$$y = 9.2924\text{E-}006 * x + 6.9919\text{E-}006$$


$$R = 0.9997$$

$$DL = 0.4687$$

$$BEC = 0.7524$$


Weight: <None>

Min Conc: 0

83 Kr [No Gas] No available calibration points

	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐			183.34		P	18.5
2	☐			165.56		P	14.3
3	☐			171.11		P	12.5
4	☐			183.33		P	11.4
5	☐			188.89		P	15.9
6	☐			200.01		P	17.4
7	☐			164.45		P	21.1
8	☐			223.34		P	16.6

86 Sr [No Gas] ISTD:89 Y [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	312.23	0.0000	P	11.8
2	☐	1.000	0.995	3961.69	0.0002	P	2.8
3	☐	1250.000	1288.648	4693533.09	0.2409	A	1.3
4	☐	3125.000	3242.241	11760560.93	0.6060	A	2.1
5	☐	6250.000	6284.427	23178682.43	1.1746	A	1.6
6	☐	12500.000	12534.550	45546808.21	2.3428	A	2.2
7	☐	25000.000	24957.531	90229920.88	4.6646	A	1.1
8	☐			9553.20	0.0005	P	2.3

$$y = 1.8690E-004 * x + 1.6040E-005$$

$$R = 1.0000$$


$$DL = 0.03032$$

$$BEC = 0.08582$$

Weight: <None>

Min Conc: 0

88 Sr [No Gas] ISTD:89 Y [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	234.45	0.0000	P	12.5
2	☐	1.000	1.003	32672.98	0.0017	P	1.2
3	☐	1250.000	1282.960	41235511.61	2.1161	A	0.7
4	☐	3125.000	3208.220	102693819.5	5.2917	A	2.3
5	☐	6250.000	6232.845	202882605.8	10.2805	A	1.1
6	☐	12500.000	12566.242	402978611.7	20.7269	A	1.8
7	☐	25000.000	24959.118	796323917.0	41.1678	A	1.2
8	☐			81973.37	0.0046	P	3.9

$$y = 0.0016 * x + 1.2043E-005$$

$$R = 1.0000$$


$$DL = 0.002741$$

$$BEC = 0.007301$$

Weight: <None>

Min Conc: 0

90 Zr [No Gas] ISTD : 89 Y [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	742.25	0.0000	P	11.0
2	☐	1.000	0.907	19204.86	0.0010	P	0.8
3	☐	50.000	51.511	1042437.83	0.0535	P	0.5
4	☐	125.000	129.313	2605548.35	0.1342	A	0.7
5	☐	250.000	250.409	5129606.00	0.2599	A	0.5
6	☐	500.000	500.505	10100387.63	0.5195	A	0.8
7	☐	1000.000	999.030	20055643.17	1.0368	A	0.7
8	☐			8837.20	0.0005	P	1.1

$$y = 0.0010 * x + 3.8139E-005$$

$$R = 1.0000$$


$$DL = 0.01214$$

$$BEC = 0.03675$$

Weight: <None>

Min Conc: 0

91 Zr [No Gas] ISTD : 89 Y [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	131.11	0.0000	P	11.7
2	☐	1.000	0.893	4189.53	0.0002	P	3.1
3	☐	50.000	51.278	231553.04	0.0119	P	0.4
4	☐	125.000	130.218	585494.80	0.0302	P	1.0
5	☐	250.000	251.725	1150613.26	0.0583	P	1.5
6	☐	500.000	502.973	2265052.05	0.1165	A	1.4
7	☐	1000.000	997.366	4468311.11	0.2310	A	1.8
8	☐			1916.81	0.0001	P	0.8

$$y = 2.3160E-004 * x + 6.7378E-006$$

$$R = 1.0000$$


$$DL = 0.01024$$

$$BEC = 0.02909$$

Weight: <None>

Min Conc: 0

94 Mo [No Gas] ISTD:89 Y [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	288.90	0.0000	P	10.1
2	☐	5.000	5.821	23100.53	0.0012	P	1.3
3	☐	500.000	517.341	2014322.69	0.1034	A	1.1
4	☐	1250.000	1283.415	4976768.54	0.2564	A	1.5
5	☐	2500.000	2491.029	9820795.76	0.4977	A	2.1
6	☐	5000.000	5004.414	19439467.90	0.9998	A	1.5
7	☐	10000.000	9994.991	38626563.32	1.9969	A	0.7
8	☐			8847.22	0.0005	P	4.2

$$y = 1.9979E-004 * x + 1.4837E-005$$

$$R = 1.0000$$


$$DL = 0.02255$$

$$BEC = 0.07426$$

Weight: <None>

Min Conc: 0

95 Mo [No Gas] ISTD:89 Y [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	50.00	0.0000	P	43.2
2	☐	5.000	5.091	28525.63	0.0015	P	1.1
3	☐	500.000	514.036	2856542.01	0.1466	A	0.9
4	☐	1250.000	1285.755	7116286.63	0.3667	A	1.8
5	☐	2500.000	2488.278	14003905.35	0.7096	A	0.8
6	☐	5000.000	5023.200	27849757.64	1.4325	A	2.2
7	☐	10000.000	9986.159	55086680.29	2.8478	A	0.8
8	☐			8560.37	0.0005	P	6.3

$$y = 2.8518E-004 * x + 2.5660E-006$$

$$R = 1.0000$$


$$DL = 0.01167$$

$$BEC = 0.008998$$

Weight: <None>

Min Conc: 0

96 Mo [No Gas] ISTD:89 Y [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	140.00	0.0000	P	14.9
2	☐	5.000	5.151	31560.74	0.0016	P	0.4
3	☐	500.000	512.154	3103892.07	0.1593	A	0.5
4	☐	1250.000	1294.485	7813594.47	0.4026	A	1.2
5	☐	2500.000	2504.350	15369618.80	0.7788	A	1.3
6	☐	5000.000	5028.688	30404372.60	1.5639	A	2.2
7	☐	10000.000	9978.400	60027257.44	3.1032	A	0.5
8	☐			23856.36	0.0013	P	4.3

$$y = 3.1099\text{E-}004 * x + 7.1970\text{E-}006$$

$$R = 1.0000$$


$$DL = 0.01032$$

$$BEC = 0.02314$$

Weight: <None>

Min Conc: 0

97 Mo [No Gas] ISTD:89 Y [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	26.67	0.0000	P	11.9
2	☐	5.000	5.116	17832.10	0.0009	P	0.4
3	☐	500.000	513.611	1775756.80	0.0911	A	0.9
4	☐	1250.000	1285.514	4426967.33	0.2281	A	2.0
5	☐	2500.000	2492.605	8727584.04	0.4423	A	1.7
6	☐	5000.000	5025.815	17336285.44	0.8917	A	2.1
7	☐	10000.000	9983.822	34264607.27	1.7714	A	0.7
8	☐			5633.37	0.0003	P	3.6

$$y = 1.7743\text{E-}004 * x + 1.3694\text{E-}006$$

$$R = 1.0000$$


$$DL = 0.002759$$

$$BEC = 0.007718$$

Weight: <None>

Min Conc: 0

98 Mo [No Gas] ISTD:89 Y [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	105.56	0.0000	P	35.0
2	☐	5.000	5.129	46323.27	0.0024	P	0.1
3	☐	500.000	507.783	4545945.59	0.2333	A	1.0
4	☐	1250.000	1277.326	11389819.00	0.5868	A	1.3
5	☐	2500.000	2489.777	22574777.17	1.1439	A	1.0
6	☐	5000.000	4992.586	44592662.67	2.2937	A	2.3
7	☐	10000.000	10002.458	88889608.68	4.5953	A	0.7
8	☐			13701.04	0.0008	P	7.3

$$y = 4.5942\text{E-}004 * x + 5.4179\text{E-}006$$

$$R = 1.0000$$


$$DL = 0.01238$$

$$BEC = 0.01179$$

Weight: <None>

Min Conc: 0

106 Cd [No Gas] ISTD:159 Tb [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	8147.92	0.0005	P	3.1
2	☐	1.000	1.728	8860.56	0.0005	P	1.1
3	☐	50.000	54.749	25201.98	0.0016	P	1.1
4	☐	125.000	137.147	50362.68	0.0031	P	3.0
5	☐	250.000	263.285	90357.65	0.0055	P	0.9
6	☐	500.000	510.878	168309.52	0.0103	P	0.1
7	☐	1000.000	989.483	315587.76	0.0194	P	0.9
8	☐			7536.49	0.0005	P	2.7

$$y = 1.9073\text{E-}005 * x + 5.0912\text{E-}004$$


$$R = 0.9998$$

$$DL = 2.485$$

$$BEC = 26.69$$

Weight: <None>

Min Conc: 0

107 Ag [No Gas] ISTD :159 Tb [No Gas]

	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	90.00	0.0000	P	34.7
2	☐	1.000	1.054	14326.06	0.0009	P	0.3
3	☐	50.000	56.504	757710.89	0.0467	P	0.4
4	☐	125.000	139.517	1858630.03	0.1153	A	1.8
5	☐	250.000	265.111	3579946.72	0.2191	A	1.4
6	☐	500.000	511.191	6934881.22	0.4225	A	0.6
7	☐	1000.000	988.487	13301603.27	0.8169	A	1.3
8	☐			2551.37	0.0002	P	5.2

$$y = 8.2641\text{E-}004 * x + 5.6128\text{E-}006$$


$$R = 0.9997$$

$$DL = 0.007073$$

$$BEC = 0.006792$$

Weight: <None>

Min Conc: 0

108 Cd [No Gas] ISTD :159 Tb [No Gas]

	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	17.78	0.0000	P	11.8
2	☐	1.000	1.026	243.34	0.0000	P	35.6
3	☐	50.000	55.405	12076.23	0.0007	P	1.8
4	☐	125.000	136.544	29542.37	0.0018	P	1.4
5	☐	250.000	263.532	57767.76	0.0035	P	1.6
6	☐	500.000	510.727	112475.24	0.0069	P	0.7
7	☐	1000.000	989.540	216149.89	0.0133	P	1.0
8	☐			168.89	0.0000	P	22.9

$$y = 1.3414\text{E-}005 * x + 1.1119\text{E-}006$$

$$R = 0.9998$$


$$DL = 0.02931$$

$$BEC = 0.08289$$

Weight: <None>

Min Conc: 0

109 Ag [No Gas] ISTD :159 Tb [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	31.11	0.0000	P	17.4
2	☐	1.000	1.060	13779.96	0.0008	P	2.5
3	☐	50.000	56.026	721584.83	0.0445	P	0.8
4	☐	125.000	137.318	1757221.54	0.1090	A	1.0
5	☐	250.000	264.899	3435518.18	0.2103	A	0.7
6	☐	500.000	510.881	6657118.03	0.4055	A	1.1
7	☐	1000.000	988.994	12783570.64	0.7851	A	0.5
8	☐			2444.68	0.0002	P	4.5

$$y = 7.9380\text{E-}004 * x + 1.9466\text{E-}006$$

$$R = 0.9998$$


$$DL = 0.001279$$

$$BEC = 0.002452$$

Weight: <None>

Min Conc: 0

111 Cd [No Gas] ISTD :159 Tb [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	806.79	0.0001	P	3.1
2	☐	1.000	1.100	3732.73	0.0002	P	4.6
3	☐	50.000	55.069	145380.39	0.0090	P	1.0
4	☐	125.000	137.863	360420.53	0.0224	P	0.6
5	☐	250.000	267.445	707808.34	0.0433	P	1.2
6	☐	500.000	517.253	1374687.05	0.0837	P	0.9
7	☐	1000.000	985.151	2596398.91	0.1595	A	0.9
8	☐			1796.59	0.0001	P	7.2

$$y = 1.6180\text{E-}004 * x + 5.0411\text{E-}005$$

$$R = 0.9996$$


$$DL = 0.02916$$

$$BEC = 0.3116$$

Weight: <None>

Min Conc: 0

118 Sn [No Gas] ISTD :159 Tb [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	2696.29	0.0002	P	73.7
2	☐	5.000	4.894	49788.10	0.0030	P	0.5
3	☐	50.000	52.848	506747.60	0.0312	P	1.1
4	☐	125.000	133.167	1264510.32	0.0784	P	1.7
5	☐	250.000	258.300	2483429.67	0.1520	A	0.5
6	☐	500.000	509.143	4915537.11	0.2995	A	1.6
7	☐	1000.000	992.190	9499637.08	0.5834	A	2.1
8	☐			6218.08	0.0004	P	2.7

$$y = 5.8782\text{E-}004 * x + 1.6927\text{E-}004$$

$$R = 0.9999$$


$$DL = 0.6363$$

$$BEC = 0.288$$

Weight: <None>

Min Conc: 0

121 Sb [No Gas] ISTD :159 Tb [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	52.22	0.0000	P	25.1
2	☐	2.000	1.983	21170.10	0.0013	P	1.3
3	☐	50.000	52.556	555705.83	0.0343	P	0.5
4	☐	125.000	132.563	1392561.68	0.0864	P	1.2
5	☐	250.000	256.583	2731853.50	0.1672	A	0.2
6	☐	500.000	507.791	5431938.25	0.3309	A	0.7
7	☐	1000.000	993.385	10540870.33	0.6473	A	1.2
8	☐			6324.79	0.0004	P	6.0

$$y = 6.5165\text{E-}004 * x + 3.2683\text{E-}006$$


$$R = 0.9999$$

$$DL = 0.003782$$

$$BEC = 0.005015$$

Weight: <None>

Min Conc: 0

135 Ba [No Gas] ISTD :159 Tb [No Gas]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	23.33	0.0000	P	78.9
2	☐	10.000	9.471	28786.90	0.0018	P	1.8
3	☐	250.000	251.560	758436.65	0.0467	P	0.8
4	☐	625.000	652.193	1953508.72	0.1212	A	1.8
5	☐	1250.000	1258.608	3821087.03	0.2339	A	0.9
6	☐	2500.000	2531.056	7720621.48	0.4703	A	1.1
7	☐	5000.000	4978.844	15065231.86	0.9252	A	0.4
8	☐			7817.75	0.0005	P	4.3

$$y = 1.8582\text{E-}004 * x + 1.4508\text{E-}006$$


$$R = 1.0000$$

$$DL = 0.01847$$

$$BEC = 0.007807$$

Weight: <None>

Min Conc: 0

137 Ba [No Gas] ISTD :159 Tb [No Gas]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	61.11	0.0000	P	43.9
2	☐	10.000	9.563	50126.89	0.0031	P	1.9
3	☐	250.000	253.054	1315274.61	0.0811	P	0.5
4	☐	625.000	652.712	3370270.30	0.2091	A	1.8
5	☐	1250.000	1253.189	6558476.92	0.4014	A	1.4
6	☐	2500.000	2501.059	13151531.33	0.8012	A	1.0
7	☐	5000.000	4995.057	26054153.50	1.6001	A	1.7
8	☐			13463.12	0.0009	P	3.2

$$y = 3.2034\text{E-}004 * x + 3.8244\text{E-}006$$

$$R = 1.0000$$

$$DL = 0.01573$$


$$BEC = 0.01194$$

Weight: <None>

Min Conc: 0

150 Nd [No Gas] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			6.67		P	100.
2	☐			11.11		P	69.3
3	☐			102.22		P	19.1
4	☐			265.56		P	18.9
5	☐			450.01		P	3.0
6	☐			1022.27		P	4.8
7	☐			1820.14		P	2.2
8	☐			484.46		P	7.2

150 Nd [He] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			12.22		P	56.8
2	☐			6.67		P	100.
3	☐			23.33		P	14.3
4	☐			48.89		P	10.4
5	☐			115.56		P	28.0
6	☐			172.23		P	3.0
7	☐			375.56		P	12.1
8	☐			224.45		P	6.7

156 Dy [No Gas] No available calibration points


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			11.11		P	34.6
2	☐			22.22		P	48.2
3	☐			61.11		P	33.3
4	☐			148.89		P	6.8
5	☐			280.01		P	4.8
6	☐			493.35		P	8.3
7	☐			1040.05		P	4.7
8	☐			2523.59		P	2.5

156 Dy [He] No available calibration points


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			7.78		P	65.5
2	☐			12.22		P	83.3
3	☐			46.67		P	7.1
4	☐			105.56		P	12.8
5	☐			245.56		P	19.3
6	☐			501.13		P	16.0
7	☐			993.38		P	4.7
8	☐			1594.55		P	1.4

160 Gd [No Gas] Noavailable calibration poin...


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			88.89		P	24.1
2	☐			92.22		P	17.1
3	☐			111.11		P	1.7
4	☐			164.45		P	1.2
5	☐			281.12		P	6.5
6	☐			424.46		P	17.2
7	☐			882.26		P	3.2
8	☐			2640.28		P	4.7

160 Gd [He] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			501.13		P	11.3
2	☐			486.68		P	4.9
3	☐			530.02		P	13.8
4	☐			574.46		P	6.4
5	☐			631.13		P	5.9
6	☐			732.25		P	6.4
7	☐			1026.71		P	5.2
8	☐			2133.52		P	2.3


164 Er [No Gas] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			108.89		P	36.5
2	☐			125.56		P	24.1
3	☐			142.22		P	11.8
4	☐			152.23		P	7.7
5	☐			193.34		P	19.0
6	☐			272.23		P	4.9
7	☐			420.01		P	10.1
8	☐			408.90		P	3.1

164 Er [He] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			54.45		P	28.9
2	☐			82.22		P	8.4
3	☐			90.00		P	26.7
4	☐			76.67		P	26.4
5	☐			107.78		P	17.0
6	☐			164.45		P	12.9
7	☐			256.67		P	16.9
8	☐			247.78		P	8.8

203 Tl [No Gas] ISTD :209 Bi [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	66.67	0.0000	P	20.3
2	☐	1.000	0.894	10795.50	0.0011	P	1.8
3	☐	50.000	47.709	561318.23	0.0603	P	0.4
4	☐	125.000	121.189	1420041.39	0.1532	P	1.5
5	☐	250.000	250.876	2940214.47	0.3171	A	0.8
6	☐	500.000	495.538	5766624.36	0.6263	A	1.0
7	☐	1000.000	1002.603	11289446.22	1.2671	A	1.2
8	☐			1716.80	0.0002	P	10.6

$$y = 0.0013 * x + 7.1660E-006$$

$$R = 1.0000$$


$$DL = 0.003445$$

$$BEC = 0.00567$$

Weight: <None>

Min Conc: 0

205 Tl [No Gas] ISTD :209 Bi [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	168.89	0.0000	P	18.0
2	☐	1.000	0.887	25615.26	0.0027	P	0.8
3	☐	50.000	47.721	1343080.56	0.1443	P	0.5
4	☐	125.000	123.882	3472725.36	0.3745	A	1.1
5	☐	250.000	245.378	6879505.52	0.7419	A	0.4
6	☐	500.000	498.293	13871280.91	1.5065	A	0.9
7	☐	1000.000	1002.263	26996528.76	3.0301	A	1.1
8	☐			4148.46	0.0006	P	6.7

$$y = 0.0030 * x + 1.8153E-005$$

$$R = 1.0000$$


$$DL = 0.003251$$

$$BEC = 0.006005$$

Weight: <None>

Min Conc: 0

206 [Pb] [No Gas] ISTD :209 Bi [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	186.67	0.0000	P	17.8
2	☐	1.000	0.887	8947.47	0.0009	P	1.0
3	☐	250.000	249.075	2411207.53	0.2590	A	1.2
4	☐	625.000	620.268	5980917.62	0.6451	A	0.7
5	☐	1250.000	1237.626	11934978.71	1.2871	A	0.9
6	☐	2500.000	2478.406	23732145.76	2.5774	A	0.6
7	☐	5000.000	5014.529	46460274.31	5.2148	A	1.4
8	☐			21454.80	0.0029	P	2.2

$$y = 0.0010 * x + 2.0050E-005$$

$$R = 1.0000$$


$$DL = 0.01029$$

$$BEC = 0.01928$$

Weight: <None>

Min Conc: 0

207 [Pb] [No Gas] ISTD :209 Bi [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	128.89	0.0000	P	16.1
2	☐	1.000	0.884	7705.60	0.0008	P	3.6
3	☐	250.000	251.684	2115154.28	0.2272	A	0.9
4	☐	625.000	629.584	5270205.69	0.5684	A	1.1
5	☐	1250.000	1234.639	10335701.31	1.1146	A	1.7
6	☐	2500.000	2481.372	20626712.19	2.2402	A	1.2
7	☐	5000.000	5012.497	40318306.34	4.5253	A	0.9
8	☐			18117.74	0.0025	P	3.1

$$y = 9.0280E-004 * x + 1.3854E-005$$

$$R = 1.0000$$


$$DL = 0.007404$$

$$BEC = 0.01535$$

Weight: <None>

Min Conc: 0

208 Pb [No Gas] ISTD :209 Bi [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	691.13	0.0001	P	6.7
2	☐	1.000	0.893	35476.21	0.0037	P	2.1
3	☐	250.000	249.821	9543272.81	1.0252	A	0.6
4	☐	625.000	627.755	23885465.62	2.5761	A	1.0
5	☐	1250.000	1240.502	47205064.09	5.0906	A	1.2
6	☐	2500.000	2487.199	93981088.32	10.2065	A	0.4
7	☐	5000.000	5008.440	183116571.4	20.5526	A	0.7
8	☐			84527.89	0.0115	P	2.6

$$y = 0.0041 * x + 7.4256E-005$$

$$R = 1.0000$$


$$DL = 0.003615$$

$$BEC = 0.0181$$

Weight: <None>

Min Conc: 0

238 U [No Gas] ISTD :209 Bi [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	13.33	0.0000	P	114.
2	☐	1.000	0.835	31692.24	0.0033	P	2.0
3	☐	50.000	47.257	1758123.22	0.1889	A	1.8
4	☐	125.000	121.090	4486844.06	0.4840	A	1.9
5	☐	250.000	241.361	8945172.71	0.9647	A	1.4
6	☐	500.000	490.885	18065775.43	1.9620	A	0.7
7	☐	1000.000	1007.343	35870856.13	4.0262	A	1.5
8	☐			3458.27	0.0005	P	9.2

$$y = 0.0040 * x + 1.4337E-006$$


$$R = 0.9999$$

$$DL = 0.001235$$


$$BEC = 0.0003587$$

Weight: <None>


Min Conc: 0

6 Li (ISTD) [No Gas]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		3212807.14		A	1.0
2	☐	1.000		3297819.15		A	2.1
3	☐	1.000		3297501.23		A	1.3
4	☐	1.000		3290155.02		A	1.1
5	☐	1.000		3224789.01		A	1.7
6	☐	1.000		3157469.36		A	1.6
7	☐	1.000		3064346.79		A	1.2
8	☐	1.000		2779690.17		A	3.4

45 Sc (ISTD) [No Gas]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		6982970.59		A	0.3
2	☐	1.000		7126754.20		A	1.4
3	☐	1.000		6995886.70		A	0.4
4	☐	1.000		6891468.44		A	2.4
5	☐	1.000		6854910.59		A	0.4
6	☐	1.000		6737057.54		A	0.7
7	☐	1.000		6725047.54		A	0.9
8	☐	1.000		6290235.18		A	2.5

45 Sc (ISTD) [He]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		528596.00		P	0.8
2	☐	1.000		541460.92		P	0.7
3	☐	1.000		532038.49		P	1.1
4	☐	1.000		530307.48		P	0.8
5	☐	1.000		511997.12		P	0.5
6	☐	1.000		513894.60		P	0.7
7	☐	1.000		515517.88		P	0.5
8	☐	1.000		485094.03		P	0.6

89 Y (ISTD) [No Gas]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		19464185.68		A	0.6
2	☐	1.000		19614104.29		A	0.5
3	☐	1.000		19486486.65		A	0.3
4	☐	1.000		19411128.04		A	1.6
5	☐	1.000		19736320.40		A	1.4
6	☐	1.000		19445644.99		A	1.5
7	☐	1.000		19343518.18		A	0.1
8	☐	1.000		17699613.77		A	3.1

89 Y(ISTD) [He]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		4129187.89		A	0.4
2	☐	1.000		4257169.42		A	0.3
3	☐	1.000		4174175.94		A	1.0
4	☐	1.000		4197025.88		A	1.6
5	☐	1.000		4105946.61		A	0.7
6	☐	1.000		4086395.11		A	0.4
7	☐	1.000		4113103.23		A	0.7
8	☐	1.000		3838947.06		A	0.0

103 Rh(ISTD) [No Gas]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		10992193.87		A	1.2
2	☐	1.000		11108330.25		A	1.4
3	☐	1.000		10892070.39		A	1.2
4	☐	1.000		10733258.87		A	2.7
5	☐	1.000		10667517.76		A	0.8
6	☐	1.000		10313272.48		A	0.2
7	☐	1.000		10062437.56		A	1.1
8	☐	1.000		8693202.30		A	3.6

103 Rh (ISTD) [He]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		5839122.14		A	1.1
2	☐	1.000		5990751.85		A	0.9
3	☐	1.000		5801388.59		A	1.6
4	☐	1.000		5785732.62		A	1.9
5	☐	1.000		5650045.54		A	0.7
6	☐	1.000		5559197.49		A	0.6
7	☐	1.000		5490239.92		A	0.5
8	☐	1.000		4744091.91		A	0.5

115 In (ISTD) [No Gas]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		12036849.64		A	0.9
2	☐	1.000		12283894.62		A	1.4
3	☐	1.000		12128962.69		A	0.3
4	☐	1.000		11977361.77		A	2.5
5	☐	1.000		11905403.25		A	0.1
6	☐	1.000		11773567.21		A	0.8
7	☐	1.000		11563219.32		A	0.7
8	☐	1.000		10303582.32		A	3.5

115 In (ISTD) [He]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		3480402.22		A	0.4
2	☐	1.000		3580102.79		A	0.3
3	☐	1.000		3522129.89		A	1.5
4	☐	1.000		3451131.72		A	1.6
5	☐	1.000		3432231.78		A	1.5
6	☐	1.000		3364906.40		A	0.5
7	☐	1.000		3349877.95		A	0.1
8	☐	1.000		3084114.38		A	0.1

159 Tb (ISTD) [No Gas]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		16001928.24		A	1.0
2	☐	1.000		16344752.53		A	0.9
3	☐	1.000		16224929.90		A	0.9
4	☐	1.000		16122032.12		A	1.7
5	☐	1.000		16338367.95		A	0.9
6	☐	1.000		16415691.84		A	0.5
7	☐	1.000		16283482.95		A	0.3
8	☐	1.000		14586054.64		A	4.6

159 Tb (ISTD) [He]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		9428770.28		A	0.4
2	☐	1.000		9668258.33		A	0.4
3	☐	1.000		9497713.19		A	0.1
4	☐	1.000		9564020.97		A	1.2
5	☐	1.000		9629133.33		A	0.2
6	☐	1.000		9703978.54		A	1.0
7	☐	1.000		9732688.60		A	1.1
8	☐	1.000		8929208.13		A	1.1

165 Ho (ISTD) [No Gas]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		15519785.32		A	0.4
2	☐	1.000		15935727.26		A	1.4
3	☐	1.000		15703222.13		A	1.1
4	☐	1.000		15816056.29		A	1.0
5	☐	1.000		15991162.40		A	0.2
6	☐	1.000		15992115.73		A	0.9
7	☐	1.000		16073031.71		A	0.3
8	☐	1.000		14378922.01		A	3.7

165 Ho (ISTD) [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		9421233.19		A	0.5
2	☐	1.000		9643800.06		A	0.5
3	☐	1.000		9515664.86		A	0.5
4	☐	1.000		9767410.83		A	1.7
5	☐	1.000		9703142.98		A	0.9
6	☐	1.000		9747254.99		A	0.7
7	☐	1.000		9762155.76		A	0.9
8	☐	1.000		8987028.89		A	0.4

209 Bi (ISTD) [No Gas]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		9306702.99		A	0.3
2	☐	1.000		9489834.72		A	1.6
3	☐	1.000		9308409.72		A	0.2
4	☐	1.000		9272592.22		A	1.6
5	☐	1.000		9273736.95		A	1.3
6	☐	1.000		9208123.47		A	0.8
7	☐	1.000		8909901.53		A	0.6
8	☐	1.000		7359102.11		A	2.5

209 Bi (ISTD) [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		6419149.14		A	1.2
2	☐	1.000		6568898.31		A	0.7
3	☐	1.000		6400432.13		A	0.7
4	☐	1.000		6485553.31		A	1.3
5	☐	1.000		6415174.07		A	0.9
6	☐	1.000		6324225.46		A	0.5
7	☐	1.000		6141884.77		A	0.8
8	☐	1.000		5247218.47		A	0.9

US EPA Tune Check Report

Operator Name Jaswal
Acq/Data Batch D:\Agilent\ICPMH\1\DATA\IP7091323MS.b
Acq. Date-Time 2023-09-13 12:17:42
Report Comment ---
Instrument Name G8403A JP14410463

[No Gas]

Sensitivity

Mass	Conc. [ug/l]	Count	CPS	Resp (Required) [cps/ug/l]	Resp (Flag)	RSD%	RSD% (Required)
9		12274	122735.68			0.349	5.000
24		462978	4629777.89			0.398	5.000
25		61014	610143.15			0.552	5.000
26		69039	690388.19			2.972	5.000
59		100622	1006224.96			0.700	5.000
113		14694	146936.35			0.306	5.000
115		175501	1755005.96			0.454	5.000
206		91919	919190.63			0.288	5.000
207		83107	831069.76			0.405	5.000
208		202951	2029514.67			0.480	5.000
220		0	2.70			54.935	

Mass	RSD% (Flag)
9	
24	
25	
26	
59	
113	
115	
206	
207	
208	
220	


Mass	Rep#1 Count	Rep#2 Count	Rep#3 Count	Rep#4 Count	Rep#5 Count
9	12317	12294	12233	12301	12223
24	461353	463052	460902	464692	464889
25	60491	61239	60942	61035	61365
26	69950	66983	66685	70542	71033
59	101521	100406	100461	99666	101059
113	14746	14714	14660	14635	14713
115	176535	176152	174684	175066	175067
206	92147	91637	91808	91754	92249
207	83368	83120	82675	82881	83491
208	201281	203134	203145	203814	203382

US EPA Tune Check Report

Mass	Rep#1 Count	Rep#2 Count	Rep#3 Count	Rep#4 Count	Rep#5 Count
220	1	0	0	0	0

Integration Time [sec] 0.1

Resolution/Axis



Mass	Peak Height	Axis	Axis (Required)	Axis (Flag)
9	19738.29	9.00	8.90 - 9.10	
24	739116.81	23.95	23.90 - 24.10	
25	101326.54	24.95	24.90 - 25.10	
26	115603.98	26.00	25.90 - 26.10	
59	164641.37	58.95	58.90 - 59.10	
113	26515.83	112.95	112.90 - 113.10	
115	317417.34	114.95	114.90 - 115.10	
206	179785.54	205.95	205.90 - 206.10	
207	158744.52	206.95	206.90 - 207.10	
208	386734.65	207.95	207.90 - 208.10	
220			-	

Mass	W-50%	W-5%	W-5% (Required)	W-5% (Flag)
9	0.64	0.780	0.900	
24	0.65	0.830	0.900	
25	0.62	0.747	0.900	
26	0.63	0.776	0.900	
59	0.63	0.783	0.900	
113	0.58	0.737	0.900	
115	0.56	0.737	0.900	
206	0.53	0.798	0.900	
207	0.54	0.735	0.900	
208	0.55	0.786	0.900	
220				

Integration Time [sec] 0.1

Acquisition Time [sec] 256.770000000002

Y Axis Linear

Tune Parameters

Plasma Parameters

Plasma Mode --- Nebulizer Gas 0.82 L/min Dilution Gas 0.40 L/min

US EPA Tune Check Report

RF Power	1600 W	Option Gas	---	Auxiliary Gas	0.90 L/min
RF Matching	1.80 V	Nebulizer Pump	0.10 rps	Plasma Gas	15.0 L/min
Sample Depth	9.0 mm	S/C Temp	2 °C		

Lens Parameters

Extract 1	0.0 V	Omega Lens	8.5 V	Deflect	14.8 V
Extract 2	-125.0 V	Cell Entrance	-30 V	Plate Bias	-35 V
Omega Bias	-65 V	Cell Exit	-50 V		

Cell Parameters

Use Gas	No	3rd Gas Flow	---	Energy Discrimination	5.0 V
He Flow	0.0 mL/min	OctP Bias	-8.0 V		
H2 Flow	---	OctP RF	200 V		

QP Parameters

Mass Gain	131	Axis Gain	0.9970	QP Bias	-3.0 V
Mass Offset	129	Axis Offset	0.16		

Hardware Settings

Torch

Torch H	-1.0 mm	Torch V	0.9 mm
---------	---------	---------	--------

EM

Discriminator	4.6 mV	Analog HV	2275 V	Pulse HV	1406 V
---------------	--------	-----------	--------	----------	--------

[He]

Sensitivity

Mass	Conc. [ug/l]	Count	CPS	Resp (Required) [cps/ug/l]	Resp (Flag)	RSD%	RSD% (Required)
59		32973	329728.21			0.400	
89		343430	3434297.17			1.683	
205		77923	779233.15			0.394	

Mass	RSD% (Flag)
59	
89	
205	

Mass	Rep#1 Count	Rep#2 Count	Rep#3 Count	Rep#4 Count	Rep#5 Count
59	33131	33060	32948	32938	32786
89	349806	336455	340330	349014	341543
205	77956	77777	78348	78020	77516

Integration Time [sec] 0.1

Tune Parameters

Plasma Parameters

Plasma Mode	---	Nebulizer Gas	0.82 L/min	Dilution Gas	0.40 L/min
RF Power	1600 W	Option Gas	---	Auxiliary Gas	0.90 L/min
RF Matching	1.80 V	Nebulizer Pump	0.10 rps	Plasma Gas	15.0 L/min
Sample Depth	9.0 mm	S/C Temp	2 °C		

Lens Parameters

Extract 1	0.0 V	Omega Lens	8.7 V	Deflect	2.4 V
-----------	-------	------------	-------	---------	-------

US EPA Tune Check Report

Extract 2	-120.0 V	Cell Entrance	-40 V	Plate Bias	-60 V
Omega Bias	-60 V	Cell Exit	-60 V		

Cell Parameters

Use Gas	Yes	3rd Gas Flow	---	Energy Discrimination	5.0 V
He Flow	3.9 mL/min	OctP Bias	-18.0 V		
H2 Flow	---	OctP RF	200 V		

QP Parameters

Mass Gain	131	Axis Gain	0.9970	QP Bias	-13.0 V
Mass Offset	129	Axis Offset	0.16		

Hardware Settings

Torch

Torch H	-1.0 mm	Torch V	0.9 mm
---------	---------	---------	--------

EM

Discriminator	4.6 mV	Analog HV	2275 V	Pulse HV	1406 V
---------------	--------	-----------	--------	----------	--------