


Calibration for 004CALB.d

Batch Folder: D:\Agilent\ICPMH\1\DATA\P8022824 MS.b\
 Analysis File: P8022824 MS.batch.bin
 DA Date-Time: 2024-02-28 17:26:20
 Calibration Title:
 Calibration Method: External Calibration
 VIS Interpolation Fit:

Level	Standard Data File	Sample Name	Acq. Date-Time
1	004CALB.d	S00	2024-02-28 11:49:30
2	005CALS.d	S02	2024-02-28 11:52:55
3	006CALS.d	S03	2024-02-28 11:56:21
4	007CALS.d	S04	2024-02-28 11:59:40
5	008CALS.d	S05	2024-02-28 12:02:51
6	009CALS.d	S06	2024-02-28 12:05:55
7	010CALS.d	S07	2024-02-28 12:08:59
8	011CALS.d	S08	2024-02-28 12:12:01

9 Be [No Gas] ISTD:6 Li [No Gas]

	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	31.25	0.0000	P	13.7
2	☐	1.000	1.053	1346.15	0.0007	P	2.6
3	☐	50.000	52.523	64147.71	0.0341	P	1.5
4	☐	125.000	130.435	149242.73	0.0846	P	2.8
5	☐	250.000	255.993	281755.37	0.1661	P	1.6
6	☐	500.000	511.946	543175.07	0.3321	P	1.0
7	☐	1000.000	991.723	1037484.11	0.6434	M	1.1
8	☐			196.23	0.0001	P	6.4

$$y = 6.4874\text{E-}004 * x + 1.6174\text{E-}005$$

$$R = 0.9999$$

$$DL = 0.01022$$

$$BEC = 0.02493$$

Weight: <None>


Min Conc: 0

12 C [No Gas] No available calibration points

	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐			1545056.83		A	1.7
2	☐			1568620.98		A	0.8
3	☐			1656129.58		A	0.9
4	☐			1721125.68		A	1.0
5	☐			1696826.49		A	1.9
6	☐			1755608.78		A	2.1
7	☐			1763507.54		A	3.1
8	☐			1590065.22		A	5.6

12 C [He] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			19879.09		P	1.1
2	☐			20546.63		P	0.1
3	☐			21007.34		P	2.7
4	☐			21993.21		P	2.5
5	☐			22333.72		P	2.7
6	☐			23456.58		P	1.7
7	☐			24770.92		P	0.6
8	☐			25866.13		P	3.0

23 Na [He] ISTD:45 Sc [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	6141.34	0.0615	P	2.5
2	☐	500.000	487.289	102759.79	1.0119	P	4.3
3	☐	5000.000	5264.903	991313.33	10.3295	P	2.3
4	☐	12500.000	13768.834	2337705.99	26.9145	A	11.0
5	☐	25000.000	26071.030	4339222.78	50.9071	A	1.7
6	☐	50000.000	52019.862	8618906.88	101.5143	A	0.5
7	☐	100000.00	101596.18	16543853.50	198.2016	A	1.7
8	☐	500000.00	499390.86	91158241.98	974.0090	A	1.4

$$y = 0.0020 * x + 0.0615$$


$$R = 1.0000$$

$$DL = 2.374$$

$$BEC = 31.54$$

Weight: <None>

Min Conc: 0

24 Mg [He] ISTD:45 Sc [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	128.89	0.0013	P	15.1
2	☐	500.000	493.652	55189.48	0.5435	P	4.9
3	☐	5000.000	5239.369	552517.34	5.7565	P	1.5
4	☐	12500.000	13831.697	1318074.10	15.1948	A	12.9
5	☐	25000.000	26128.528	2446521.73	28.7022	A	1.8
6	☐	50000.000	51208.145	4776087.88	56.2510	A	0.8
7	☐	100000.00	100682.26	9230943.96	110.5960	A	2.6
8	☐	500000.00	499650.62	51368196.46	548.8438	A	1.0

$$y = 0.0011 * x + 0.0013$$


$$R = 1.0000$$

$$DL = 0.5331$$

$$BEC = 1.176$$

Weight: <None>

Min Conc: 0

27 Al [He] ISTD:45 Sc [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	80.00	0.0008	P	15.8
2	☐	20.000	18.958	834.48	0.0082	P	4.9
3	☐	1000.000	1050.030	39486.95	0.4116	P	4.2
4	☐	2500.000	2703.041	91817.45	1.0582	P	12.5
5	☐	5000.000	5125.647	170990.05	2.0059	P	1.2
6	☐	10000.000	10154.937	337333.26	3.9732	P	0.8
7	☐	20000.000	20049.895	654739.05	7.8439	P	0.7
8	☐	100000.00	99962.669	3660418.07	39.1042	A	0.7

$$y = 3.9118E-004 * x + 8.0183E-004$$

$$R = 1.0000$$


$$DL = 0.9715$$

$$BEC = 2.05$$

Weight: <None>

Min Conc: 0

28 Si [No Gas] ISTD :45 Sc [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	165021.76	0.0577	P	3.6
2	☐	10.000	0.311	181066.76	0.0640	P	1.3
3	☐	50.000	53.669	3212186.41	1.1494	A	0.6
4	☐	125.000	131.240	7171853.30	2.7272	A	2.5
5	☐	250.000	256.506	13321205.22	5.2752	A	1.6
6	☐	500.000	507.173	25690368.78	10.3739	A	2.1
7	☐	1000.000	993.920	48591629.28	20.2746	A	1.7
8	☐			766219.98	0.3147	P	5.4

$$y = 0.0203 * x + 0.0577$$

$$R = 0.9998$$


$$DL = 0.3089$$

$$BEC = 2.838$$

Weight: <None>

Min Conc: 0

31 P [He] ISTD :45 Sc [He]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	-18.330	144.45	0.0014	P	19.0
2	☐	0.000	18.330	212.23	0.0021	P	4.7
3	☐	1000.000	1062.877	1946.82	0.0203	P	6.6
4	☐	2500.000	2670.129	4193.98	0.0483	P	14.0
5	☐	5000.000	5155.450	7812.16	0.0917	P	2.5
6	☐	10000.000	9976.108	14917.74	0.1757	P	0.7
7	☐	20000.000	19948.674	29178.26	0.3496	P	2.3
8	☐			173.34	0.0018	P	12.9

$$y = 1.7436E-005 * x + 0.0018$$

$$R = 0.9999$$


$$DL = 32.12$$

$$BEC = 101.2$$

Weight: <None>

Min Conc: 0

34 S [No Gas] ISTD:45 Sc [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	-66.939	213802.37	0.0748	P	3.3
2	☐	0.000	66.939	214469.33	0.0759	P	1.3
3	☐	1000.000	1395.568	241926.28	0.0866	P	1.2
4	☐	2500.000	2116.495	242926.03	0.0924	P	2.0
5	☐	5000.000	4587.762	283539.56	0.1123	P	2.2
6	☐	10000.000	9777.049	381617.70	0.1541	P	2.6
7	☐	20000.000	20242.694	571526.18	0.2385	P	1.3
8	☐			203189.56	0.0835	P	2.7

$$y = 8.0593E-006 * x + 0.0753$$

R = 0.9991

DL = 631.6

BEC = 9345

Weight: <None>

Min Conc: 0


35 Cl [No Gas] No available calibration points



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐			108271.13		P	3.8
2	☐			108035.04		P	4.5
3	☐			137439.59		P	2.8
4	☐			150703.72		P	1.5
5	☐			183700.58		P	0.4
6	☐			272179.89		P	1.0
7	☐			460213.20		P	3.2
8	☐			92344.22		P	1.7

35 Cl [He] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			732.25		P	6.2
2	☐			775.58		P	3.6
3	☐			916.71		P	3.3
4	☐			1052.27		P	9.2
5	☐			1210.06		P	2.1
6	☐			1844.58		P	6.0
7	☐			3312.64		P	1.7
8	☐			702.25		P	6.1

39 K [He] ISTD:45 Sc [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	5803.44	0.0581	P	3.1
2	☐	500.000	487.330	40325.07	0.3971	P	4.5
3	☐	2500.000	2546.556	175566.17	1.8294	P	2.3
4	☐	6250.000	6581.785	402576.24	4.6361	P	11.4
5	☐	12500.000	12543.045	748742.31	8.7825	P	0.5
6	☐	25000.000	25058.632	1484747.18	17.4877	A	0.7
7	☐	50000.000	49338.999	2869380.69	34.3759	A	0.7
8	☐	250000.00	250115.45	16287849.34	174.0261	A	1.0

$$y = 6.9555E-004 * x + 0.0581$$


$$R = 1.0000$$

$$DL = 7.812$$

$$BEC = 83.58$$

Weight: <None>

Min Conc: 0

43 Ca [No Gas] ISTD:45 Sc [No Gas]

	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	207.78	0.0001	P	11.6
2	☐	500.000	502.265	6829.46	0.0024	P	4.0
3	☐	5000.000	5945.026	77712.90	0.0278	P	1.2
4	☐	12500.000	14776.482	181473.57	0.0690	P	2.0
5	☐	25000.000	29319.755	345586.89	0.1368	P	1.4
6	☐	50000.000	58007.010	670285.91	0.2707	P	2.3
7	☐	100000.00	118696.74	1327401.57	0.5538	A	0.5
8	☐	500000.00	495177.59	5621769.01	2.3101	A	1.2

$$y = 4.6650\text{E-}006 * x + 7.2719\text{E-}005$$


$$R = 0.9992$$

$$DL = 5.433$$

$$BEC = 15.59$$

Weight: <None>

Min Conc: 0

44 Ca [No Gas] ISTD:45 Sc [No Gas]

	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	15945.63	0.0056	P	4.9
2	☐	500.000	505.118	124539.94	0.0440	P	0.6
3	☐	5000.000	5673.146	1222988.16	0.4376	M	0.7
4	☐	12500.000	14075.659	2834191.17	1.0775	A	1.0
5	☐	25000.000	27906.342	5379968.60	2.1308	A	2.9
6	☐	50000.000	54767.459	10344441.03	4.1764	A	1.2
7	☐	100000.00	108616.69	19839277.20	8.2772	A	0.9
8	☐	500000.00	497608.47	92215429.74	37.9008	A	0.4

$$y = 7.6155\text{E-}005 * x + 0.0056$$

$$R = 0.9998$$


$$DL = 10.82$$

$$BEC = 73.26$$

Weight: <None>

Min Conc: 0

47 Ti [No Gas] ISTD:45 Sc [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	60.00	0.0000	P	24.9
2	☐	5.000	4.956	3221.51	0.0011	P	3.9
3	☐	500.000	521.164	328670.71	0.1176	P	0.6
4	☐	1250.000	1292.570	766936.76	0.2916	P	2.5
5	☐	2500.000	2535.344	1444702.23	0.5720	A	0.9
6	☐	5000.000	4977.576	2781236.38	1.1230	A	2.0
7	☐	10000.000	9995.996	5405809.36	2.2553	A	0.4
8	☐			1164.51	0.0005	P	8.8

$$y = 2.2562\text{E-}004 * x + 2.0968\text{E-}005$$

$$R = 1.0000$$


$$DL = 0.0694$$

$$BEC = 0.09294$$

Weight: <None>

Min Conc: 0

51 V [He] ISTD:45 Sc [He]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	7.78	0.0001	P	25.7
2	☐	5.000	5.106	5146.53	0.0507	P	3.6
3	☐	50.000	50.855	48372.64	0.5039	P	1.4
4	☐	125.000	132.273	113757.91	1.3106	P	12.0
5	☐	250.000	254.922	215304.71	2.5258	P	1.3
6	☐	500.000	499.647	420299.34	4.9504	P	0.7
7	☐	1000.000	997.994	825333.17	9.8878	P	1.3
8	☐			432.23	0.0046	P	19.8

$$y = 0.0099 * x + 7.8040\text{E-}005$$


$$R = 1.0000$$

$$DL = 0.006072$$

$$BEC = 0.007877$$

Weight: <None>

Min Conc: 0

52 Cr [He] ISTD:45 Sc [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	696.69	0.0070	P	2.8
2	☐	2.000	1.915	3147.05	0.0309	P	2.3
3	☐	50.000	52.023	63154.33	0.6580	P	1.9
4	☐	125.000	134.685	147004.34	1.6925	P	11.0
5	☐	250.000	259.107	276990.94	3.2497	P	1.8
6	☐	500.000	505.579	537789.19	6.3342	P	0.8
7	☐	1000.000	993.622	1038549.31	12.4420	P	0.9
8	☐			26010.43	0.2780	P	2.6

$$y = 0.0125 * x + 0.0070$$


$$R = 0.9999$$

$$DL = 0.04699$$

$$BEC = 0.5575$$

Weight: <None>

Min Conc: 0

54 Fe [He] ISTD:45 Sc [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	223.34	0.0022	P	19.1
2	☐	50.000	52.731	3199.28	0.0315	P	5.7
3	☐	2500.000	2727.499	145543.47	1.5166	P	2.4
4	☐	6250.000	7071.216	341042.29	3.9283	P	11.7
5	☐	12500.000	13589.763	643409.10	7.5475	P	0.9
6	☐	25000.000	26443.752	1246726.26	14.6842	P	0.6
7	☐	50000.000	52594.371	2437637.06	29.2034	A	0.6
8	☐	250000.00	249259.45	12953558.14	138.3945	A	0.6

$$y = 5.5521E-004 * x + 0.0022$$


$$R = 0.9999$$

$$DL = 2.317$$

$$BEC = 4.035$$

Weight: <None>

Min Conc: 0



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	32.22	0.0003	P	43.4
2	☐	1.000	1.046	724.47	0.0071	P	2.7
3	☐	500.000	519.613	324127.38	3.3773	P	1.9
4	☐	1250.000	1339.514	755849.51	8.7057	P	11.6
5	☐	2500.000	2580.805	1429778.57	16.7728	A	1.3
6	☐	5000.000	5044.403	2783430.65	32.7836	A	0.8
7	☐	10000.000	9945.427	5395307.80	64.6351	A	0.4
8	☐			5159.88	0.0552	P	8.6

$$y = 0.0065 * x + 3.2288E-004$$


$$R = 0.9999$$

$$DL = 0.06462$$

$$BEC = 0.04968$$

Weight: <None>

Min Conc: 0



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	1128.94	0.0113	P	5.0
2	☐	50.000	52.278	54715.61	0.5387	P	4.3
3	☐	2500.000	2731.577	2646030.50	27.5706	A	2.0
4	☐	6250.000	6961.190	6096474.08	70.2438	A	12.1
5	☐	12500.000	13363.123	11493512.33	134.8339	A	1.5
6	☐	25000.000	26306.782	22535106.88	265.4245	A	0.7
7	☐	50000.000	51283.483	43190086.86	517.4183	A	0.6
8	☐	250000.00	249549.37	235622723.1	2.517.753	A	1.7

$$y = 0.0101 * x + 0.0113$$


$$R = 1.0000$$

$$DL = 0.1679$$

$$BEC = 1.121$$

Weight: <None>

Min Conc: 0

57 Fe [He] ISTD:45 Sc [He]

	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	64.44	0.0006	P	16.1
2	☐	50.000	52.485	1431.20	0.0141	P	4.8
3	☐	2500.000	2671.054	65758.59	0.6851	P	1.3
4	☐	6250.000	6884.941	153251.69	1.7648	P	11.3
5	☐	12500.000	13227.688	289008.60	3.3901	P	0.9
6	☐	25000.000	25732.410	559881.25	6.5943	P	0.7
7	☐	50000.000	50704.321	1084537.69	12.9930	P	0.7
8	☐	250000.00	249731.92	5989555.88	63.9914	A	0.5

$$y = 2.5624\text{E-}004 * x + 6.4564\text{E-}004$$


$$R = 1.0000$$

$$DL = 1.22$$

$$BEC = 2.52$$

Weight: <None>

Min Conc: 0

59 Co [He] ISTD:45 Sc [He]

	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	87.78	0.0009	P	22.9
2	☐	1.000	1.065	2466.91	0.0243	P	9.5
3	☐	50.000	52.446	110735.66	1.1539	P	2.6
4	☐	125.000	136.149	259870.82	2.9941	P	12.1
5	☐	250.000	259.383	486199.56	5.7035	P	1.2
6	☐	500.000	504.804	942335.98	11.0991	P	0.8
7	☐	1000.000	993.736	1823754.29	21.8483	A	1.0
8	☐			5248.80	0.0561	P	3.6

$$y = 0.0220 * x + 8.8036\text{E-}004$$

$$R = 0.9999$$


$$DL = 0.02751$$

$$BEC = 0.04004$$

Weight: <None>

Min Conc: 0

60 Ni [He] ISTD:45 Sc [He]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	47.78	0.0005	P	10.5
2	☐	1.000	1.021	653.36	0.0064	P	4.3
3	☐	50.000	54.099	30339.07	0.3161	P	3.1
4	☐	125.000	138.608	70260.22	0.8092	P	11.5
5	☐	250.000	261.716	130212.61	1.5275	P	1.3
6	☐	500.000	507.784	251581.15	2.9632	P	1.0
7	☐	1000.000	991.273	482802.67	5.7841	P	0.7
8	☐			7870.01	0.0841	P	1.5

$$y = 0.0058 * x + 4.7846E-004$$

$$R = 0.9998$$


$$DL = 0.02589$$

$$BEC = 0.08201$$

Weight: <None>

Min Conc: 0

63 Cu [He] ISTD:45 Sc [He]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	464.46	0.0047	P	6.8
2	☐	2.000	2.030	3869.46	0.0381	P	6.5
3	☐	500.000	535.659	848055.47	8.8361	P	1.8
4	☐	1250.000	1387.237	1986290.25	22.8761	A	11.5
5	☐	2500.000	2638.203	3708398.83	43.5009	A	0.9
6	☐	5000.000	5092.838	7129608.23	83.9706	A	0.3
7	☐	10000.000	9900.093	13625147.30	163.2282	A	0.8
8	☐			5235.50	0.0561	P	19.8

$$y = 0.0165 * x + 0.0047$$


$$R = 0.9998$$

$$DL = 0.05792$$

$$BEC = 0.282$$

Weight: <None>

Min Conc: 0

66 Zn [He] ISTD:45 Sc [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	130.00	0.0013	P	4.8
2	☐	2.000	5.020	1231.18	0.0121	P	6.6
3	☐	500.000	530.967	109879.94	1.1451	P	3.2
4	☐	1250.000	1368.573	256091.71	2.9494	P	11.5
5	☐	2500.000	2600.638	477632.90	5.6035	P	1.7
6	☐	5000.000	5055.157	924649.92	10.8910	P	1.0
7	☐	10000.000	9930.891	1785743.90	21.3941	A	1.4
8	☐			2680.28	0.0286	P	4.1

$$y = 0.0022 * x + 0.0013$$


$$R = 0.9999$$

$$DL = 0.08767$$

$$BEC = 0.6044$$

Weight: <None>

Min Conc: 0

75 As [He] ISTD:89 Y [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	3.33	0.0000	P	173.2
2	☐	1.000	0.887	102.23	0.0001	P	19.6
3	☐	50.000	49.962	5274.37	0.0063	P	1.9
4	☐	125.000	133.304	12733.63	0.0168	P	10.9
5	☐	250.000	257.148	24035.05	0.0324	P	1.2
6	☐	500.000	499.267	46264.65	0.0629	P	1.3
7	☐	1000.000	997.543	90155.00	0.1257	P	0.8
8	☐			78.89	0.0001	P	20.9

$$y = 1.2602E-004 * x + 3.8946E-006$$

$$R = 0.9999$$


$$DL = 0.1606$$

$$BEC = 0.0309$$

Weight: <None>

Min Conc: 0

77 Se [He] ISTD:89 Y [He]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	0.00	0.0000	P	
2	☐	5.000	6.080	14.44	0.0000	P	86.8
3	☐	50.000	66.561	148.89	0.0002	P	12.9
4	☐	125.000	128.367	261.12	0.0003	P	5.1
5	☐	250.000	254.002	503.35	0.0007	P	5.6
6	☐	500.000	493.361	970.04	0.0013	P	2.9
7	☐	1000.000	1001.065	1919.04	0.0027	P	5.8
8	☐			12.22	0.0000	P	42.7

$$y = 2.6735\text{E-}006 * x + 0.0000\text{E+}000$$

$$R = 0.9998$$


$$DL = 0$$

$$BEC = 0$$

Weight: <None>

Min Conc: 0

78 Se [He] ISTD:89 Y [He]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	10.00	0.0000	P	57.6
2	☐	5.000	4.214	45.55	0.0001	P	4.0
3	☐	50.000	49.821	406.68	0.0005	P	17.4
4	☐	125.000	132.788	965.60	0.0013	P	14.3
5	☐	250.000	249.612	1771.24	0.0024	P	1.1
6	☐	500.000	501.598	3520.48	0.0048	P	3.5
7	☐	1000.000	998.338	6825.05	0.0095	P	2.0
8	☐			48.89	0.0001	P	17.6

$$y = 9.5218\text{E-}006 * x + 1.1611\text{E-}005$$

$$R = 1.0000$$

$$DL = 2.107$$


$$BEC = 1.219$$

Weight: <None>

Min Conc: 0

81 Br [No Gas] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			2163.53		P	4.7
2	☐			2077.95		P	1.6
3	☐			2139.08		P	1.1
4	☐			1876.81		P	3.9
5	☐			1760.13		P	3.3
6	☐			1575.66		P	2.2
7	☐			1772.35		P	2.5
8	☐			2514.70		P	4.1

82 Se [No Gas] ISTD: 89 Y [No Gas]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	-35.56	0.0000	P	-104.
2	☐	5.000	5.378	376.68	0.0000	P	12.5
3	☐	50.000	53.672	4059.55	0.0005	P	2.3
4	☐	125.000	133.784	9553.44	0.0013	P	3.8
5	☐	250.000	263.556	18223.26	0.0025	P	0.5
6	☐	500.000	510.096	35094.30	0.0048	P	0.6
7	☐	1000.000	990.279	66915.12	0.0094	P	0.2
8	☐			375.57	0.0001	P	17.1

$$y = 9.4873E-006 * x - 4.3909E-006$$


$$R = 0.9998$$

$$DL = 1.457$$


$$BEC = -0.4628$$

Weight: <None>

Min Conc: 0

83 Kr [No Gas] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			155.56		P	12.9
2	☐			148.89		P	33.9
3	☐			137.78		P	7.4
4	☐			161.12		P	13.1
5	☐			148.89		P	11.0
6	☐			138.89		P	9.1
7	☐			138.89		P	25.0
8	☐			153.34		P	13.2

86 Sr [No Gas] ISTD : 89 Y [No Gas]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	307.78	0.0000	P	7.3
2	☐	1.000	0.957	1621.22	0.0002	P	1.1
3	☐	625.000	1295.756	1774083.90	0.2206	A	1.7
4	☐	3125.000	3209.831	4127652.16	0.5465	A	3.2
5	☐	6250.000	6353.376	7895896.82	1.0816	A	0.8
6	☐	12500.000	12596.999	15564068.93	2.1445	A	1.5
7	☐	25000.000	24898.284	30199551.22	4.2385	A	1.3
8	☐			4078.46	0.0006	P	5.8

$$y = 1.7023E-004 * x + 3.7775E-005$$

$$R = 0.9997$$


$$DL = 0.04865$$

$$BEC = 0.2219$$

Weight: <None>

Min Conc: 0

88 Sr [No Gas] ISTD:89 Y [No Gas]



	R _{ct}	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	594.47	0.0001	P	5.0
2	☐	1.000	0.986	12372.24	0.0015	P	1.7
3	☐	625.000	1292.412	15375922.27	1.9124	A	0.5
4	☐	3125.000	3219.862	35991729.47	4.7643	A	2.4
5	☐	6250.000	6386.874	68990529.53	9.4503	A	0.6
6	☐	12500.000	12654.749	135911477.9	18.7245	A	0.9
7	☐	25000.000	24859.864	262081631.6	36.7835	A	1.3
8	☐			34949.84	0.0050	P	10.9

$$y = 0.0015 * x + 7.2852E-005$$

$$R = 0.9997$$


$$DL = 0.007431$$

$$BEC = 0.04924$$

Weight: <None>

Min Conc: 0

90 Zr [No Gas] ISTD:89 Y [No Gas]



	R _{ct}	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	302.23	0.0000	P	4.3
2	☐	1.000	0.974	7989.03	0.0010	P	1.9
3	☐	50.000	51.153	402480.62	0.0501	P	1.1
4	☐	125.000	129.608	957858.92	0.1268	P	1.7
5	☐	250.000	256.480	1831086.22	0.2508	A	1.9
6	☐	500.000	506.816	3597828.87	0.4956	A	1.3
7	☐	1000.000	994.338	6928657.19	0.9724	A	0.6
8	☐			2972.57	0.0004	P	0.2

$$y = 9.7787E-004 * x + 3.7069E-005$$

$$R = 0.9999$$


$$DL = 0.004847$$

$$BEC = 0.03791$$

Weight: <None>

Min Conc: 0

91 Zr [No Gas] ISTD: 89 Y [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	42.22	0.0000	P	14.3
2	☐	1.000	0.974	1764.58	0.0002	P	6.1
3	☐	50.000	50.557	89062.38	0.0111	P	0.8
4	☐	125.000	129.025	213523.47	0.0283	P	2.0
5	☐	250.000	255.595	408685.64	0.0560	P	1.0
6	☐	500.000	500.635	795832.32	0.1096	P	0.9
7	☐	1000.000	997.753	1556851.70	0.2185	A	2.2
8	☐			655.58	0.0001	P	15.8

$$y = 2.1900\text{E-}004 * x + 5.1901\text{E-}006$$

$$R = 1.0000$$


$$DL = 0.01016$$

$$BEC = 0.0237$$

Weight: <None>

Min Conc: 0

94 Mo [No Gas] ISTD: 89 Y [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	96.67	0.0000	P	4.5
2	☐	5.000	5.860	9249.81	0.0011	P	2.4
3	☐	500.000	515.558	801849.98	0.0997	P	0.7
4	☐	1250.000	1294.316	1891552.77	0.2504	A	1.7
5	☐	2500.000	2594.797	3663976.40	0.5019	A	1.0
6	☐	5000.000	5019.363	7045945.17	0.9708	A	1.9
7	☐	10000.000	9960.301	13726363.27	1.9265	A	1.4
8	☐			5907.99	0.0008	P	3.3

$$y = 1.9342\text{E-}004 * x + 1.1851\text{E-}005$$

$$R = 0.9999$$


$$DL = 0.00827$$

$$BEC = 0.06127$$

Weight: <None>

Min Conc: 0

95 Mo [No Gas] ISTD:89 Y [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	25.56	0.0000	P	9.7
2	☐	5.000	5.081	11352.50	0.0014	P	3.3
3	☐	500.000	513.058	1138688.07	0.1416	P	0.6
4	☐	1250.000	1315.037	2742555.65	0.3630	A	1.7
5	☐	2500.000	2577.104	5193107.32	0.7114	A	1.0
6	☐	5000.000	5023.526	10063320.55	1.3867	A	2.1
7	☐	10000.000	9960.178	19589766.93	2.7493	A	1.2
8	☐			8163.60	0.0012	P	3.5

$$y = 2.7603\text{E-}004 * x + 3.1390\text{E-}006$$

$$R = 1.0000$$


$$DL = 0.003302$$

$$BEC = 0.01137$$

Weight: <None>

Min Conc: 0

96 Mo [No Gas] ISTD:89 Y [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	☐	0.000	0.000	88.89	0.0000	P	16.1
2	☐	5.000	4.984	12459.00	0.0015	P	1.4
3	☐	500.000	508.730	1256982.74	0.1563	P	0.6
4	☐	1250.000	1296.327	3009427.39	0.3984	A	2.3
5	☐	2500.000	2560.762	5744641.93	0.7869	A	1.2
6	☐	5000.000	4997.148	11146043.45	1.5356	A	0.5
7	☐	10000.000	9980.008	21852046.89	3.0668	A	0.6
8	☐			8999.70	0.0013	P	4.1

$$y = 3.0729\text{E-}004 * x + 1.0907\text{E-}005$$

$$R = 1.0000$$


$$DL = 0.01716$$

$$BEC = 0.0355$$

Weight: <None>

Min Conc: 0

97 Mo [No Gas] ISTD:89 Y [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	18.89	0.0000	P	60.5
2	☐	5.000	5.009	6979.60	0.0009	P	3.7
3	☐	500.000	514.554	711725.03	0.0885	P	1.3
4	☐	1250.000	1296.617	1684893.76	0.2231	A	3.4
5	☐	2500.000	2582.562	3243755.86	0.4443	A	1.4
6	☐	5000.000	5001.810	6245958.31	0.8605	A	0.5
7	☐	10000.000	9971.900	12224008.02	1.7155	A	0.4
8	☐			4784.21	0.0007	P	2.2

$$y = 1.7204\text{E-}004 * x + 2.3047\text{E-}006$$

$$R = 1.0000$$


$$DL = 0.0243$$

$$BEC = 0.0134$$

Weight: <None>

Min Conc: 0

98 Mo [No Gas] ISTD:89 Y [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	44.44	0.0000	P	40.6
2	☐	5.000	5.011	18161.99	0.0022	P	2.8
3	☐	500.000	515.611	1855913.01	0.2308	A	1.3
4	☐	1250.000	1285.152	4347243.41	0.5753	A	1.3
5	☐	2500.000	2548.196	8327648.90	1.1408	A	1.5
6	☐	5000.000	5034.325	16357399.62	2.2538	A	1.5
7	☐	10000.000	9965.614	31787018.69	4.4614	A	1.4
8	☐			12753.77	0.0018	P	3.2

$$y = 4.4768\text{E-}004 * x + 5.4830\text{E-}006$$

$$R = 1.0000$$


$$DL = 0.01491$$

$$BEC = 0.01225$$

Weight: <None>

Min Conc: 0

106 Cd [No Gas] ISTD:159 Tb [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	2365.78	0.0004	P	5.2
2	☐	1.000	0.635	2424.69	0.0004	P	4.2
3	☐	50.000	52.061	8573.86	0.0013	P	3.4
4	☐	125.000	130.197	17238.68	0.0028	P	0.9
5	☐	250.000	252.011	30864.57	0.0050	P	1.0
6	☐	500.000	501.697	58900.94	0.0096	P	2.5
7	☐	1000.000	997.896	111015.99	0.0188	P	1.0
8	☐			1960.16	0.0003	P	2.7

$$y = 1.8501\text{E-}005 * x + 3.6762\text{E-}004$$

$$R = 1.0000$$


$$DL = 3.072$$

$$BEC = 19.87$$

Weight: <None>

Min Conc: 0

107 Ag [No Gas] ISTD:159 Tb [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	58.89	0.0000	P	27.1
2	☐	1.000	1.048	5717.91	0.0009	P	3.1
3	☐	50.000	53.635	291754.33	0.0453	P	1.6
4	☐	125.000	131.625	690046.38	0.1111	P	0.4
5	☐	250.000	256.188	1327171.79	0.2163	P	0.8
6	☐	500.000	511.131	2634250.13	0.4315	A	1.8
7	☐	1000.000	991.878	4937334.09	0.8374	A	0.5
8	☐			1037.83	0.0002	P	8.2

$$y = 8.4426\text{E-}004 * x + 9.1971\text{E-}006$$

$$R = 0.9999$$


$$DL = 0.008849$$

$$BEC = 0.01089$$

Weight: <None>

Min Conc: 0

108 Cd [No Gas] ISTD:159 Tb [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	6.67	0.0000	P	50.8
2	☐	1.000	0.953	88.89	0.0000	P	13.5
3	☐	50.000	53.934	4699.73	0.0007	P	2.0
4	☐	125.000	131.518	11036.74	0.0018	P	1.1
5	☐	250.000	254.377	21089.61	0.0034	P	1.2
6	☐	500.000	499.330	41181.28	0.0067	P	1.3
7	☐	1000.000	998.229	79507.50	0.0135	P	0.6
8	☐			77.78	0.0000	P	41.3

$$y = 1.3508\text{E-}005 * x + 1.0440\text{E-}006$$

$$R = 1.0000$$


$$DL = 0.1178$$

$$BEC = 0.07729$$

Weight: <None>

Min Conc: 0

109 Ag [No Gas] ISTD:159 Tb [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	22.22	0.0000	P	49.6
2	☐	1.000	1.012	5335.53	0.0008	P	2.9
3	☐	50.000	53.667	283964.45	0.0441	P	1.5
4	☐	125.000	130.811	667127.76	0.1074	P	0.3
5	☐	250.000	254.358	1281934.11	0.2089	P	0.7
6	☐	500.000	499.409	2503901.96	0.4102	A	1.8
7	☐	1000.000	998.296	4834394.75	0.8199	A	0.6
8	☐			967.83	0.0002	P	2.3

$$y = 8.2134\text{E-}004 * x + 3.4885\text{E-}006$$


$$R = 1.0000$$

$$DL = 0.006317$$

$$BEC = 0.004247$$

Weight: <None>

Min Conc: 0

111 Cd [No Gas] ISTD:159 Tb [No Gas]

	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	1662.49	0.0003	P	5.2
2	☐	1.000	1.037	2796.23	0.0004	P	3.4
3	☐	50.000	53.860	61544.88	0.0096	P	1.2
4	☐	125.000	132.527	143622.61	0.0231	P	0.7
5	☐	250.000	257.108	273861.42	0.0446	P	0.8
6	☐	500.000	498.357	526656.56	0.0863	P	0.9
7	☐	1000.000	997.911	1016927.08	0.1725	P	1.1
8	☐			1985.47	0.0003	P	2.9

$$y = 1.7259\text{E-}004 * x + 2.5833\text{E-}004$$


$$R = 1.0000$$

$$DL = 0.2331$$

$$BEC = 1.497$$

Weight: <None>

Min Conc: 0

118 Sn [No Gas] ISTD:159 Tb [No Gas]

	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	545.57	0.0001	P	4.3
2	☐	5.000	5.075	19361.57	0.0030	P	1.0
3	☐	50.000	52.077	195059.49	0.0303	P	1.7
4	☐	125.000	129.027	465059.38	0.0749	P	0.3
5	☐	250.000	251.317	894659.57	0.1458	P	0.8
6	☐	500.000	502.324	1778546.64	0.2914	A	1.5
7	☐	1000.000	997.901	3411919.33	0.5787	A	1.2
8	☐			2730.30	0.0005	P	6.1

$$y = 5.7984\text{E-}004 * x + 8.4838\text{E-}005$$

$$R = 1.0000$$


$$DL = 0.01867$$

$$BEC = 0.1463$$

Weight: <None>

Min Conc: 0

121 Sb [No Gas] ISTD :159 Tb [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	27.78	0.0000	P	41.6
2	☐	2.000	2.065	9229.87	0.0014	P	1.6
3	☐	50.000	51.567	231544.16	0.0359	P	1.3
4	☐	125.000	128.157	554614.41	0.0893	P	1.1
5	☐	250.000	251.098	1073793.42	0.1750	P	1.1
6	☐	500.000	497.724	2117547.80	0.3469	A	1.6
7	☐	1000.000	1000.390	4110615.88	0.6972	A	1.6
8	☐			2496.92	0.0004	P	8.7

$$y = 6.9694\text{E-}004 * x + 4.3556\text{E-}006$$

$$R = 1.0000$$


$$DL = 0.007794$$

$$BEC = 0.00625$$

Weight: <None>

Min Conc: 0

135 Ba [No Gas] ISTD :159 Tb [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	81.11	0.0000	P	11.6
2	☐	10.000	9.760	10597.55	0.0017	P	0.7
3	☐	250.000	253.574	275313.59	0.0427	P	1.9
4	☐	625.000	630.331	659566.85	0.1062	P	0.3
5	☐	1250.000	1234.578	1276598.13	0.2080	P	0.9
6	☐	2500.000	2477.043	2548091.59	0.4174	A	1.6
7	☐	5000.000	5014.490	4981827.57	0.8450	A	1.4
8	☐			2525.85	0.0004	P	5.9

$$y = 1.6851\text{E-}004 * x + 1.2613\text{E-}005$$


$$R = 1.0000$$

$$DL = 0.02602$$

$$BEC = 0.07485$$

Weight: <None>

Min Conc: 0

137 Ba [No Gas] ISTD :159 Tb [No Gas]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	66.66	0.0000	P	5.8
2	☐	10.000	10.109	18576.20	0.0029	P	3.1
3	☐	250.000	259.271	478466.18	0.0743	P	1.0
4	☐	625.000	649.413	1154951.17	0.1860	P	0.6
5	☐	1250.000	1266.346	2225518.40	0.3627	A	1.2
6	☐	2500.000	2497.106	4365801.88	0.7152	A	1.9
7	☐	5000.000	4993.845	8432670.08	1.4303	A	1.5
8	☐			4370.76	0.0007	P	2.7

$$y = 2.8641E-004 * x + 1.0360E-005$$

$$R = 1.0000$$

$$DL = 0.006307$$

$$BEC = 0.03617$$

Weight: <None>

Min Conc: 0

150 Nd [No Gas] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			14.44		P	66.6
2	☐			14.44		P	13.4
3	☐			33.33		P	26.5
4	☐			61.11		P	3.1
5	☐			86.67		P	16.8
6	☐			190.00		P	19.0
7	☐			333.34		P	9.5
8	☐			164.45		P	18.2

150 Nd [He] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			4.44		P	114.6
2	☐			0.00		P	
3	☐			2.22		P	86.6
4	☐			7.78		P	65.5
5	☐			10.00		P	57.7
6	☐			24.44		P	34.3
7	☐			60.00		P	0.0
8	☐			50.00		P	29.1

156 Dy [No Gas] No available calibration points


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			4.45		P	86.6
2	☐			5.56		P	34.7
3	☐			22.22		P	77.0
4	☐			60.00		P	29.4
5	☐			105.56		P	25.7
6	☐			154.45		P	21.3
7	☐			351.12		P	5.6
8	☐			1007.83		P	0.5

156 Dy [He] No available calibration points


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			3.33		P	0.0
2	☐			2.22		P	86.6
3	☐			6.67		P	50.0
4	☐			16.67		P	52.9
5	☐			38.89		P	32.4
6	☐			88.89		P	9.4
7	☐			162.22		P	4.3
8	☐			450.01		P	5.2

160 Gd [No Gas] Noavailable calibration poin_

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			55.55		P	6.9
2	☐			57.78		P	18.5
3	☐			78.89		P	24.4
4	☐			94.45		P	18.1
5	☐			125.56		P	15.1
6	☐			208.89		P	7.4
7	☐			331.12		P	1.2
8	☐			1150.06		P	10.5

160 Gd [He] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			98.89		P	15.6
2	☐			78.89		P	12.9
3	☐			62.22		P	43.6
4	☐			126.67		P	12.1
5	☐			93.33		P	38.6
6	☐			126.67		P	20.6
7	☐			207.78		P	10.3
8	☐			588.91		P	7.9

164 Er [No Gas] No available calibration points


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			45.56		P	22.4
2	☐			38.89		P	47.2
3	☐			54.44		P	21.5
4	☐			70.00		P	17.2
5	☐			82.22		P	14.2
6	☐			82.22		P	18.7
7	☐			161.11		P	19.2
8	☐			165.56		P	12.1

164 Er [He] No available calibration points


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			14.44		P	35.3
2	☐			16.67		P	52.9
3	☐			20.00		P	33.4
4	☐			23.33		P	37.8
5	☐			24.44		P	31.5
6	☐			45.56		P	21.1
7	☐			65.56		P	21.2
8	☐			98.89		P	17.3

172 Yb [No Gas] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			24.45		P	43.8
2	☐			42.22		P	32.9
3	☐			61.11		P	11.4
4	☐			61.11		P	8.3
5	☐			82.22		P	20.4
6	☐			108.89		P	24.6
7	☐			163.34		P	9.4
8	☐			146.67		P	13.6

172 Yb [He] No available calibration points


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			22.22		P	22.9
2	☐			18.89		P	20.4
3	☐			20.00		P	33.4
4	☐			22.22		P	45.8
5	☐			41.11		P	16.9
6	☐			50.00		P	17.6
7	☐			52.22		P	38.5
8	☐			57.78		P	17.6

176 Yb [No Gas] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			822.25		P	2.8
2	☐			785.59		P	9.8
3	☐			1942.39		P	4.1
4	☐			3657.21		P	2.1
5	☐			6245.97		P	4.3
6	☐			11717.52		P	1.2
7	☐			22656.17		P	1.1
8	☐			752.25		P	10.1

176 Yb [He] No available calibration points

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐			7415.51		P	1.9
2	☐			7653.41		P	7.1
3	☐			7825.73		P	2.3
4	☐			7780.16		P	9.5
5	☐			9000.93		P	4.6
6	☐			11233.79		P	1.6
7	☐			15246.71		P	1.5
8	☐			7257.63		P	7.2

203 Tl [No Gas] ISTD :209 Bi [No Gas]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	236.67	0.0001	P	8.4
2	☐	1.000	0.921	5432.32	0.0012	P	2.7
3	☐	50.000	48.511	275304.83	0.0600	P	1.4
4	☐	125.000	122.170	672236.72	0.1511	P	2.2
5	☐	250.000	246.113	1331073.22	0.3044	P	3.1
6	☐	500.000	504.932	2656324.47	0.6245	A	0.5
7	☐	1000.000	998.934	5189268.47	1.2355	A	1.3
8	☐			2070.19	0.0005	P	8.9

$$y = 0.0012 * x + 5.1565E-005$$

$$R = 1.0000$$


$$DL = 0.01055$$

$$BEC = 0.04169$$

Weight: <None>

Min Conc: 0

205 Tl [No Gas] ISTD :209 Bi [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	503.35	0.0001	P	11.2
2	☐	1.000	0.962	13389.23	0.0029	P	2.1
3	☐	50.000	49.726	669922.24	0.1461	P	1.6
4	☐	125.000	126.082	1647229.49	0.3704	M	2.0
5	☐	250.000	258.941	3325576.23	0.7605	A	2.6
6	☐	500.000	506.986	6332640.39	1.4889	A	0.9
7	☐	1000.000	994.150	12262021.49	2.9195	A	1.6
8	☐			4874.30	0.0013	P	4.8

$$y = 0.0029 * x + 1.0947E-004$$

$$R = 0.9999$$


$$DL = 0.01249$$

$$BEC = 0.03728$$

Weight: <None>

Min Conc: 0

206 [Pb] [No Gas] ISTD :209 Bi [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	258.89	0.0001	P	16.8
2	☐	1.000	0.977	4520.84	0.0010	P	5.6
3	☐	250.000	245.012	1074784.02	0.2344	P	0.4
4	☐	625.000	629.185	2677080.81	0.6019	A	1.7
5	☐	1250.000	1268.145	5305746.83	1.2131	A	1.4
6	☐	2500.000	2472.159	10057686.17	2.3647	A	1.1
7	☐	5000.000	5009.110	20125012.06	4.7914	A	1.0
8	☐			10486.55	0.0027	P	4.0

$$y = 9.5652E-004 * x + 5.6280E-005$$

$$R = 1.0000$$


$$DL = 0.02968$$

$$BEC = 0.05884$$

Weight: <None>

Min Conc: 0

207 [Pb] [No Gas] ISTD :209 Bi [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	231.11	0.0001	P	17.9
2	☐	1.000	1.001	4020.67	0.0009	P	2.1
3	☐	250.000	245.753	935633.75	0.2041	P	1.3
4	☐	625.000	639.841	2363424.13	0.5313	A	0.3
5	☐	1250.000	1273.854	4625083.89	1.0577	A	2.3
6	☐	2500.000	2479.012	8754760.15	2.0583	A	1.5
7	☐	5000.000	5002.888	17446736.96	4.1537	A	1.9
8	☐			8859.77	0.0023	P	2.1

$$y = 8.3026\text{E-}004 * x + 5.0268\text{E-}005$$

$$R = 1.0000$$


$$DL = 0.03249$$

$$BEC = 0.06054$$

Weight: <None>

Min Conc: 0

208 Pb [No Gas] ISTD :209 Bi [No Gas]



	R _j ct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	☐	0.000	0.000	1022.25	0.0002	P	4.8
2	☐	1.000	1.003	18486.53	0.0041	P	2.1
3	☐	250.000	249.812	4372005.71	0.9536	A	1.0
4	☐	625.000	637.094	10816584.99	2.4315	A	0.5
5	☐	1250.000	1265.015	21112616.67	4.8278	A	2.0
6	☐	2500.000	2494.218	40486251.83	9.5188	A	0.6
7	☐	5000.000	4997.635	80108220.05	19.0724	A	1.6
8	☐			41453.12	0.0108	P	3.5

$$y = 0.0038 * x + 2.2246\text{E-}004$$

$$R = 1.0000$$


$$DL = 0.008388$$

$$BEC = 0.05829$$

Weight: <None>

Min Conc: 0

238 U [No Gas] ISTD :209 Bi [No Gas]



	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	0.000	0.000	24.44	0.0000	P	19.8
2	☐	1.000	0.910	18854.13	0.0041	P	1.8
3	☐	50.000	47.411	985761.46	0.2150	P	1.1
4	☐	125.000	124.754	2517183.31	0.5658	A	0.7
5	☐	250.000	250.715	4971828.36	1.1370	A	2.7
6	☐	500.000	497.683	9599640.48	2.2570	A	1.5
7	☐	1000.000	1001.140	19068836.66	4.5403	A	2.1
8	☐			5261.15	0.0014	P	8.1

$$y = 0.0045 * x + 5.3151E-006$$

$$R = 1.0000$$


$$DL = 0.0006947$$

$$BEC = 0.001172$$


Weight: <None>

Min Conc: 0


6 Li (ISTD) [No Gas]




	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		1935193.70		A	1.8
2	☐	1.000		1925779.27		A	0.2
3	☐	1.000		1882070.06		A	2.2
4	☐	1.000		1764457.18		A	3.3
5	☐	1.000		1696785.79		A	2.1
6	☐	1.000		1635475.35		A	0.7
7	☐	1.000		1612612.18		A	0.7
8	☐	1.000		1602401.29		A	2.6

45 Sc (ISTD) [No Gas]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		2861612.11		A	3.8
2	☐	1.000		2827474.96		A	0.6
3	☐	1.000		2794643.08		A	0.8
4	☐	1.000		2630764.46		A	2.6
5	☐	1.000		2525775.43		A	1.9
6	☐	1.000		2477388.47		A	2.7
7	☐	1.000		2397006.96		A	1.2
8	☐	1.000		2433202.52		A	2.1

45 Sc (ISTD) [He]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		99846.47		P	1.1
2	☐	1.000		101693.86		P	4.8
3	☐	1.000		95999.22		P	2.1
4	☐	1.000		87490.78		P	9.9
5	☐	1.000		85261.11		P	2.4
6	☐	1.000		84905.64		P	0.9
7	☐	1.000		83472.80		P	0.5
8	☐	1.000		93602.35		P	1.7

89 Y (ISTD) [No Gas]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		8153800.02		A	2.4
2	☐	1.000		8077058.21		A	0.4
3	☐	1.000		8040518.49		A	1.1
4	☐	1.000		7557496.97		A	2.5
5	☐	1.000		7300737.25		A	1.2
6	☐	1.000		7258715.10		A	1.4
7	☐	1.000		7125691.63		A	1.1
8	☐	1.000		6980387.74		A	1.4

89 Y (ISTD) [He]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		859691.34		P	0.4
2	☐	1.000		879581.36		P	4.5
3	☐	1.000		837192.97		P	1.1
4	☐	1.000		762891.72		P	9.2
5	☐	1.000		741712.10		P	2.0
6	☐	1.000		735318.15		P	0.9
7	☐	1.000		717142.90		P	0.5
8	☐	1.000		791301.26		P	2.0

103 Rh (ISTD) [No Gas]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		4429452.57		A	3.0
2	☐	1.000		4350551.60		A	1.6
3	☐	1.000		4266222.64		A	1.4
4	☐	1.000		4046464.42		A	2.4
5	☐	1.000		3895533.17		A	1.8
6	☐	1.000		3767692.79		A	0.7
7	☐	1.000		3650714.32		A	0.8
8	☐	1.000		3443092.55		A	0.7

103 Rh (ISTD) [He]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		1885513.01		A	1.5
2	☐	1.000		1916496.69		A	4.4
3	☐	1.000		1825353.38		A	2.6
4	☐	1.000		1668189.30		A	9.6
5	☐	1.000		1637653.29		A	1.3
6	☐	1.000		1588475.74		A	2.3
7	☐	1.000		1528219.75		A	0.3
8	☐	1.000		1574962.84		A	1.8

115 In (ISTD) [No Gas]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		4566210.03		A	2.5
2	☐	1.000		4583530.60		A	1.2
3	☐	1.000		4540002.35		A	0.2
4	☐	1.000		4311376.07		A	2.7
5	☐	1.000		4165449.05		A	1.3
6	☐	1.000		4059230.70		A	0.5
7	☐	1.000		3968273.92		A	0.6
8	☐	1.000		3919522.18		A	3.4

115 In (ISTD) [He]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		665461.39		P	0.9
2	☐	1.000		677807.19		P	5.1
3	☐	1.000		645342.74		P	1.4
4	☐	1.000		589965.06		P	9.7
5	☐	1.000		574162.20		P	2.0
6	☐	1.000		562528.77		P	0.8
7	☐	1.000		534457.83		P	0.2
8	☐	1.000		596711.22		P	1.8

159 Tb (ISTD) [No Gas]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		6428400.60		A	3.2
2	☐	1.000		6395127.61		A	2.1
3	☐	1.000		6442828.24		A	1.8
4	☐	1.000		6209046.16		A	0.5
5	☐	1.000		6136002.48		A	0.5
6	☐	1.000		6105364.70		A	1.5
7	☐	1.000		5895916.65		A	0.5
8	☐	1.000		5866022.14		A	1.3

159 Tb (ISTD) [He]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		2541349.63		A	1.0
2	☐	1.000		2552408.28		A	4.8
3	☐	1.000		2477789.50		A	1.0
4	☐	1.000		2326570.14		A	10.0
5	☐	1.000		2326181.35		A	1.9
6	☐	1.000		2326028.79		A	1.0
7	☐	1.000		2251277.64		A	0.9
8	☐	1.000		2394648.87		A	2.0

165 Ho (ISTD) [No Gas]


	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		6422969.00		A	2.1
2	☐	1.000		6398554.42		A	0.8
3	☐	1.000		6428662.47		A	1.8
4	☐	1.000		6215015.74		A	0.2
5	☐	1.000		6094167.00		A	1.4
6	☐	1.000		6120369.35		A	0.7
7	☐	1.000		6018792.48		A	0.5
8	☐	1.000		5912036.71		A	3.1

165 Ho (ISTD) [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		2579781.79		A	1.3
2	☐	1.000		2647110.83		A	4.6
3	☐	1.000		2560675.95		A	2.3
4	☐	1.000		2424666.37		A	9.0
5	☐	1.000		2445042.60		A	2.5
6	☐	1.000		2455135.57		A	0.4
7	☐	1.000		2339555.55		A	1.7
8	☐	1.000		2488070.24		A	1.9

209 Bi (ISTD) [No Gas]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		4593322.26		A	1.4
2	☐	1.000		4563099.72		A	1.1
3	☐	1.000		4584957.16		A	1.3
4	☐	1.000		4448685.59		A	1.7
5	☐	1.000		4374598.51		A	2.6
6	☐	1.000		4253317.64		A	0.3
7	☐	1.000		4200540.77		A	1.1
8	☐	1.000		3838255.29		A	1.6

209 Bi (ISTD) [He]

	Rj ct	Conc.	Calc Conc.	CPS	Ratio	Det .	RSD
1	☐	1.000		2092608.68		A	1.0
2	☐	1.000		2102001.63		A	5.4
3	☐	1.000		2040778.89		A	0.9
4	☐	1.000		1906406.17		A	8.6
5	☐	1.000		1907959.97		A	3.3
6	☐	1.000		1894422.84		A	1.4
7	☐	1.000		1782590.16		A	0.5
8	☐	1.000		1767229.42		A	1.6

US EPA Tune Check Report

Operator Name Jaswal

Acq/Data Batch D:\Agilent\ICPMH\1\DATA\IP8022024 MS.b

Acq. Date-Time 2024-02-20 13:21:30

Report Comment ---

Instrument Name G8403A SG19224459

[No Gas]

Sensitivity

Mass	Conc. [ug/l]	Count	CPS	Resp (Required) [cps/ug/l]	Resp (Flag)	RSD%	RSD% (Required)
9		7536	75359.06			0.419	5.000
24		71738	717382.56			0.750	5.000
25		9487	94868.96			0.562	5.000
26		11338	113383.86			0.749	5.000
59		55210	552101.72			0.434	5.000
113		6577	65770.54			0.797	5.000
115		81968	819683.93			1.304	5.000
206		23785	237853.11			1.327	5.000
207		21687	216865.07			1.240	5.000
208		51567	515672.83			1.173	5.000
220		0	1.80			66.898	

Mass	RSD% (Flag)
9	
24	
25	
26	
59	
113	
115	
206	
207	
208	
220	


Mass	Rep#1 Count	Rep#2 Count	Rep#3 Count	Rep#4 Count	Rep#5 Count
9	7482	7544	7537	7559	7558
24	72400	71501	72102	71011	71678
25	9509	9564	9469	9420	9472
26	11357	11449	11379	11252	11254
59	54860	55152	55464	55170	55405
113	6529	6584	6545	6564	6663
115	81245	82897	82114	80547	83039
206	23483	23666	23584	23924	24269
207	21382	21491	21649	21875	22035
208	51024	51186	51300	51814	52512

US EPA Tune Check Report

Mass	Rep#1 Count	Rep#2 Count	Rep#3 Count	Rep#4 Count	Rep#5 Count
220	0	0	0	0	0

Integration Time [sec] 0.1

Resolution/Axis



Mass	Peak Height	Axis	Axis (Required)	Axis (Flag)
9	13328.85	9.05	8.90 - 9.10	
24	125313.57	24.00	23.90 - 24.10	
25	16939.13	25.00	24.90 - 25.10	
26	19892.47	26.00	25.90 - 26.10	
59	103221.77	59.00	58.90 - 59.10	
113	13780.06	113.05	112.90 - 113.10	
115	170715.28	115.05	114.90 - 115.10	
206	48957.49	205.95	205.90 - 206.10	
207	44733.37	206.95	206.90 - 207.10	
208	106299.53	207.95	207.90 - 208.10	
220	0.20	220.40	-	

Mass	W-50%	W-5%	W-5% (Required)	W-5% (Flag)
9	0.60	0.782	0.900	
24	0.60	0.786	0.900	
25	0.59	0.772	0.900	
26	0.60	0.785	0.900	
59	0.56	0.735	0.900	
113	0.49	0.750	0.900	
115	0.50	0.733	0.900	
206	0.48	0.775	0.900	
207	0.48	0.737	0.900	
208	0.48	0.775	0.900	
220	0.27	0.297		

Integration Time [sec] 0.1

Acquisition Time [sec] 256.770000000002

Y Axis Linear

Tune Parameters

Plasma Parameters

Plasma Mode --- Nebulizer Gas 0.85 L/min Dilution Gas 0.40 L/min

US EPA Tune Check Report

RF Power	1600 W	Option Gas	---	Auxiliary Gas	0.90 L/min
RF Matching	1.80 V	Nebulizer Pump	0.10 rps	Plasma Gas	15.0 L/min
Sample Depth	9.0 mm	S/C Temp	2 °C		

Lens Parameters

Extract 1	-6.0 V	Omega Lens	10.5 V	Deflect	14.2 V
Extract 2	-205.0 V	Cell Entrance	-30 V	Plate Bias	-50 V
Omega Bias	-110 V	Cell Exit	-50 V		

Cell Parameters

Use Gas	No	3rd Gas Flow	---	Energy Discrimination	4.0 V
He Flow	0.0 mL/min	OctP Bias	-8.0 V		
H2 Flow	---	OctP RF	150 V		

QP Parameters

Mass Gain	124	Axis Gain	0.9990	QP Bias	-4.0 V
Mass Offset	125	Axis Offset	0.03		

Hardware Settings

Torch

Torch H	1.4 mm	Torch V	-0.8 mm
---------	--------	---------	---------

EM

Discriminator	4.3 mV	Analog HV	2316 V	Pulse HV	1698 V
---------------	--------	-----------	--------	----------	--------

[He]

Sensitivity

Mass	Conc. [ug/l]	Count	CPS	Resp (Required) [cps/ug/l]	Resp (Flag)	RSD%	RSD% (Required)
59		12695	126952.93			1.404	
89		9488	94884.19			1.573	
205		16448	164482.85			2.510	

Mass	RSD% (Flag)
59	
89	
205	

Mass	Rep#1 Count	Rep#2 Count	Rep#3 Count	Rep#4 Count	Rep#5 Count
59	12991	12674	12701	12547	12563
89	9744	9454	9456	9440	9349
205	17161	16418	16332	16162	16169

Integration Time [sec] 0.1

Tune Parameters

Plasma Parameters

Plasma Mode	---	Nebulizer Gas	0.85 L/min	Dilution Gas	0.40 L/min
RF Power	1600 W	Option Gas	---	Auxiliary Gas	0.90 L/min
RF Matching	1.80 V	Nebulizer Pump	0.10 rps	Plasma Gas	15.0 L/min
Sample Depth	9.0 mm	S/C Temp	2 °C		

Lens Parameters

Extract 1	-6.0 V	Omega Lens	10.5 V	Deflect	3.4 V
-----------	--------	------------	--------	---------	-------

US EPA Tune Check Report

Extract 2	-205.0 V	Cell Entrance	-50 V	Plate Bias	-60 V
Omega Bias	-110 V	Cell Exit	-70 V		

Cell Parameters

Use Gas	Yes	3rd Gas Flow	---	Energy Discrimination	5.0 V
He Flow	4.5 mL/min	OctP Bias	-18.0 V		
H2 Flow	---	OctP RF	200 V		

QP Parameters

Mass Gain	124	Axis Gain	0.9990	QP Bias	-13.0 V
Mass Offset	125	Axis Offset	0.03		

Hardware Settings

Torch

Torch H	1.4 mm	Torch V	-0.8 mm
---------	--------	---------	---------

EM

Discriminator	4.3 mV	Analog HV	2316 V	Pulse HV	1698 V
---------------	--------	-----------	--------	----------	--------