



Analytical Summary Report

Analysis Method: 1010A

Reviewed By: KETANKUMAR

Parameter: Flash Point

Supervisor Review By: apatel

Run Number: LB95534

Ambient Barometric Pressure (mmHg): 755

Reagent/Standard	Lot/Log #
p-xylene (ICV)	W2168

Seq	LabID	True Value °F	DL	Celsius °C	Result °F	Final Result °F	Anal Date	Anal Time
1	ICV	81	1	27.0	80.6	80.9	05/22/2018	13:32
2	J2962-05		1	74.0	165.2	165.5	05/22/2018	13:50
3	J2962-05DUP		1	74.0	165.2	165.5	05/22/2018	14:15

Result = (Celsius * 1.8) + 32

Final Result = Result + (760 - Ambient Barometric Pressure) * 0.06

LB 95539

WORKLIST(Hardcopy Internal Chain)

WorkList Name : FP52218

WorkList ID : 112444

Date : 5/22/2018 1:13:29 PM

Due Date	Matrix	Sample	Test	Preservative	Customer	Storage Location	Customer Sample	Collect Date	Method
05/25/2018	Solid	J2962-05	Flash Point	Cool 4 deg C	PSEG02	I13	DIESEL-TANK	05/16/2018	1010A

Date/Time 05/22/18 1:15 PM
Received by: KS
Relinquished by: CP

Date/Time 05/22/18 14:20
Received by: CP
Relinquished by: KS